

85)14

APR 26 1985

Docket No. 50-237
Docket No. 50-249

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Vice President
P. O. Box 767
Chicago, IL 60690

Gentlemen:

This refers to the routine safety inspection conducted by Mr. S. M. Hare of this office on March 27 through April 17, 1985, of activities at Dresden Nuclear Power Station Units 2 and 3 authorized by NRC Operating License Nos. DPR-19 and DPR-25 and to the discussion of our findings with Mr. D. Scott, Mr. J. Wujciga and others of your staff at the conclusion of the inspection. Additional information concerning this inspection was discussed on April 17, 1985, during a telephone call between Mr. Hare and Mr. Wujciga of your staff.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No items of noncompliance with NRC requirements were identified during the course of this inspection.

As you are aware, due to past as found test failures in 1979, and 1983, Dresden Unit 2 is on an accelerated Type A test schedule. Pursuant to the 10 CFR Part 50, Appendix J, Section III.A.6(b) requirement, the next Unit 2 Type A test shall be performed at the next refueling outage unless you request and are granted an exemption from this requirement by NRR.

During this inspection our inspectors noted evidence of thorough preplanning and conscientious execution of the Type A test by Dresden Station personnel. This represents an improvement in your performance in this area and greatly enhanced the successful conduct of the test.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosure(s) will be placed in the NRC Public Document Room.

8505030500 850426
PDR ADOCK 05000237
G PDR

120111

APR 26 1985

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

"Original signed by R. L. Spessard"

R. L. Spessard, Director
Division of Reactor Safety

Enclosure: Inspection Reports
No. 50-237/85015(DRS);
No. 50-249/85014(DRS)

cc w/encl:
D. L. Farrar, Director
of Nuclear Licensing
D. J. Scott, Station
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Phyllis Dunton, Attorney
General's Office, Environmental
Control Division

RIII
SMH
Hare/cs
04/24/85

RIII
WJ
Guldmond
4/26/85

RIII
Chris
Christimos

RIII
Reyes
Reyes
4/26/85

RIII
Spessard
Spessard
4/26