


Georgia Power Company
Post Office Box 444
Atlanta, Georgia 30303
Telephone: 404-526-8100

Georgia Power Company Services
Post Office Box 444
Atlanta, Georgia 30303
Telephone: 404-526-8100

Georgia Power
Southern Company Services 

D. O. Foster
Vice President and General Manager
Nuclear Project

January 7, 1983

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X75G10
Log: GN-206

Reference: 50-424/82-26
50-425/82-26

Attention: H. C. Dance

Gentlemen:

The Georgia Power Company wishes to submit the following information concerning the deviation discussed in your inspection report 50-424/82-26 and 50-425/82-26.


The Plant Vogtle Manager of GC initiated a directive on 11/3/82 addressing test cycles for cadweld operators. The method of test frequency stipulated in this correspondence assures random specified sampling of splices for each operator, bar size, cadweld type and position. This method has been in effect since 11/3/82.

Georgia Power Field Procedure CD-T-06, Rebar and Cadweld Quality Control is in the process of being revised to formally incorporate the test sample frequency changes.

Full compliance will be achieved by January 14, 1983.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,


D. O. Foster

CWH/DOF/tip

8302150714 830107
PDR ADDCK 05000424
PDR

IE01

cc: U. S. Nuclear Regulatory Commission
Attn: Victor J. Isella, Jr., Director
Office of Inspection and Enforcement
Washington, D.C. 20548

- R. J. Kelly
- R. L. Lamb
- E. F. Reed
- J. T. Buchanan, Jr.
- J. H. Smith
- D. E. Gatten
- R. H. Pinner
- R. L. McHenry
- R. A. Thomas
- L. A. Bailey
- G. Eaton
- R. H. Gregory, III
- E. D. Gruber
- L. T. Gibbs
- M. Nelson
- J. R. Miles, Jr.
- R. Henry
- P. D. Rice
- R. M. Staffa
- J. L. Yula
- K. F. Sanders