

DRAFT 2
07/13/84

WATERFORD OPEN ISSUE

Task: A-115, A-155

Reference No.: 4-84-A-06-10 and 50

Characterization: It is alleged that there were deficiencies in Cadweld splice, tensile testing rates when compared to the requirements in the EBASCO Cadweld specification. It is also alleged that the closure of the nonconformance report (NCR) which identified these deficiencies may not be adequate.

Initial Assessment of Significance: If this allegation is true, it may mean that regulatory commitments have not been met and further evaluation may be necessary to assess the safety significance of the deficiencies.

Source: Gambit Newspaper Article dated December 10, 1983, and Allegor ["A,"] transcript page 130.

Approach to Resolution:

1. Review the EBASCO Cadwelding specification.
2. Review the EBASCO and J. A. Jones Construction Company procedures for work performance and inspections relative to Cadwelding.
3. Review NCR W3-5998.
4. Evaluate the facts against the regulatory requirements.
5. Prepare conclusions and define any necessary action for LP&L.
6. Prepare the SSER.

Status:

Review Lead: L. Shao, Civil-Structural

Support: None.

Estimated Resources: 2 man-weeks.

Estimated Completion: May 25, 1984

CLOSURE:

8510020134 B40713
PDR ADOCK 05000382
PDR

Document Name:
WOI A-115

Requestor's ID:
JOHNNIE

Author's Name:
SHFWMAKER/jkh

Document Comments:
Allegations A-115, A-155

[blank page]

Chawmator
2/12/84

WATERFORD OPEN ISSUE

Task: A-115, A-155

Ref. No.: 4-84-A-06-10 and 50

Characterization: It is alleged that there were deficiencies in Cadweld splice, tensile testing rates when compared to the requirements in the EBASCO Cadweld specification. It is also alleged that the closure of the non-conformance report (NCR) which identified these deficiencies may not be adequate.

Initial Assessment of Significance: If this allegation is true it may mean that regulatory commitments have not been met and further evaluation may be necessary to assess the safety significance of the ~~status~~ deficiencies.

Source: Gannett Newspaper Article dated December 10, 1983 and Allegation transcript page 130

Approach to Resolution:

1. Review the EBASCO Cadwelding specification
2. Review the EBASCO and J.A. Jones Construction Company procedures for work performance and inspections relative to Cadwelding
3. Review NCR W3-5998
4. Evaluate the facts against the regulatory requirements
5. Prepare conclusions and define any necessary action for UP&L
6. Prepare the SSER

Status:

Review Lead: L. Shao, Civil-Structural

Support: None

Estimate Resources: 2 man weeks

Estimated Completion: May 25, 1984

CLOSURE: