

X

**TEXAS UTILITIES GENERATING COMPANY**

2001 BRYAN TOWER • DALLAS, TEXAS 75201

January 18, 1978  
TXX-2678

**R. J. GARY**  
EXECUTIVE VICE PRESIDENT  
AND GENERAL MANAGER

Mr. W. C. Seidle, Chief  
Reactor Construction & Engineering  
Support Branch  
U. S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
611 Ryan Dr., Suite 1000  
Arlington, Texas 76011

FOIA-87-508

Docket Nos. 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
1981-83 2300 MW INSTALLATION  
ORIENTATION OF CADWELD SLEEVES  
FILE NO. 10110

A/4

Dear Mr. Seidle:

On November 22, 1977, we reported to Mr. R. C. Stewart by telephone that we had discovered a nonconformance with the orientation of cadweld sleeves in regard to anchorage of embedded structural steel furnished by a sub-tier supplier. We further indicated to Mr. Stewart that we were evaluating the problem with respect to reportability under 10CFR50.55(e).

We have performed physical tests and engineering evaluations with respect to the units involved and have concluded that the nonconformance was not reportable under the provisions of 10CFR50.55(e). Records supporting this determination are available for your review at the jobsite.

If we can provide any additional information on this subject, please advise.

Very truly yours,

*R. J. Gary*  
R. J. Gary

RJG:d1b

cc: Director, Office of Inspection & Enforcement (15)

Director, Office of Management Information & Program Control (1)  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8709240268 870921  
PDR FOIA  
WILLIAM 87-508 PDR

FILE