



Telegram

VEE089(1107)(1-007192C024)PD 01/24/73, 1105

1973 JAN 24 AM 10:12

ICS IPMVEIB MVN

Is PHYSICAL DELIVERY requested?

(YES-AGENT, NO-NO-AGENT)

ZCZC 02014 MORRIS ILL 66 01-24 1015A CST

ADDRESS OR SECTION

312-858-2660

PMS BOYCE GRIER DIRECTOR DIVN OF COMPLIANCE 1030A

NO.

BG BY DC

REGION 3 US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD

mail

GLEN ELLYN ILL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2:

THIS WILL CONFIRM A CONVERSATION WITH MR MAURA OF YOUR OFFICE AT 1530 HOURS THIS DATE CONCERNING CONDENSOR LOW VACUUM SCRAM SENSOR DRIFT. ROUTINE SURVEILLANCE 1-23-73 FOUND SETTING OF PSL-2-503D HAD DRIFTED BELOW TECH. SPEC. OF 23 INCHES HIGH TO A SETTING OF 22.45 INCHES IGH. SWITCH WAS RESET TO 23.25 INCHES HIGH

W P WORDEN SUPERINTENDENT COMMONWEALTH EDISON
DRESDEN NUCLEAR POWER STATION RRI MORRIS ILL

JAN 26 1973

15A.1

Duplication