



Telegram

VEE274(1453)(1-018775C326)PD 11/21/72 1450

1972 NOV 21 PM 1 57

ICS IPMVEIC MVN

ZCZC 00141 TDVE MORRIS ILL 73 11-21 1145A CST

PMS MR BOYCE GRIER WUX DIRECTOR DIVISON OF COMPLIANCE

REGENT 3 US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN ILL 60137

SUBJECT; DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2;

THIS WILL CONFIRM THE CONVERSATION WITH MRDANCE OF YOUR OFFICE

AT 1030 HOUS THIS DATE CONCERNING DEVIATION REPORTS D-2-72-3 IN WH

ICH ALL MAIN STEAM LINE LOW PRESSURE SWITCHES WERE FOUND TO BE BEL

OW THE TECHNICAL SPECIFICATION LIMITS OF 850 PSIG. ALL

SWITCHES PS-2-261-30 A THROUGH B WERE RESET TO 871 PLUS OR MINUS

4 PPSIG

TELEGRAMS (OTHER THAN MONEY ORDERS) *LB 3-2*

Is PHYSICAL DELIVERY requested? \_\_\_\_\_ (YES-AGENT, NO-ADDRESSES)

WP WORDEN

AGENT SECTION

ADDRESS-SEE SECTION

SUPERINTENDENT

Nbr. & Name

Nbr. *312-858-2660*

COMMONWEALTH EDISON

Date dtd *11-21* Time dtd *5:05P* To *mlg* Ex *284*

To be mailed or filed *Mail*  
NO Attempts to deliver (Indicate DA or BX)

SF-1201 (RS-69)

DRESDEN NUCLEAR STATION

RR NO 1

MORRIS-ILL

SF-1201 (RS-69)