

MGMCGBT HSB
2-040360A254002 09/11/75
ICS IPMVEIB MVN
02242 (8159424449) TDBN MORRIS IL 94 09-11 0430P CDT
ZIP 60137

western union Mailgram



JAMES G KEPPLER, REGIONAL DIRECTOR, DIRECTORATE OF REGULATORY
OPERATIONS REGION THREE US NUCLEAR REGULATORY COMMISSION
799 ROOSEVELT RD
GLEN ELLYN IL 60137

SUBJECT: DPR-19, DRESDEN NUCLEAR POWER STATION, UNIT TWO.
THIS WILL CONFIRM A CONVERSATION WITH MR P JOHNSON OF YOUR OFFICE AT
330 PM THIS DATE CONCERNING A TRIP OF 2/3 DIESEL GENERATOR COOLING
WATER PUMP BREAKER ON BUS 28-3. THE PUMP WAS RUNNING FOR A TEST OF
THIS BREAKER WHICH HAD TRIPPED ON 9-2-75 WHILE THE DIESEL GENERATOR
WAS IN SERVICE. THIS PUMP HAS AN ALTERNATE FEED ON BUS 38-3.
AT THE TIME OF THE PUMP TRIP U?NIT TWO WAS OPERATING AT 810MWE. UNIT
THREE WAS IN COLD SHUTDOWN.

B B STEPHENSON, SUPERINTENDENT DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON CO RR 1 MORRIS IL 60450

20:41 EST

MGMCGBT HSB

SEP 12 1975