



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

January 20, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Units 2 and 3
Proposed Amendment to the
Technical Specifications -
Miscellaneous Changes
NRC Docket Nos. 50-237 and 50-249

Dear Mr. Denton:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Appendix A, the Technical Specifications to Provisional Operating License DPR-19 and Facility Operating License DPR-25. The proposed amendments primarily involve editorial changes and other changes to achieve consistency between Unit 2 and Unit 3.

The proposed amendments for Dresden Units 2 and 3 are provided in Attachments 1 and 2, respectively. A summary of the proposed changes is provided in Attachment 3. The changes primarily involve corrections in nomenclature, sentence structure, references, etc., with the exception of change number 18 (Attachment 3). This change adds a provision for Unit 3 to allow post-maintenance testing of control rod drives in the refuel mode with low pressure cooling systems inoperable. This provision is similar to existing Specification 3.5.F.3 which allows all low pressure cooling systems to be inoperable when in cold shutdown (with restrictions). The proposed change was previously approved for Dresden Unit 2 in Amendment No. 6 to DPR-19. A copy of the NRC approval letter and Safety Evaluation is provided in Attachment 4 for your convenience and is fully applicable to the proposed Unit 3 change.

The proposed changes have been On-Site and Off-Site reviewed and approved. We have reviewed the proposed Technical Specification amendments and determined that no significant hazards consideration exists. Our review is documented in Attachment 5. Commonwealth Edison is notifying the State of Illinois of this request and our no significant hazards determination by transmittal of a copy of this letter and its attachments to the designated State Official.

8601290173 860120
PDR ADDCK 05000237
P PDR

Handwritten:
A001 w/checked
3/40 15000
0013132


January 20, 1986

In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is enclosed.

Please direct any further questions you may have regarding this matter to this office.

Three (3) signed originals and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,




J. R. Wojnarowski
Nuclear Licensing Administrator

lm

- Attachments 1: Technical Specification Changes to DPR-19
2: Technical Specification Changes to DPR-25
3: Summary of Changes
4: Additional Information on Change No. 18
5: Evaluation of Significant Hazards Consideration

cc: R. Gilbert - NRR
NRC Resident Inspector - Dresden
M. C. Parker - State of IL

SUBSCRIBED AND SWORN to
before me this 20th day
of January, 1986


Notary Public