



**Commonwealth Edison**

One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

March 4, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Dresden Station Units 2 and 3  
Proposed Fire Protection License  
Amendment Revised Interim Action  
NRC Docket Nos. 50-237 and 50-249

Reference: Letter from D. L. Farrar to H. R. Denton  
dated December 2, 1985.

Dear Mr. Denton:

The referenced letter proposed an amended License Condition regarding Fire Protection for Dresden and Quad Cities Stations to reflect a number of modifications which had not been completed in accordance with the existing requirement. The attachments to the reference identified the affected modifications and documented interim actions which are in effect until these issues are resolved. This letter documents a change in interim actions as identified in the reference.

Item 2.2 of Attachment 2 to the referenced letter identified a lack of electrical supervision for doors to the Dresden Auxiliary Electric Equipment Room and the doors from the 2/3 Diesel Generator to HPCI rooms. As an interim action, we instituted a fire watch surveillance for these doors. As of March 3, 1986, we have implemented a temporary electrical supervision system for these doors and discontinued the fire watch. This substitution of interim actions was discussed with and agreed to by Mr. W. Guldemon of Region III and the Dresden NRR Project Manager prior to implementation. It will remain in effect until your review of our proposed License amendment is completed.

Please direct any questions you may have concerning this matter to this office. One signed original and forty (40) copies of this letter are provided for your use.

Very truly yours,

J. R. Wojnarowski  
Nuclear Licensing Administrator

lm

cc: W. G. Guldemon - Region III  
R. Gilbert - NRR  
Dresden Resident Inspector

1372K

8603110323 860304  
PDR ADOCK 05000237  
P PDR

A006  
1/0