



**Commonwealth Edison**  
One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

March 10, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

**Subject: Dresden Station Unit 2  
Proposed Technical Specification  
Amendment - Temporary Extension  
of Diesel Generator Allowable  
Outage Period  
NRC Docket No. 50-237**

Dear Mr. Denton:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Provisional Operating License DPR-19 Appendix A, the Technical Specifications, to extend the allowable outage period for the Unit 2/3 Diesel Generator from seven to fourteen days. This extension is requested on a one time only basis to allow installation of Appendix R modifications on the diesel generator.

The proposed Technical Specification amendment is provided in Attachment 1 and has been On-Site and Off-Site reviewed and approved. Our analysis of the issue of No Significant Hazards Consideration (NSHC) as required by 10 CFR 50.91 is provided in Attachment 2. Our analysis has determined that no significant hazards consideration exists.

To provide additional assurance that back-up AC power will be available during the extended outage period, we've established compensatory measures as identified in Attachment 3. These measures are also described in our NSHC analysis.

Commonwealth Edison is notifying the State of Illinois of our request for this amendment and our determination regarding no significant hazards consideration by transmittal of a copy of this letter and its attachments to the designated State Official.

In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is enclosed.

8603170087 860310  
PDR ADDCK 05000237  
PDR

Rec'd w/Check \$150.00

Acc 1/1

March 10, 1986

In order to complete the required Appendix R modifications to the 2/3 diesel generator without impacting the current Unit 3 refueling outage schedule, we request your approval of this amendment by April 21, 1986 or as soon thereafter as possible.

Please direct any questions you may have regarding this matter to this office.

Three (3) signed originals and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,




J. R. Wojnarowski  
Nuclear Licensing Administrator

lm

Attachments (1): Technical Specification Change to DPR-19  
(2): No Significant Hazards Consideration Analysis  
(3): Compensatory Measures

cc: Region III Inspector - Dresden  
R. Gilbert - NRR  
M. C. Parker - State of Ill.

SUBSCRIBED AND SWORN to  
before me this 10<sup>th</sup> day  
of March, 1986



Notary Public