



**Commonwealth Edison**  
One First National Plaza, Chicago, Illinois  
Address, Reply to: Post Office Box 767  
Chicago, Illinois 60690

March 31, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

**Subject: Dresden Station Unit 3  
Proposed Technical Specification  
Amendment - Isolation Condenser  
Return Line Flow Setpoint Revision  
NRC Docket No. 50-249**

Dear Mr. Denton:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Facility Operating License DPR-25 Appendix A, the Technical Specifications to revise the high flow isolation setpoint for the Unit 3 Isolation Condenser Return Line. This change is necessitated by the replacement of the existing elbow taps for sensing flow rate with an annubar flow element. This modification is being performed in conjunction with our current Recirculation Pipe Replacement.

The proposed Technical Specification amendment is provided in Attachment 1 and has been On-Site and Off-Site reviewed and approved. Attachment 2 describes the technical basis for the revised setpoint value. Our analysis of the issue of No Significant Hazards Consideration (NSHC) as required by 10 CFR 50.91 is provided in Attachment 2. Our analysis has determined that no significant hazards consideration exists.

Commonwealth Edison is notifying the State of Illinois of our request for this amendment and our determination regarding no significant hazards consideration by transmittal of a copy of this letter and its attachments to the designated State Official.

In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is enclosed.

8604170168 860331  
PDR ADOCK 05000249  
P PDR


*A001  
11/ w/check  
\$150.00  
#0030500*

March 31, 1986

Please direct any questions you may have regarding this matter to this office. We request approval of this proposed amendment by June 16, 1986 to support our current scheduled startup date of June 30, 1986.

Three (3) signed originals and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,



J. R. Wojnarowski  
Nuclear Licensing Administrator

lm

- Attachments (1): Technical Specification Change to DPR-25  
(2): Technical Basis for Proposed Setpoint  
(3): No Significant Hazards Consideration Analysis

cc: Region III Inspector - Dresden  
R. Gilbert - NRR  
M. C. Parker - State of Ill.

SUBSCRIBED AND SWORN to  
before me this 31<sup>st</sup> day  
of March, 1986

  
Notary Public