



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

May 14, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Dresden Station Units 2 and 3
Quad Cities Station Units 1 and 2
Proposed Technical Specification Amendment
4 kv Cross-tie Operability
NRC Docket Nos. 50-237/249 and 50-254/265

Reference: Letter from M. S. Turbak to H. R. Denton
dated December 13, 1985

Dear Mr. Denton:

The referenced letter transmitted Commonwealth Edison's review of the Dresden Station electrical distribution system with respect to General Design Criterion 17. In that transmittal, we committed to submit a Technical Specification amendment to impose operability requirements on the existing 4 kv cross-tie which provides an alternate source of off-site AC power to Dresden Units 2 and 3. Accordingly, pursuant to 10CFR50.90, Commonwealth Edison propose to amend Provisional Operating License DPR-19 and Facility Operating Licenses DPR-25, 29 and 30 for Dresden Units 2 and 3 and Quad Cities Units 1 and 2 respectively. The proposed amendments impose operability requirements on the 4kv cross-tie similar to the existing operability requirements on other sources of AC power.

The proposed Technical Specification amendments are provided in Attachments 1 and 2 for Dresden Units 2 and 3 and Quad Cities Units 1 and 2 respectively. These proposed amendments have been On-Site and Off-Site reviewed and approved. Our analysis of the issue of No Significant Hazards Consideration (NSHC) as required by 10 CFR 50.91 is provided in Attachment 2. Our analysis has determined that no significant hazards consideration exists.

Commonwealth Edison is notifying the State of Illinois of our request for this amendment and our determination regarding no significant hazards consideration by transmittal of a copy of this letter and its attachments to the designated State Official.

In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is enclosed.

8605220193 860514
PDR ADOCK 05000237
PDR

Rec'd w/fee - \$150.00

A001
3/30

Please direct any questions you may have regarding this matter to this office.

Three (3) signed originals and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,




J. R. Wojnarowski
Nuclear Licensing Administrator

bs

- Attachments (1): Technical Specification Changes to DPR-19 and 25
- (2): Technical Specification Changes to DPR-29 and 30
- (3): No Significant Hazards Consideration Analysis

- cc: R. Gilbert - NRR
- R. Bevan - NRR
- J. Harrison - Region III
- Resident Inspectors - Dresden/Quad Cities
- M. C. Parker - State of Illinois

SUBSCRIBED and SWORN to
before me this 14th day
of May, 1986



Notary Public