



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690 - 0767

January 15, 1987

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Dresden Station Unit 2
Systematic Evaluation Program IPSAR
Schedule For Submittal of Remaining
open Topics
NRC Docket No. 50-237

Dear Mr. Denton:

It is the intent of Commonwealth Edison to provide the final responses to the remaining open SEP Topics according to the following schedule.

Topic III-1, Section 4.2.2

The response to the concern about radiography requirements and fracture toughness of components important to safety to be provided by April 1, 1987.

Topic III-4.A, Section 4.5.4

It is understood that the remaining concern of this topic is to describe the Safety-Related equipment located behind the outer wall of the Turbine Building ("C" wall). This question stemmed from the staff review of the Probabilistic Assessment of Tornado Missile Hazards at Dresden Station. This response will be provided by April 1, 1987.

Topic VI-7.C.1, Section 4.21.5

The remaining response for this topic is to address the request for additional information concerning the separation of 1E sources from Non-1E loads. This response will be provided by May 1, 1987.

Topic VI-10.B, Section 4.23.1

To resolve this topic CECO was to revise existing procedures which are used to find grounds in the D.C. System. The revised procedure is to add safeguards during the search for grounds in 125VDC and 250VDC Systems. The procedure changes for the 125VDC system have been revised, and CECO needs to revise the 250VDC procedure accordingly. A response to this concern will be provided by May 1, 1987.


A001
1/6

8702030330 870115
PDR ADOCK 05000237
P PDR

Responses to the foregoing topics should complete the remaining open items.

Please address any questions you may have concerning this matter to this office.

Very truly yours,


for J.R. Wojnarowski
Nuclear Licensing
Administrator

cc: J.Stang -NRR
Resident Inspector - Dresden
NRC Region III Regional Administrator

DS/sj/8902D

DS 1/23/87