



**Bechtel Power Corporation**  
**April 1980**

**- NOTICE -**

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE Docket # 50-249  
Control # 8005300089  
Date 4/29/80 of Document  
REGULATORY DOCKET FILE


**REGULATORY DOCKET FILE COPY**

RECORDS FACILITY BRANCH

**RESPONSE TO IE BULLETIN 79-01B**  
**DRESDEN**  
**NUCLEAR POWER STATION**  
**UNIT 3**

**Volume 1**

**Commonwealth Edison**



RESPONSE TO IE BULLETIN 79-01B

FOR

DRESDEN NUCLEAR POWER STATION UNIT 3

COMMONWEALTH EDISON COMPANY

DOCKET NUMBER 50-249

PREPARED BY: BECHTEL POWER CORPORATION

Report Date: April 21, 1980

## TABLE OF CONTENTS

### VOLUME 1

	<u>Page</u>
1.0 STUDY OBJECTIVES	1
2.0 STUDY RESULTS	1
3.0 STUDY CONCLUSIONS AND RECOMMENDATIONS	2
4.0 DETAILED EVALUATION	2
4.1 Definition of Postulated Accidents	3
4.2 Identification of Class IE Components Required to Function Under Postulated Accident Conditions (Bulletin Action Item 1)	4
4.3 Definition of Environmental Service Conditions (Bulletin Actions Items 3 and 5)	4
4.4 Evaluation of Environmental Qualification Data (Bulletin Action Items 2 and 4)	7
4.5 Class IE Equipment Qualification Plan	8
4.6 Submittal of Licensee Event Reports (Bulletin Action Item 6)	9
5.0 REFERENCES	10

### APPENDIXES

- A Dresden Unit 3 and Common Systems List
- B Dresden Unit 3 and Common Specific and General Use Components List Sorted by System
- C Dresden Unit 3 Key Plan Identifying Harsh Environmental Areas and Tabulation of Service Conditions, List of Figures and Tables

### VOLUMES 2 AND 3

- D Dresden Unit 3 and Common Component Evaluation Worksheets Sorted by System

## 1.0 STUDY OBJECTIVES

This study has been prepared in response to NRC IE Bulletin 79-01B, dated January 14, 1980. It has been prepared by Bechtel Power Corporation, Ann Arbor, Michigan, for Commonwealth Edison Company's Dresden Nuclear Power Station Unit 3.

The scope of the study includes:

- a. Preparing a master list of all ESF systems
- b. Identifying all components required to function under postulated accident conditions
- c. Defining environmental service conditions for the components identified above
- d. Establishing maximum flood elevation inside containment
- e. Evaluating qualification data for components and document bases of equipment qualification
- f. Identifying for Commonwealth Edison Company, those Class IE electrical equipment items for which a Licensee Event Report (LER) should be prepared
- g. Preparing a report documenting the results of the study in accordance with Item 7 of NRC IE Bulletin 79-01B

## 2.0 STUDY RESULTS

The systems required to function following the postulated accidents have been identified and the essential Class IE components listed. Environmental service conditions have been established. Evaluation of environmental qualification test reports is currently in progress. Table 2-1 provides the completion status of each of the bulletin action items.

## 3.0 STUDY CONCLUSIONS AND RECOMMENDATIONS

Investigations in response to NRC IE Bulletin 79-01B Action Items 2 and 4 are presently partially complete. There are no conclusions at this time.

It is recommended that investigations continue to complete the response to NRC IE Bulletin 79-01B Action Items 2 and 4.

## **4.0 DETAILED EVALUATION**

### **4.1 DEFINITION OF POSTULATED ACCIDENTS**

NRC IE Bulletin 79-01B defines the postulated accident conditions to be addressed as the loss-of-coolant-accident/high energy line break (LOCA/HELB) inside containment, and the HELB outside containment.

For the Dresden Nuclear Power Station Unit 3, the LOCA/HELB inside containment is discussed in FSAR Sections 5.2.3 and 6.2.7. The HELB outside containment is discussed in Special Report No. 37, Revision 1, submitted to the NRC in February 1975.

For the LOCA/HELB inside containment, worst case environmental conditions are established by the LOCA, resulting from a double-ended recirculation line break. The environmental conditions which result from this accident are provided in Section 4.3 and Appendix C.

For a HELB outside containment, Special Report No. 37 identifies the high energy lines and the location of postulated breaks. In support of the response to IE Bulletin 79-01B, studies were performed to establish equipment integrated radiation doses as a result of the postulated accidents. These environmental conditions are discussed in Section 4.3.

The following postulated accidents established the environmental conditions:

- a. LOCA inside drywell
- b. Main steam line break in the steam tunnel
- c. Main feedwater line break
- d. High-pressure coolant injection (HPCI) steam line break
- e. Isolation condenser steam line break
- f. Reactor water cleanup (RWCU) line break

Where components, because of their location, could be subjected to differing environments for the various accidents, the most severe environmental conditions were utilized for qualification. Components located within compartments with postulated HELBs would be subjected to pressure, temperature, and humidity conditions resulting from that HELB, but would

not be subjected to radiation doses in excess of  $10^4$  rads simultaneously. These same components could be subjected to radiation doses in excess of  $10^4$  rads following a LOCA, but these doses would not be simultaneous with pressure, temperature, and humidity. To simplify this analysis, qualification data will be sought which demonstrates operability of these components for the combination of all environmental conditions. Where qualification cannot be demonstrated for the entire spectrum of conditions simultaneously, components will be evaluated for the conditions associated with each individual accident.

#### 4.2 IDENTIFICATION OF CLASS IE COMPONENTS REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS (BULLETIN ACTION ITEM 1)

The Dresden Nuclear Power Station FSAR and emergency procedures were reviewed to identify the engineered safety features systems which are required to mitigate the consequences of the postulated accidents discussed in Section 1.0. These systems are those needed to achieve reactor shutdown, containment isolation, reactor core cooling, containment and reactor heat removal, and to prevent the release of radioactive material to the environment in excess of the guidelines of 10 CFR 100.

In addition, the emergency procedures were reviewed to identify systems that are non-class IE, and not considered in the station safety evaluation for accident mitigation, but which would be utilized if available. These systems are identified as alternative use systems. No data is provided for components in alternative use systems.

Appendix A provides the master list of Unit 3 and common systems required to function following all of the postulated accidents discussed in Section 4.1.

The station piping and instrument diagrams and electrical schematics were reviewed to determine the specific components which must function following the postulated accidents. Based on this review, a master components list has been developed for each system identified in Appendix A. The master components list identifies each Class IE electrical component that is required to function following the postulated accidents discussed in Section 4.1. Appendix B provides the master components lists for Unit 3 and common systems.

#### **4.3 DEFINITION OF ENVIRONMENTAL SERVICE CONDITIONS (BULLETIN ACTION ITEMS 3 AND 5)**

##### **4.3.1 Inside the Drywell**

The drywell pressure and temperature response following the postulated LOCA are provided in FSAR Figures 5.2.11 and 5.2.12, respectively. These figures are included in Appendix C. The maximum humidity inside the drywell is defined in FSAR Table 5.2.2 as 100%. Chemical sprays are not used in the Dresden design. Demineralized water containment spray is utilized and considered in the evaluation. The Dresden FSAR does not provide integrated radiation doses inside the drywell. Studies were performed to establish the integrated doses inside the drywell for a postulated LOCA. The integrated doses for 1 hour, 1 day, 30 days, and 1 year are provided in Appendix C. The study methodology is described in Section 4.3.5. Radiation doses are evaluated for actual equipment operating times. Appendix C also defines the containment spray fluid and provides the maximum drywell pressure, temperature, humidity, flood elevation.

##### **4.3.2 Outside the Drywell, Subject to HELB**

HELB is discussed in detail in Special Report No. 37, Revision 1, submitted to the NRC in February 1975. The environmental conditions (pressure, temperature, and humidity), due to pipe break in the steam tunnel, torus compartment, RWCU heat exchanger room and turbine building are listed in Appendix C. Radiation doses following a HELB are less severe than the doses associated with a LOCA and are therefore not provided. Flooding does not occur outside the drywell as a result of the postulated HELBs. Chemical and demineralized water spray do not exist outside the drywell.

##### **4.3.3 Outside the Drywell, Post-LOCA Radiation Exposures**

Integrated doses have been calculated for areas outside the drywell. Doses were established for 1 day, 30 days, and 1 year exposure. Integrated doses of less than  $10^4$  rads during a component's service life are evaluated as nonharsh environmental conditions. Integrated doses of  $10^4$  rads and greater are evaluated as harsh environmental conditions. Appendix C provides integrated doses as a function of exposure time for areas containing components identified in Appendix B. The radiation study methodology is described in Section 4.3.5.

##### **4.3.4 Nonharsh Areas**

Plant areas which are not covered in the above referenced Appendix C tables are considered nonharsh environmental areas with respect to HELB and post-LOCA radiation. These

areas are either maintained in a suitable environmental condition by safety-related heating, ventilating and air conditioning (HVAC) equipment, or are considered nonharsh because they are controlled to less than 104F prior to the postulated accidents and are relatively large open areas with no large motors or other equivalent heat sources.

Where environmental conditions are maintained by HVAC equipment, the HVAC system is provided with redundant components and/or a backup power supply for reliable operation. Safety related HVAC systems are provided for the following areas:

- a. Control room, cable spreading room, battery rooms, computer room, and electrical equipment room
- b. Standby diesel generator room
- c. HPCI room
- d. Low-pressure coolant injection corner rooms

#### 4.3.5 Radiation Study Methodology

A radiation study was performed to establish integrated doses to equipment following a postulated LOCA. The core fission product inventory was based on General Electric document "Radiation Source Information for NUREG 0578 Implementation, Computer Run Identified as SNUMB 7007S" dated November 1979.

The fission products were diluted into the appropriate fluid media as follows:

<u>Fluid</u>	<u>Noble Gases(%)</u>	<u>Halogens(%)</u>	<u>Other(%)</u>
Suppression pool liquid	50	-	1
Reactor coolant liquid	100	50	1
Containment atmosphere	100	25	-
Reactor steam	100	25	-

Dilution of the fission products was considered using the fluid volume as the dilution media.

For components located inside the drywell, gamma doses were only considered if the component was enclosed in a nonorganic material (e.g., valve motor actuators in metal enclosures). The gamma dose was established based on immersion of the component in the gaseous drywell atmosphere for the time which the component must remain functional. For components

enclosed in organic material (e.g., cable), beta radiation doses will be calculated and the total exposure (gamma and beta) used to define the environmental service condition. The integrated dose will be based on the time which the component must remain functional.

For components located outside the drywell, source terms were established for piping systems containing reactor steam, reactor coolant liquid, suppression pool liquid, and containment atmosphere. Since the piping wall thickness is sufficient to shield against beta radiation only gamma radiation need be considered. Each Class IE component was located with respect to the piping systems containing post-LOCA radioactive fluids. The integrated dose was established based on the piping source term, distance from pipe to component, and component operating time. Where a component could receive dose from more than one piping system, the doses were added to derive a total dose. Appendix C, Table C-3, provides integrated doses as a function of time calculated one foot from the greatest single source in each plant major area.

#### 4.3.6 Aging

In this study, the need to consider aging is based on the evaluation of component design and application. The effects of aging have also been considered based on Enclosure 4 to NRC Bulletin 79-01B, "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment."

##### a. Components Located Inside the Drywell

The environmental conditions inside the drywell are defined as harsh (Sections 4.3.1 and 4.3.4) and hence the effects of thermal and radiation aging are evaluated for all Class IE electrical components.

##### b. Components Located Outside the Drywell

###### 1. Radiation aging

The components which are located outside the drywell and steam tunnel are exposed to insignificant amounts of radiation during normal operating conditions. The effects of radiation aging are therefore not considered in the qualification evaluation of these components.

Under postulated accident conditions some components may be exposed to greater than  $10^4$  rads (integrated radiation dose). The effects of this short-term radiation exposure are considered in the qualification evaluation.

## 2. Thermal aging

Most areas outside the drywell are maintained in a suitable environmental condition by safety-related HVAC equipment. The normal maximum environmental design temperature is 103F, which in this study is defined as a nonharsh environment (Section 4.3.4). Thermal aging for these components is not required since the normal and post-accident environments are nonharsh. In addition, infrequent temperature extremes up to 120F may occur in some plant areas. However, these conditions would result only during periods of extreme outdoor temperatures. Equipment designed and installed per industry standards would be capable of satisfactory operation without exhibiting age related degradation due to these infrequent temperature extremes up to 120F. Therefore, the effects of thermal aging are not considered for components located in areas where the maximum ambient temperature can be maintained at 120F or below.

The effects of aging will be considered for components in harsh environments and components with a defined operating life less than 30 years.

## 4.4 EVALUATION OF ENVIRONMENTAL QUALIFICATION DATA (BULLETIN ACTION ITEMS 2 AND 4)

Appendix B identifies all specific components necessary following the postulated accidents. In addition, this bulletin covers general use electrical items such as motor lubricating oil, sealants, tape, terminal blocks, gaskets, etc. These general use items are discussed in Section 4.5.

For each specific component identified in Appendix B, a component evaluation worksheet was prepared. These worksheets identified the most harsh environment each component would be subjected to following the postulated accidents. Environments were considered nonharsh when the temperature was controlled to 104F or less and the maximum integrated radiation dose was less than  $10^4$  rads.

Since industry standards did not exist for environmental qualification of Class IE electrical equipment during the time frame the Dresden station was designed and constructed, qualification testing was not required for these components when originally purchased. However, many of these same components were used in later designs and qualification testing data is available. Also some testing has been performed by the Nuclear Steam System Supplier in response to IE Bulletin 79-01. These qualification reports are being evaluated to determine their applicability to the components identified in Appendix B. Where applicable qualification data exists, this data is entered on the component evaluation worksheets to document the suitability of the component.

It is anticipated that some components may be qualified by analysis or a combination of analysis and testing. In those cases the component evaluation worksheets will reference the subject analysis and document the suitability of the component.

Finally for those components which are exposed to harsh environments and for which data is not available and qualification by analysis is not appropriate, the qualification status will be resolved by testing, replacement, or relocation of the component to a nonharsh environment.

The component evaluation worksheets are provided in Appendix D (Volumes 2 and 3) for Unit 3 and common components.

Section 4.5 provides the qualification plan which will be followed to complete the response to IE Bulletin 79-01B.

#### 4.5 CLASS IE EQUIPMENT QUALIFICATION PLAN

##### 4.5.1 Specific Components

Where existing data is not available to demonstrate qualification of a component, one of the following methods will be utilized to resolve the status of the component.

- a. Tests on similar components will be evaluated. Where the component is sufficiently similar to the qualified component, the test data and component design data will be analyzed. Providing sufficient similarity exists to utilize the report for the similar component, the evaluation will be documented and the analysis and test report referenced as demonstrating the suitability of the component.

- b. An identical component from the spare parts inventory or one of the installed components will be tested.
- c. The component will be relocated in a nonharsh environment.
- d. The component will be replaced.

#### 4.5.2 General Use Components

A walkdown inspection of accessible electrical boxes and cable connections was performed in the Dresden Unit 3 drywell. The inspection was performed following the spring 1980 refueling outage prior to returning the station to power. Mr. J. Hughes, NRC Region III inspector, was onsite and accompanied the inspection team for a portion of the drywell inspection.

The purpose of the inspection was to identify miscellaneous general use electrical items (i.e., gaskets, seals, grommets, terminal blocks, splices, and termination tapes) used inside the drywell. In addition, the condition of cable at the electrical boxes and component terminations was inspected. Boxes which did not have preassigned numbers were numbered by the inspection team. These field-assigned numbers were prefixed with 79-01B. The condition of cables entering boxes was satisfactory with no damage noted. The boxes were generally in satisfactory condition, with minor repairs required of three boxes. This information was discussed with station electrical personnel who agreed to make the repairs prior to returning the unit to power. Splices and termination tapes were not found in the electrical boxes inspected. The results of the electrical box inspection are provided in Table 4-1.

Where qualification data is not available for existing installed materials, procedures will be written to replace these items with qualified materials. The station inventory of lubricating oils and greases will include qualified materials and steps implemented so that only these materials are utilized on Class IE components.

#### 4.6 SUBMITTAL OF LICENSEE EVENT REPORTS (BULLETIN ACTION ITEM 6)

In the event any Class IE electrical equipment item is determined to be not capable of meeting its required function under the established service conditions, Bechtel will advise Commonwealth Edison Company so that a LER can be submitted. LERs, when submitted, will identify the component conditions which it must function under and basis of determination that

it is incapable of functioning. Where justification for continued station operation exists, this will be included in the LERs. LERs will be submitted within the time frame specified by NRC IE Bulletin 79-01B.

LERs will not be submitted for items previously documented as not being capable of meeting their required function in the response submitted for NRC IE Bulletin 79-01 (Reference 5e).

#### 5.0 REFERENCES

- a. USNRC IE Bulletin 79-01B, dated January 14, 1980
- b. Dresden Nuclear Power Station Final Safety Analysis Report, Docket Number 50-237 and 50-249
- c. Analysis of Effects of Pipe Break Outside Primary Containment, Dresden Station, Units 2 and 3, Special Report No. 37, Revision 1, February 1975
- d. Dresden Station Emergency Procedures, DGA-1, Loss-of-Coolant (Break Inside Drywell), Revision 4, January 1980; DGA-2, Loss-of-Coolant (Slow Leak), Revision 2, January 1980; DGA-3, Loss-of-Coolant (Break Outside Drywell), Revision 4, January 1980
- e. Report on Results on Qualification Data Search for Dresden Units 2 and 3, NEDO-24218, General Electric Company, November 1979
- f. NUREG-0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment

TABLE 2-1  
NRC IE BULLETIN ACTION ITEM  
COMPLETION STATUS

<u>Action Item</u>	<u>Status</u>	<u>Forecast Completion</u>
1	Completed - Report Appendixes A and B	--
2	Partially complete - investigations to resolve qualification status of components for which test reports are presently unavail- able in progress - Report Appendix D	June 2, 1980
3	Completed - Report Appendix C	--
4	This item included with Action Item 2	June 2, 1980
5	Completed - Report Appendix C	--
6	Licensee Event Reports will be prepared as required	--

TABLE 4-1

TABULATION OF FIELD INSPECTION  
DATA FOR ELECTRICAL BOXES INSIDE DRYWELL

<u>Component</u>	<u>Box Number</u>	<u>Type</u>	Location		<u>Terminal Blocks Type</u>	<u>Remarks</u>
			<u>Elev</u>	<u>Azim</u>		
MO-3-1301-4	79-01B-11	Pull	538	190	NA	MO-3-1001-1B connected to same box
MO-3-1301-4	79-01B-25	Conduit Pull	536	85	NA	
AO-3-203-1A	79-01B-16	Term	521	15	GE264B965	
AO-3-203-1A	79-01B-17	Term	524	15	AB (to be confirmed)	Replace terminal blocks in next outage
AO-3-203-1B	79-01B-14	Term	521	5	GE264B965	Cleaning done by electrician during inspection; gasket broken
AO-3-203-1B	79-01B-15	Term	524	5	AB (to be confirmed)	Gasket broken
AO-3-203-1C	79-01B-20	Term	521	355	GE264B965	Cleaning done by electrician during inspection; gasket broken
AO-3-203-1C	79-01B-21	Term	521	355	AB (to be confirmed)	Gasket broken
AO-3-203-1D	79-01B-18	Term	524	345	GE264B965	Gasket broken
AO-3-203-1D	79-01B-19	Term	524	345	AB (to be confirmed)	

TABLE 4-1 (Continued)

<u>Component</u>	<u>Box Number</u>	<u>Type</u>	Location		<u>Terminal Blocks</u>	<u>Remarks</u>
			<u>Elev</u>	<u>Azim</u>	<u>Type</u>	
POS SW for AO-3-1501-26A	79-01B-24	Pull	520	90	NA	
POS SW for AO-3-1501-26B	79-01B-12	Term	524	210	GE264965	Recommended to foreman electrical maintenance to replace the terminal blocks; gasket broken.
POS SW for AO-3-1501-26B	79-01B-13	Pull	537	210	NA	Opened with NRC
AO-3-220-51 AO-3-220-52	79-01B-5	Term	575	90	GE264B265	
SRM/IRM	None	Pull	520	200	NA	All cables run into a steel duct.
Electrical penetrations low voltage-signal and power	None	NA	Var-ies	Var-ies	NA	

TABLE 4-1 (Continued)

<u>Component</u>	<u>Box Number</u>	<u>Type</u>	<u>Location</u>	<u>Elev</u>	<u>Azim</u>	<u>Terminal Blocks Type</u>	<u>Remarks</u>
MO-3-220-1	None	NA	NA	NA	NA	NA	Component located at el 517 and AZ355. No box could be located. Conduits good condition.
SO-3-220-44	79-01B-3	Pull	539	85	NA		Inside of box could not be inspected
SP-3-220-44	79-01B-4	Pull	539	90	NA		Inside of box could not be inspected
MO-3-1201-1	79-01B-1	Term	540	120	NA		Inside of box could not be inspected.
MO-3-1001-1A	NA	NA	522	350	NA		Box could not be located. Equipment located.
MO-3-1001-1B	79-01B-11	Pull	538	210	NA		MO-3-1301-4 connected to same box
MO-2-2301-9	NA	NA	NA	NA	NA		Located outside drywell (M-51)
MO-2-3706	NA	NA	NA	NA	NA		Box could not be located
POS SW for AO-3-1501-25A	NA	NA	NA	NA	NA		Not accessible because of high radiation
POS SW for AO-3-1501-25B	79-01B-2 (CECo 3RB-32)	NA	517	265	NA		Not opened
POS SW for AO-3-1501-26A	79-01B-23	Term	522	90	GE264B965		Recommended to foreman electrical maintenace to replace the cover and gasket

APPENDIX A

DRESDEN UNIT 3 AND COMMON  
SYSTEMS LIST

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

DRESDEN 3

Systems Required Following a LOCA, MSLB, HELB

1. Reactor Protection/Neutron Monitoring System
2. Core Spray System
3. High-Pressure Coolant Injection System
4. Auto Depressurization System/Main Steam System
5. Low-Pressure Coolant Injection System
6. Pressure Suppression System
7. Standby Gas Treatment System
8. Deleted (Included With 1)
9. Service Water System
10. Diesel Oil Piping System
11. Containment Isolation System\*
12. Control Rod Drive Hydraulic System
13. Reactor (Nuclear Boiler) Recirculation System
14. Process Radiation Monitoring System
- 15A. Reactor Building Ventilation System
- 15B. Control Room, Office, and Drywell Air Conditioning
16. Standby Alternating Current Power
17. Standby Direct Current Power
18. Isolation Condenser System
19. General Use Electrical Equipment
20. Main Steam (Alternate Use Only)
21. Main Feedwater/Condensate (Alternate Use Only)

\* Containment isolation includes all components in various systems performing the containment isolation function.

APPENDIX B

DRESDEN UNIT 3 AND COMMON SPECIFIC  
AND GENERAL USE COMPONENTS LIST SORTED  
BY SYSTEM

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Reactor Protection/Neutron Monitoring

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location	
Plant Identification Number	Generic Name (**)	Inside Primary Containment	Outside Primary Containment
*LS-3-302-82A,B,C,D	Level Switch (M-365)		X
PS-3-503A,B,C,D	Pressure Switch Low (M-346)		X
*AO-3-203-1A,B,C,D	Glove Valve, Air Operated (M-345)		X
*PS-3-1621A,B,C,D	Pressure Switch - High (M-356)		X
*PS-3-263-55A,B,C,D	Pressure Switch (M-357)		X
*LIS-3-363-57A,B	Level Indication Switch (M-357)		X
*LIS-3-263-58A,B	Level Indication Switch (M-357)		X
*RE-3-1705-2A,B,C,D (3-1734-A,B,C,D)	Radiation Element (M-345)		X
RAM-3-0762A,B,C,D, E,F,G,H	IRM Preamplifier		X
***APRM-1, 2, 3A, 3B, 4A, 4B, 5,6	Average Power Range Neutron Monitor		
RAM-3-0752A,B,C,D	SRM-Preamplifier		X
****TE-3-1291-60A,B, C,D,E,F,G,H	Temperature Element		X

\* These components are listed for information only. Their qualification evaluation is covered with their respective systems.

\*\* Shows P&ID number of respective system

\*\*\* The existence of the related instrument outside the control room shall be determined later.

\*\*\*\* Area temperature detectors for reactor cleanup

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Core Spray

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>	
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Contain-ment</u>	<u>Outside Primary Contain-ment</u>
MO-3-1402-25A,B	Gate Valve, Motor Operated		X
MO-3-1402-24A,B	Gate Valve, Motor Operated		X
MO-3-1402-4A,B	Globe Valve, Motor Operated		X
FT-3-1461A,B	Flow Transmitter		X
PT-3-1460A,B	Pressure Transmitter		X
3-1401A,B	Core Spray Pump		X
MO-3-1402-3A,B	Gate Valve, Motor Operated		X
FS-3-1464A,B	Flow Switch		X
MO-3-1402-38A,B	Gate Valve, Motor Operated		X
PS-3-1466A,B,C,D	Pressure Switch		X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: High-Pressure Coolant Injection

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>	
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Contain-ment</u>	<u>Outside Primary Contain-ment</u>
MO-3-2301-5	Gate Valve, Motor Operated		X
MO-3-2301-3	Gate Valve, Motor Operated		X
SV 12	Turbine Stop Valve		X
PT-3-2359	Pressure Transmitter		X
FT-3-2358	Flow Transmitter		X
MO-3-2301-9	Gate Valve, Motor Operated (dc)		X
MO-3-2301-8	Gate Valve, Motor Operated (dc)		X
None	Turbine Gland Seal Condenser Hotwell Drain Pump (dc)		X
PT-3-2382	Pressure Transmitter		X
MO-3-2301-35	Gate Valve, Motor Operated		X
MO-3-2301-6	Gate Valve, Motor Operated		X
TS-3-2370A,B,C,D	Temperature Switch		X
TS-3-2371A,B,C,D	Temperature Switch		X
TS-3-2372A,B,C,D	Temperature Switch		X
TS-3-2373A,B,C,D	Temperature Switch		X
TE-3-2374A,B,C,D	Temperature Element		X

Rev 2  
April 18, 1980  
Page 2

SYSTEM: High-Pressure Coolant Injection

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM

Plant Identification Number	Generic Name	Location	
		Inside Primary Containment	Outside Primary Containment
AO-3-2301-30	Air Operated Valve (Solenoid)		X
POS-3-2301-30	Air Operated Valve (Position Switch)		X
AO-3-2301-29	Air Operated Valve (Solenoid)		X
POS-3-2301-29	Air Operated Valve (Position Switch)		X
MO-3-2301-4	Steam Supply Isolation Valve	X	
None	Motor Speed Changer		X
None	Motor Gear Unit		X
None	Emergency Oil Pump		X
None	Auxiliary Oil Pump		X
None	Gland Steam Exhauster Fan		X
DPIS-3-2352	Differential Pressure Indicating Switch		X
DPIS-3-2353	Differential Pressure Indicating Switch		X
PS-3-2389A,B,C,D	Pressure Switch		X
MO-3-2301-14	Gate Valve, Motor Operated		X
MO-3-2301-15	Gate Valve, Motor Operated		X
MO-3-2301-48	Gate Valve, Motor Operated		X
MO-3-2301-49	Gate Valve, Motor Operated		X

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location (elevation)	
Plant Identification Number	Generic Name	Inside Primary Containment	Outside Primary Containment
AO-3-2301-64	Air Operated Valve (Solenoid)		X
POS-3-2301-64	Air Operated Valve (Position Switch)		X
AO-3-2301-65	Air Operated Valve (Solenoid)		X
POS-3-2301-65	Air Operated Valve (Position Switch)		X
MO-3-2301-36	Gate Valve, Motor Operated		X
MO-3-2301-10	Motor Operated Valve		X
3-2386	HPCI Motor Control Signal Convertor		X
PS-3-2360	Pressure Switch		X
LS-3-2351A,B	Level Switch		X
FS-3-2354	Flow Switch		X
PS-3-2368A,B	Pressure Switch		X
LS-LCS-1	Level Switch		X
LS-2/3-2350A,B,C,D	Level Switch		X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Auto Depressurization/Main Steam

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Location</u>
		Inside      Outside Primary      Primary Contain-      Contain- ment      ment
3-203-3A	Target Rock Valve and Associated Solenoid	X
3-203-3B,C,D,E	Electromatic Relief Valve and Associated Solenoid Valve	X
AO-3-203-1A,B,C,D	Main Steam Isolation Valve with Associated Solenoid Valves	X
POS-3-203-1A,B,C,D	Main Steam Isolation Valve (Position Switch)	X
MO-3-220-1	Globe Valve, Motor Operated	X
TS-3-261-15A,B,C,D 16A,B,C,D 17A,B,C,D 18A,B,C,D	Temperature Switch	X
MO-3-220-2	Globe Valve, Motor Operated	X
AO-3-203-2A,B,C,D	Main Steam Isolation Valve with Associated Solenoid Valve	X
POS-3-203-2A,B,C,D	Main Steam Isolation Valve (Position Switch)	X
DPIS-3-261-2A,B,C, D,E,F,G,H,J,K,L,M, N,P,R,S	Differential Pressure Indication Switch	X
PS-3-0261-30A,B,D,C	Pressure Switch	X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Low-Pressure Coolant Injection

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location	
Plant Identification Number	Generic Name	Inside Primary Contain-ment	Outside Primary Contain-ment
MO-3-1501-5A,B,C,D	Gate Valve, Motor Operated		X
PS-3-1554A,B,C,D,E, F,H,J	Pressure Switch		X
3-A,B,C,D-1502	LP Coolant Injection Pump		X
MO-3-1501-3A,B	Globe Valve, Motor Operated		X
POT-3-1501-3A,B	Position Transmitter		X
DPT-3-1543A,B	Differential Pressure Transmitter		X
MO-3-1501-11A,B	Gate Valve, Motor Operated		X
MO-3-1501-32A,B	Gate Valve, Motor Operated		X
MO-3-1501-13A,B	Gate Valve, Motor Operated		X
FT-3-1549A,B	Flow Transmitter		X
MO-3-1501-18A,B	Globe Valve, Motor Operated		X
MO-3-1501-19A,B	Gate Valve, Motor Operated		X
FT-3-1551A,B	Flow Transmitter		X
FS-3-1501-58A,B	Flow Switch		X

Rev 2  
April 18, 1980  
Page 2

SYSTEM: Low-Pressure Coolant Injection

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location	
Plant Identification Number	Generic Name	Inside Primary Containment	Outside Primary Containment
MO-3-1501-21A,B	Angle Valve, Motor Operated		X
MO-3-1501-22A,B	Gate Valve, Motor Operated		X
MO-3-1501-27A,B	Gate Valve, Motor Operated		X
MO-3-1501-28A,B	Gate Valve, Motor Operated		X
3-A,B,C,D-1501-44	Containment Cooling Service Water Pumps		X
FT-3-1542A,B	Flow Transmitter		X
MO-3-1501-38A,B	Globe Valve, Motor Operated		X
MO-3-1501-20A,B	Gate Valve, Motor Operated		X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Pressure Supression

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>	
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Contain-ment</u>	<u>Outside Primary Contain-ment</u>
LT-3-1641-1	Level Transmitter		X
SO-3-1601-68	Solenoid Valve		X
SO-3-1601-69	Solenoid Valve		X
POS-3-1601-61	Gate Valve, Air Operated (Position Switch)		X
POS-3-1601-60	Butterfly Valve, Air Operated (Position Switch)		X
SO-3-8501-2A,B	Solenoid Valve		X
SO-3-8501-4A,B	Solenoid Valve		X
SO-3-9203A,B	Solenoid Valve		X
SO-3-9204A,B	Solenoid Valve		X
SO-3-8501-6A,B	Solenoid Valve		X
PS-3-1632A,B,C,D	Pressure Switch		X
PS-3-1501-62A,B,C,D	Pressure Switch		X
PS-3-1629A,B	Pressure Switch		X
PS-3-1621A,B,C,D	Pressure Switch		X
PS-3-1628A,B	Pressure Switch		X
PT-3-1625	Pressure Transmitter		X

SYSTEM: Pressure Supression

Rev 2  
April 18, 1980  
Page 2

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM			
		Location	
Plant Identification Number	Generic Name	Inside Primary Contain- ment	Outside Primary Contain- ment
POS-3-1601-23	Butterfly Valve, Air Operated (Position Switch)		X
POS-3-1601-24	Butterfly Valve, Air Operated (Position Switch)		X
POS-3-1601-62	Globe Valve, Air Operated (Position Switch)		X
SO-3-1601-70	Solenoid Valve		X
POS-3-1601-63	Butterfly Valve, Air Operated (Position Switch)		X
POS-3-1601-55	Butterfly Valve, Air Operated (Position Switch)		X
AO-3-1601-55	Air Operated Valve (Solenoid)		X
POS-3-1601-21	Butterfly Valve, Air Operated (Position Switch)		X
POS-3-1601-22	Butterfly Valve, Air Operated (Position Switch)		X
POS-3-1601-56	Butterfly Valve, Air Operated (Position Switch)		X
POS-3-1601-58	Butterfly Valve, Air Operated (Position Switch)		X
SO-3-1601-66	Solenoid Valve		X
MO-3-1601-57	Globe Valve, Motor Operated		X

SYSTEM: Pressure Supression

Rev 2  
April 18, 1980  
Page 3

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM			
Plant Identification Number	Generic Name	Location	
		Inside Primary Contain- ment	Outside Primary Contain- ment
POS-3-1601-59	Globe Valve, Air Operated (Position Switch)		X
SO-3-1601-67	Solenoid Valve		X
POS-3-1601-20A	Butterfly Valve, Air Operated (Position Switch)		X
POS-3-1601-20B	Butterfly Valve, Air Operated (Position Switch)		X
DPT-3-1602-12	Differential Pressure Transmitter		X
DPIS-3-1622A,B	Differential Pressure Indication Switch		X
LT-3-1626	Level Transmitter		X
SO-3-1601-65	Solenoid Valve		X
SO-3-1601-71	Solenoid Valve		X
SO-3-1601-51A,B	Solenoid Valve		X
SO-3-1601-52A,B	Solenoid Valve		X
SO-2-1601-50A,B	Solenoid Valve		X

Facility: Dresden  
Unit: 2/3  
Docket: 50-237/50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Standby Gas Treatment

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location
Plant Identification Number	Generic Name	Inside Primary Contain-ment      Outside Primary Contain-ment
2/3-B-7506	Fan	X
2/3-A-7506	Fan	X
FT-2/3-7541-40B	Flow Transmitter	X
FT-2/3-7541-40A	Flow Transmitter	X
FS-2/3-7541-45A	Flow Switch	X
FS-2/3-7541-45B	Flow Switch	X
2/3-7507B	Butterfly Valve, Motor Operated	X
2/3-7507A	Butterfly Valve, Motor Operated	X
2&3-7503	Butterfly Valve, Motor Operated	X
2/3-7504-B	Butterfly Valves, Motor Operated	X
2/3-7504-A	Butterfly Valves, Motor Operated	X
2/3-7505-B	Butterfly Valve, Motor Operated	X
2/3-7505-A	Butterfly Valves, Motor Operated	X
TS-2/3-7541-11B	Temperature Switch	X

SYSTEM: Standby Gas Treatment

Rev 2  
April 18, 1980  
Page 2

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM

Plant Identification Number	Generic Name	Location	
		Inside Primary Containment	Outside Primary Containment
TS-2/3-7541-11A	Temperature Switch		X
SCR-2/3-7541-36B	SCR		X
SCR-2/3-7541-36A	SCR		X
2/3-B-7503	Electric Air Heater		X
2/3-A-7503	Electric Air Heater		X
FS-2/3-7541-41A,B	Flow Switch		X
2223-28A,B	Local Control Panel		X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Service Water

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Containment</u> <u>Outside Primary Containment</u>
2/3 & 3-3903	Diesel Generator Cooling Water Pumps	X
3-5746A,B	Emergency Air Cooler Reactor Building	X
3-5747	HPCI Building Cooler	X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Diesel Oil Piping

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>
<u>Plant Identification Number</u>	<u>Generic Name</u>	
		Inside    Outside
Primary Containment	Primary Containment	
2/3 & 3-5203	Diesel Oil Transfer Pump	X
LS-3-5241-3	Level Switch (High/Low)	X
LS-2/3-5241-3	Level Switch (High/Low)	X
SO-3-5202	Solenoid Valve	X
SO-2/3-5202	Solenoid Valve	X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Containment Isolation

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>	
<u>Plant Identification Number</u>	<u>Generic Name (**)</u>	<u>Inside Primary Contain-ment</u>	<u>Outside Primary Contain-ment</u>
*AO-3-203-1A,B,C,D	Globe Valve, Air Operated (M-345)	X	
*AO-3-203-2A,B,C,D	Globe Valve, Air Operated (M-345)		X
*MO-3-220-1	Globe Valve, Motor Operated (M-345)	X	
*MO-3-220-2	Globe Valve, Motor Operated (M-345)		X
*SO-3-220-44	Solenoid Valve (M-357)	X	
*SO-3-220-45	Solenoid Valve (M-357)		X
MO-3-1201-1	Gate Valve, Motor Operated	X	
MO-3-1201-2	Gate Valve, Motor Operated		X
MO-3-1201-3	Gate Valve, Motor Operated		X
MO-3-1001-1A,B	Gate Valve, Motor Operated	X	
MO-3-1001-2A,B,C	Gate Valve, Motor Operated		X
MO-3-1001-5A,B	Gate Valve, Motor Operated		X
*MO-3-1501-5A,B,C,D	Gate Valve, Motor Operated (M-360)		X
*SO-3-305-120	Solenoid Valve		X
*SO-3-305-121	Solenoid Valve		X

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location	
Plant Identification Number			
		Inside Primary Contain-ment	Outside Primary Contain-ment
*SO-3-305-122	Solenoid Valve		X
*SO-3-305-123	Solenoid Valve		X
*MO-3-1501-22A,B	Gate Valve, Motor Operated (M-360)		X
*MO-3-1501-18A,B	Globe Valve, Motor Operated (M-360)		X
*MO-3-1501-19A,B	Gate Valve, Motor Operated (M-360)		X
*MO-3-1501-38A,B	Globe Valve, Motor Operated (M-360)		X
*MO-3-1501-20A,B	Gate Valve, Motor Operated (M-360)		X
*MO-3-1501-13A,B	Gate Valve, Motor Operated (M-360)		X
*MO-3-1501-28A,B	Gate Valve, Motor Operated (M-360)		X
*MO-3-205-2-4	Gate Valve, Motor Operated (M-357)		X
*MO-3-1301-1	Gate Valve, Motor Operated (M-359)		X
*MO-3-1301-2	Gate Valve, Motor Operated (M-359)		X
*MO-3-1301-3	Gate Valve, Motor Operated (M-359)		X
*MO-3-1301-4	Gate Valve, Motor Operated (M-359)	X	
*MO-3-1402-3A,B	Gate Valve, Motor Operated (M-358)		X
*MO-3-1402-25A,B	Gate Valve, Motor Operated (M-358)		X

SYSTEM: Containment Isolation

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location	
Plant Identification Number	Generic Name (**)	Inside Primary Contain-ment	Outside Primary Contain-ment
*MO-3-1402-4A,B	Globe Valve, Motor Operated (M-358)		X
*MO-3-2301-36	Gate Valve, Motor Operated (M-374)		X
*MO-3-2301-9	Gate Valve, Motor Operated (M-374)	X	
*MO-3-2301-5	Gate Valve, Motor Operated (M-374)		X
AO-3-2001-105	Gate Valve, Air Operated (Solenoid)		X
AO-3-2001-106	Gate Valve, Air Operated (Solenoid)		X
AO-3-2001-5	Gate Valve, Air Operated (Solenoid)		X
AO-3-2001-6	Gate Valve, Air Operated (Solenoid)		X
POS-3-2001-105	Gate Valve, Air Operated (Position Switch)		X
POS-3-2001-106	Gate Valve, Air Operated (Position Switch)		X
POS-3-2001-5	Gate Valve, Air Operated (Position Switch)		X
POS-3-2001-6	Gate Valve, Air Operated (Position Switch)		X
MO-3-3702	Gate Valve, Motor Operated		X
MO-3-3703	Gate Valve, Motor Operated		X
MO-3-3706	Gate Valve, Motor Operated	X	
*AO-3-1601-60	Butterfly Valve, Air Operated (M-356)		X

Rev 2  
April 18, 1980  
Page 4

SYSTEM: Containment Isolation

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location	
Plant Identification Number	Generic Name (**)	Inside Primary Containment	Outside Primary Containment
*AO-3-1601-61	Gate Valve, Air Operated (M-356)		X
*AO-3-1601-20A,B	Butterfly Valve, Air Operated (M-356)		X
*AO-3-1601-23	Butterfly Valve, Air Operated (M-356)		X
*AO-3-1601-24	Butterfly Valve, Air Operated (M-356)		X
*MO-3-1601-57	Globe Valve, Motor Operated (M-356)		X
*AO-3-1601-62	Globe Valve, Air Operated (M-356)		X
*AO-3-1601-21	Butterfly Valve, Air Operated (M-356)		X
*AO-3-1601-59	Butterfly Valve, Air Operated (M-356)		X
*AO-3-1601-58	Butterfly Valve, Air Operated (M-356)		X
*AO-3-1601-56	Butterfly Valve, Air Operated (M-356)		X
*MO-3-1601-57	Globe Valve, Motor Operated (M-356)		X
*AO-3-1601-22	Butterfly Valve, Air Operated (M-356)		X
*AO-3-1601-63	Butterfly Valve, Air Operated (M-356)		X
*AO-3-1601-55	Butterfly Valve, Air Operated (M-356)		X
AO-3-4720	Air Operated Valve (Solenoid)		X

---

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM

---

Plant Identification Number	Generic Name (**)	Location	
		Inside Primary Contain- ment	Outside Primary Contain- ment
AO-3-4721	Air Operated Valve (Solenoid)		X
AO-3-4722	Air Operated Valve (Solenoid)		X
POS-3-4720	Air Operated Valve (Position Switch)		X
POS-3-4721	Air Operated Valve (Position Switch)		X
POS-3-4722	Air Operated Valve (Position Switch)		X

\* These components are listed here for information only. Their qualification evaluation is covered with their respective systems.

\*\* Shows P&ID Number of respective system

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Control Rod Drive Hydraulic

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location
Plant Identification Number	Generic Name	Inside Primary Contain-ment      Outside Primary Contain-ment
*SO-3-305-117	Scram Solenoid Valve	X
*SO-3-305-118	Scram Solenoid Valve	X
SO-3-0302-20A,B	Scram Solenoid Valve	X
SO-3-0302-19A,B	Scram Solenoid Valve	X
LS-3-0302-82A,B,C,D	Level Switch	X
POS-3-302-21A,B	Air Operated Valve (Position Switch)	X
POS-3-302-22	Air Operated Valve (Position Switch)	X
*SO-3-305-120	Solenoid Valve	X
*SO-3-305-121	Solenoid Valve	X
*SO-3-305-122	Solenoid Valve	X
*SO-3-305-123	Solenoid Valve	X

\*Typical of 177 Valves

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Reactor (Nuclear Boiler) Recirculation

Plant Identification Number	Generic Name	Location	
		Inside Primary Containment	Outside Primary Containment
LITS-3-263-73A,B	Level Indicating Transmitter Switch		X
PS-3-263-111A,B,C,D	Pressure Switch		X
PT-3-647A,B	Pressure Transmitter		X
LT-3-646-A,B	Level Transmitter		X
PT-3-662	Pressure Transmitter		X
PS-3-263-51A,B	Pressure Switch		X
PS-3-263-52A,B	Pressure Switch		X
PS-3-263-53A,B,C,D	Pressure Switch		X
PS-3-263-55A,B,C,D	Pressure Switch		X
LT-3-263-61	Level Transmitter		X
MO-3-205-204	Gate Valve, Motor Operated		X
POS-3-220-51	Globe Valve, Air Operated (Position Switch)	X	
AO-3-220-51	Globe Valve, Air Operated (Solenoid)	X	
POS-3-220-52	Globe Valve, Air Operated (Position Switch)	X	
AO-3-220-52	Globe Valve, Air Operated (Solenoid)	X	

SYSTEM: Reactor (Nuclear Boiler) Recirculation

Rev 2  
April 18, 1980  
Page 2

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM			
Plant Identification Number	Generic Name	Location	
		Inside Primary Contain- ment	Outside Primary Contain- ment
LITS-3-263-59A,B	Level Indicator Transmitter Switch		X
LIS-3-263-57A,B	Level Indicator Switch		X
LIS-3-263-72A,B,C,D	Level Indicator Switch		X
LIS-3-263-58A,B	Level Indicator Switch		X
POS-3-220-44	Globe Valve, Air Operated (Position Switch)	X	
AO-3-220-44	Globe Valve, Air Operated (Solenoid)	X	
POS-3-220-45	Globe Valve, Air Operated (Position Switch)		X
AO-3-220-45	Globe Valve, Air Operated (Solenoid)		X
DPIS-3-261-35A,B,C,D E,F,G,H	Differential Pressure Indicating Switch		X
DPIS-3-261-34A,B,C,D	Differential Pressure Indicating Switch		X
MO-3-202-4A,B	Gate Valve, Motor Operated	X	
MO-3-202-5A,B	Gate Valve, Motor Operated	X	
MO-3-202-6A,B	Gate Valve, Motor Operated	X	
MO-3-202-7A,B	Gate Valve, Motor Operated	X	
MO-3-202-9A,B	Gate Valve, Motor Operated	X	

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Process Radiation Monitoring

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>
<u>Plant Identification Number</u>	<u>Generic Name</u>	
RE-3-1735A,B	Rx Building Ventilation Exhaust Radiation Element	X
RE-3-1734A,B,C,D	Main Steam Line Radiation Element	X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Reactor Building Ventilation

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>	
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Contain-ment</u>	<u>Outside Primary Contain-ment</u>
AO-3-5742A,B	Butterfly Valve, Air Operated (Solenoid)		X
AO-3-5741A,B	Butterfly Valve, Air Operated (Solenoid)		X

Facility: Dresden  
Unit: 2/3  
Docket: 50-237/50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Control Room, Office, and Drywell Air Conditioning

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Containment</u> <u>Outside Primary Containment</u>
2/3-5772-100	Isolation Damper and Solenoid Valves	X
2/3-5772-99	Damper	X
2/3-5772-101	Isolation Damper	X
2/3-5731	Supply Air Fan	X
2/3-9472-024	Damper	X
2/3-9472-023	Damper	X
2/3-5772-62	Damper	X
2/3-5728	Return Air Fan	X
2/3-	Diesel Generator Room Fan	X
2/3-2A,B	Control Room Air Conditioning Compressors	X
SE-2/3-8941-013	Smoke Detector	X
SO-2/3-9441-003	Solenoid Valve	X
SO-2/3-9441-004	Solenoid Valve	X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Standby Alternating Current Power

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location	
Plant Identification Number	Generic Name	Inside Primary Containment	Outside Primary Containment
D/G 3-5209	Standby Diesel Generator		X
D/G-2/3-5209	Standby Diesel Generator		X
SWGR 33-1	4.16 kV Switchgear		X
SWGR 34-1	4.16 kV Switchgear		X
SWGR 38	480 V Switchgear		X
SWGR 39	480 V Switchgear		X
MCC 38-1	480 V Rx Building MCC		X
MCC 38-2	480 V Turbine Building MCC		X
MCC 38-3	480 V Turbine Building MCC		X
MCC 38-7	480 V Rx Building MCC		X
MCC 39-1	480 V Rx Building MCC		X
MCC 39-2	480 V Turbine Building MCC		X
MCC 39-3	480 V Rx Building MCC		X
MCC 39-4	480 V Rx Building MCC		X
MCC 39-7	480 V Rx Building MCC		X
RPS Bus 1	120 V ac Reactor Protection System Bus 1		X
RPS Bus 2	120 V ac Reactor Protection System Bus 2		X

SYSTEM: Standby Alternating Current Power

Rev 2  
April 18, 1980  
Page 2

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM			
Plant Identification Number	Generic Name	Location	
		Inside Primary Containment	Outside Primary Containment
Essential Service Bus	120/240 V ac Essential Service Bus		X
Instrument Bus	120/240 V ac Instrument Bus		X
Essential Bus MMG Set	120/240 V ac Essentail Bus Supply MMG Set		X
2223-41	D/G 2/3 Excitation Cabinet		X
None	D/G 3 Excitation Cabinet		X
None	D/G 2/3-3 Engine Control Panel		X
None	D/G 2/3-3 Speed Sensing Panel at Engine		X
None	D/G 3 Relay and Meter Panel		X
2223-33	D/G 2/3 Relay and Meter Panel		X
None	4 kV Nonsegregated Bus		X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Standby Direct Current Power

<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>	
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Contain-ment</u>	<u>Outside Primary Contain-ment</u>
250 V Batt Chgr 3	250 V Battery Charger		X
250 V Batt Chgr 2/3	250 V Batter Charger		X
MCC 3 (Turbine Building)	250 V dc Turbine Building MCC		X
MCC 3 (Rx Building Bus 3A & 3B	250 V dc Reactor Building MCC		X
250 V Battery	250 V dc Battery		X
125 V Batt Chgr 3	125 V Battery Charger		X
125 V Batt Chgr 3A	125 V Battery Charger		X
125 V Battery	125 V dc Battery		X
125 V DCDP Main Bus 3	125 V dc Turbine Building Distribution Panel (Main Bus)		X
125 V DCDP Res Bus 3	125 V dc Turbine Building Distribution Panel (Reserve Bus)		X
48/24 Batt 3A & 3B	48/24 V Battery		X
24V Batt Chgr 3A & 3B (+)	24 V Battery Charger		X
24 V Batt Chgr 3A & 3B (-)	24 V Battery Charger		X
48/24 DCDB 3A & 3B	48/24 V dc Distribution Panel		X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: Isolation Condenser

SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM		Location
Plant Identification Number	Generic Name	Inside Primary Contain-ment      Outside Primary Contain-ment
POS-3-1301-17	Globe Valve, Air Operated (Position Switch)	X
AO-3-1301-17	Globe Valve, Air Operated (Solenoid)	X
POS-3-1301-20	Globe Valve, Air Operated (Position Switch)	X
AO-3-1301-20	Globe Valve, Air Operated (Solenoid)	X
MO-3-1301-3	Gate Valve, Motor Operated (dc)	X
DPIS-3-1349-A,B	Differential Pressure Indication Switch	X
MO-3-1301-4	Gate Valve, Motor Operated	X
MO-3-1301-1	Gate Valve, Motor Operated	X
MO-3-1301-2	Gate Valve, Motor Operated (dc)	X
DPIS-3-1350A,B	Differential Pressure Indication Switch	X
TE-3-1346A,B,C,D	Temperature Elements	X

Facility: Dresden  
Unit: 3  
Docket: 50-249

Rev 2  
April 18, 1980

MASTER LIST

CLASS 1E ELECTRICAL EQUIPMENT  
REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: General Use Electrical Equipment


<u>SPECIFIC COMPONENTS ASSOCIATED WITH ABOVE SYSTEM</u>		<u>Location</u>	
<u>Plant Identification Number</u>	<u>Generic Name</u>	<u>Inside Primary Contain- ment</u>	<u>Outside Primary Contain- ment</u>
Cable	5 kV Power		X
Cable	600 V Power and Control	X	X
Cable	Instruments	X	X
Cable	Thermocouples	X	X
Electrical Penetration	High-Voltage Power	X	X
Electrical Penetration	Low-Voltage Power & Control	X	X
Electrical Penetration	Instruments	X	X
Electrical Penetration	Thermocouples	X	X

## APPENDIX C


### LIST OF FIGURES AND TABLES


#### DRESDEN UNIT 3 KEY PLAN IDENTIFYING HARSH ENVIRONMENTAL AREAS AND TABULATION OF SERVICE CONDITIONS


- Figure C.1 Plan view general arrangement drawing identifying harsh environmental areas for Dresden Unit 3 el 476'-6"
- Figure C.2 Plan view general arrangement drawing identifying harsh environmental areas for Dresden Unit 3 el 517'-6"
- Figure C.3 Plan view general arrangement drawing identifying harsh environmental areas for Dresden Unit 3 el 545'-6"
- Figure C.4 Plan view general arrangement drawing identifying harsh environmental areas for Dresden Unit 3 el 570'-0"
- Figure C.5 Plan view general arrangement drawing identifying harsh environmental areas for Dresden Unit 3 el 589'-0" and 613'-0"
- Figure C.6 FSAR Figure 5.2.11 providing the drywell pressure response following the postulated LOCA
- Figure C.7 FSAR Figure 5.2.12 providing drywell temperature response following the postulated LOCA
- Table C-1 Maximum environmental conditions inside drywell for the postulated LOCA/HELB
- Table C-2 Maximum environmental conditions outside drywell following the postulated HELB accidents discussed in Section 4.1 of this report
- Table C-3 Post-LOCA maximum radiation doses for areas outside the drywell for 1 day, 30 days, and 1-year exposure. Where times other than 1 day, 30 days, and 1 year apply calculated values for the appropriate time are utilized.



THIS FIGURE REPRODUCED FROM S&L  
DRAWING M-5 FIGURE C.1 EL 476'6"








## LEGEND

**LEGEND**

||||| RADIATION, PRESSURE  
HUMIDITY & TEMPERATURE

[REDACTED] RADIATION ONLY






Figure 5.2.11 Pressure Response to Loss-of-Coolant Accident

FIGURE C.7




Figure 5.2.12 Temperature Response to Loss-of-Coolant Accident

TABLE C-1

MAXIMUM ENVIRONMENTAL CONDITIONS INSIDE THE DRYWELL  
FOLLOWING THE POSTULATED LOCA/HELB

<u>Temperature</u>	<u>Pressure</u>	<u>Relative Humidity</u>	<u>Containment Spray</u>	<u>Gamma Radiation</u>	<u>Subemergency Elevation</u>
281F	63 psia	100%	Demineralized Water	1 hour- $2.0 \times 10^7$ rads 1 day- $4.3 \times 10^7$ rads 30 day- $1.0 \times 10^8$ rads 1 year- $1.1 \times 10^8$ rads	505'-6"

TABLE C-2  
 HELB ENVIRONMENTAL CONDITIONS  
 OUTSIDE THE DRYWELL

<u>Area</u>	<u>Pipe Break</u>	<u>Maximum Pressure (psia)</u>	<u>Maximum Temperature (°F)</u>	<u>Relative Humidity (%)</u>
Torus Compartment	High-pressure coolant injection Steam	27.0	242	100
Reactor Building Pipe Chase, el 589'-0", 570'-0", and 545'-6" South of Drywell Between Columns L and M near Column 41.	Isolation condenser	27.0	242	100
Steam Tunnel	Main steam Feedwater	27.0	242	100
Reactor Water Cleanup Heat Exchanger and Holding Pump Room	Reactor water cleanup	Not evaluated - Only containment isolation valve(s) required to function. Its qualification will meet conservatively assumed inside drywell conditions.		
High-Pressure Heater Bay	Main steam Feedwater	27.0	242	100
Turbine Building el 538'-0" North of Column G Between Column 40 and 42 and 46 and 48	Main steam	21.9	230	100

TABLE C-2 (Continued)

<u>Area</u>	<u>Pipe Break</u>	<u>Maximum Pressure (psia)</u>	<u>Maximum Temperature (°F)</u>	<u>Relative Humidity (%)</u>
Reactor Feed Pump Room	Feedwater		Not evaluated - No equipment required to function located in this room	
Diesel Generator Room	Feedwater	14.9	213	100
Electrical Equipment Room (This room is located in Unit 2, but is included because some Unit 3 equipment is located in this room).	Feedwater	14.9	213	100

TABLE C-3

RADIATION ENVIRONMENTAL CONDITIONS OUTSIDE DRYWELL  
FOLLOWING THE POSTULATED LOCA  
MAXIMUM RADIATION SOURCES

<u>Area</u>	<u>Source*</u>	Integrated Dose Levels (rads)		
		<u>1 Day</u>	<u>30 Days</u>	<u>1 Year</u>
Torus	SP	$1.5 \times 10^7$	$3.2 \times 10^7$	$3.9 \times 10^7$
Low-Pressure Coolant Injection Corner Rooms	SP	$2.4 \times 10^5$	$9.4 \times 10^5$	$1.7 \times 10^6$
High-Pressure Coolant Injection Room	MS	$6.6 \times 10^6$	$1.6 \times 10^7$	$1.7 \times 10^7$
Steam Tunnel	SP	$1.9 \times 10^5$	$7.0 \times 10^5$	$1.3 \times 10^6$
Reactor Building El 517'-6"	RW	$2.5 \times 10^6$	$7.8 \times 10^6$	$1.4 \times 10^7$
Reactor Building El 545'-6"	CA/SP	$2.2 \times 10^5$	$6.2 \times 10^5$	$1.1 \times 10^6$
Reactor Building El 570'-0"	CA	$2.2 \times 10^5$	$5.4 \times 10^5$	$6.1 \times 10^5$
Reactor Building El 589'-0"	RW	$3.2 \times 10^6$	$1.1 \times 10^7$	$1.8 \times 10^7$

\* SP = Suppression Pool Liquid  
RW = Reactor Water  
MS = Reactor Steam  
CA = Containment Airborne



**Bechtel Power Corporation**  
**April 1980**

**— NOTICE —**

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

Docket # 50-249  
Control # 8005300089  
Deadline Return Date 4/29/81 of Document  
REGULATORY DOCKET FILE


**REGULATORY DOCKET FILE COPY**

RECORDS FACILITY BRANCH

**RESPONSE TO IE BULLETIN 79-01B**  
**DRESDEN**  
**NUCLEAR POWER STATION**  
**UNIT 3**

**Volume 2**

**Commonwealth Edison**



RESPONSE TO IE BULLETIN 79-01B  
DRESDEN NUCLEAR POWER STATION  
UNIT 3 AND COMMON

VOLUME 2

This volume contains equipment data sheets for the following Unit 3 and common systems:

1. Reactor protection
2. Core spray
3. High-pressure coolant injection
4. Auto depressurization/main steam
5. Low-pressure coolant injection
6. Pressure suppression

Notes:

NA is used for not applicable

EO# is used for 10 to the power number (e.g., E06 =  $10^6$ )

This volume contains sheets 1 through 252

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 1  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR PROTECTION</b>  Plant I.D. Number: PS-3-503A,B,C,D Component: <b>PRESSURE SWITCH (LOW)</b>  Manufacturer: BARKSDALE  Model Number: DIT H18SS  Purchase Order Number: GE HO847 SPEC 21A1153 Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 2  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: PS-3-503A	Temperature (°F)	120
Component: <b>PRESSURE SWITCH (LOW)</b>	Pressure (PSIA)	14.7
Manufacturer: BARKSDALE	Relative Humidity (%)	100
Model Number: DIT H18SS	Chemical Spray	NA
Purchase Order Number: GE HO847 SPEC 21A1153	Radiation (Rad)	<1.0 E04
Function/Service: <b>CONDENSER LOW VACUUM SIGNAL TO SCRAM VALVE SOLENOID</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2253-20 COLUMNS 49& G Elevation 569'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: PS-3-503B	Temperature (°F)	120
Component: <b>PRESSURE SWITCH (LOW)</b>	Pressure (PSIA)	14.7
Manufacturer: BARKSDALE	Relative Humidity (%)	100
Model Number: DIT H18SS	Chemical Spray	NA
Purchase Order Number: GE HO847 SPEC 21A1153	Radiation (Rad)	<1.0 E04
Function/Service: <b>CONDENSER LOW VACUUM SIGNAL TO SCRAM VALVE SOLENOID</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2253-20 COLUMNS 49 & G Elevation 569'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 3  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS	
Plant I.D. Number: PS-3-503C	Temperature (°F)	120	
Component: <b>PRESSURE SWITCH (LOW)</b>	Pressure (PSIA)	14.7	
Manufacturer: BARKSDALE	Relative Humidity (%)	100	
Model Number: DIT H18SS	Chemical Spray	NA	
Purchase Order Number: GE HO847 SPEC 21A 1153	Radiation (Rad)	<1.0 E04	
Function/Service: CONDENSER LOW VACUUM SIGNAL TO SCRAM VALVE SOLENOID	Aging	NOT REQD.	
Accuracy: Spec: Demo:	Submergence	NA	
Location RACK 2253-20 COLUMNS 49 & G Elevation 569'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS	
Plant I.D. Number: PS-3-503D	Temperature (°F)	120	
Component: <b>PRESSURE SWITCH (LOW)</b>	Pressure (PSIA)	14.7	
Manufacturer: BARKSDALE	Relative Humidity (%)	100	
Model Number: DIT H18SS	Chemical Spray	NA	
Purchase Order Number: GE HO847 SPEC 21A1153	Radiation (Rad)	<1.0 E04	
Function/Service: CONDENSER LOW VACUUM SIGNAL TO SCRAM VALVE SOLENOID	Aging	NOT REQD.	
Accuracy: Spec: Demo:	Submergence	NA	
Location RACK 2253-20 COLUMNS 49& G Elevation 569'6"	Flood Level Elevation: Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 4  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR PROTECTION</b>  Plant I.D. Number: <b>SEE ATTACHED SHEETS</b> Component: <b>NEUTRON MONITOR PREAMPLIFIER</b> Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: <b>112C221 8G1</b> Purchase Order Number: <b>120-1916A MANUAL GEK-858A</b> Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b> Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	4.3 E05		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 5  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: RAM-3-762A	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: 112C221 8G1	Chemical Spray	NA
Purchase Order Number: 120-1916A MANUAL GEK-858 A	Radiation (Rad)	4.3 E05
Function/Service: <b>INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-15 COLUMNS 47 & M Elevation 530'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: RAM-3-762B	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: 112C221 8G1	Chemical Spray	NA
Purchase Order Number: 120-1916A MANUAL GEK-858 A	Radiation (Rad)	4.3 E05
Function/Service: <b>INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-15 COLUMNS 47 & M Elevation 530'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 6  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: RAM-3-762C	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: 112C221 8G1	Chemical Spray	NA
Purchase Order Number: 120-1916A <b>MANUAL GEK-858A</b>	Radiation (Rad)	4.3 E05
Function/Service: <b>INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-15 COLUMNS 47 & M Elevation 530' 6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: RAM-3-762D	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: 112C221 8G1	Chemical Spray	NA
Purchase Order Number: 120-1916A <b>MANUAL GEK-858A</b>	Radiation (Rad)	4.3 E05
Function/Service: <b>INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-15 COLUMNS 47&M Elevation 530' 6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 7  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT		EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR		Parameter	FSAR
System: <b>REACTOR PROTECTION</b>  Plant I.D. Number: RAM-3-762E Component: NEUTRON MONITOR PREAMPLIFIER Manufacturer: GENERAL ELECTRIC  Model Number: 112C221 8G1 Purchase Order Number: 120-1916A MANUAL GEK-858A Function/Service: INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION  Accuracy: Spec: Demo: Location RACK 2203-15 COLUMNS 47&M Elevation 530'6"	Operating Time	CONTINUOUS	System: <b>REACTOR PROTECTION</b>  Plant I.D. Number: RAM-3-762F Component: NEUTRON MONITOR PREAMPLIFIER Manufacturer: GENERAL ELECTRIC  Model Number: 112C221 8G1 Purchase Order Number: 120-1916A MANUAL GEK-858A Function/Service: INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION  Accuracy: Spec: Demo: Location RACK 2203-15 COLUMNS 47&M Elevation 530'6"	Operating Time	CONTINUOUS
	Temperature (°F)	103		Temperature (°F)	103
	Pressure (PSIA)	14.7		Pressure (PSIA)	14.7
	Relative Humidity (%)	100		Relative Humidity (%)	100
	Chemical Spray	NA		Chemical Spray	NA
	Radiation (Rad)	4.3 E05		Radiation (Rad)	4.3 E05
	Aging	NOT REQD.		Aging	NOT REQD.
	Submergence	NA		Submergence	NA
	Flood Level Elevation: NA Above Flood Level: Yes: No:			Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 8  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>RAM-3-762G</b>	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>112C221 8G1</b>	Chemical Spray	NA
Purchase Order Number: <b>120-1916A MANUAL GEK-858A</b>	Radiation (Rad)	4.3 E05
Function/Service: <b>INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location <b>RACK 2203-15 COLUMNS 47&amp;M Elevation 530'6"</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>RAM-3-762H</b>	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>112C221 8G1</b>	Chemical Spray	NA
Purchase Order Number: <b>120-1916A MANUAL GEK-858A</b>	Radiation (Rad)	4.3 E05
Function/Service: <b>INTERMEDIATE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	
Location <b>RACK 2203-15 COLUMNS 47&amp;M Elevation 530'6"</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03

Component Sheet No: 9  
 Revision O  
 Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 120-1916A MANUAL GEK-987C	Radiation (Rad)	4.3 E05		REF. (B)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD	NOT REQD.	REF. (C)			
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 10  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>RAM-3-752A</b>	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>120-1916A</b> <b>MANUAL GEK 987C</b>	Radiation (Rad)	4.3 E05
Function/Service: <b>SOURCE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location <b>RACK 2203-15</b> <b>COLUMNS 47&amp;M</b> Elevation <b>530'6"</b>	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>RAM-3-752B</b>	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>120-1916A</b> <b>MANUAL GEK-987C</b>	Radiation (Rad)	4.3 E05
Function/Service: <b>SOURCE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location <b>RACK 2203-15</b> <b>COLUMNS 47&amp;M</b> Elevation <b>530'6"</b>	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 11  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: RAM-3-752C	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: 120-1916A MANUAL GEK-987C	Radiation (Rad)	4.3 E05
Function/Service: <b>SOURCE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-15 COLMUNS 47&M Elevation 530'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR PROTECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: RAM-3-752D	Temperature (°F)	103
Component: <b>NEUTRON MONITOR PREAMPLIFIER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: 120-1916A MANUAL GEK-987C	Radiation (Rad)	4.3 E05
Function/Service: <b>SOURCE RANGE NEUTRON LEVEL DETECTION SIGNAL AMPLIFICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-15 COLMUNS 47 & M Elevation 530'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Component Sheet No: 12  
 Revision  
 Date

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR PROTECTION</b>  Plant I.D. Number: TE-3-1290A-H Component: <b>TEMPERATURE ELEMENT</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	130	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA					
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA					

DOCUMENTATION REFERENCES	NOTES
A. THESE TEMPERATURE SWITCHES ARE USED FOR LEAK DETECTION IN THE RWCU ROOM CONDITIONS ARE NON-HARSH. IMMEDIATELY FOLLOWING A LEAK THE TEMPERATURE WILL INCREASE AS SOON AS THE LEAK OCCURS THE SWITCHES WILL FUNCTION, INITIATING SYSTEM ISOLATION. THIS WILL OCCUR WITHIN ONE MINUTE.	

Component Sheet No. 13

Revision:

Date:

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY BECHTEL RADIATION STUDY. D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 14  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:		Operating Time	1 MINUTE
Plant I.D. Number:	TE-3-1290A	Temperature (°F)	103
Component:	TEMPERATURE ELEMENT	Pressure (PSIA)	14.7
Manufacturer:		Relative Humidity (%)	100
Model Number:		Chemical Spray	NA
Purchase Order Number:		Radiation (Rad)	<1.0 E04
Function/Service:	LEAK DETECTION FOR RWCU ROOM	Aging	NOT REQD.
Accuracy: Spec:		Submergence	NA
Location:	RWCU ROOM	Flood Level	
Elevation	545' 6"	Elevation:	NA
Above Flood Level:		Above Flood Level:	
Yes:	No:	Yes:	No:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:		Operating Time	1 MINUTE
Plant I.D. Number:	TE-3-1290B	Temperature (°F)	103
Component:	TEMPERATURE ELEMENT	Pressure (PSIA)	14.7
Manufacturer:		Relative Humidity (%)	100
Model Number:		Chemical Spray	NA
Purchase Order Number:		Radiation (Rad)	<1.0 E04
Function/Service:	LEAK DETECTION FOR RWCU ROOM	Aging	NOT REQD.
Accuracy: Spec:		Submergence	NA
Location:	RWCU ROOM	Flood Level	
Elevation	545' 6"	Elevation:	NA
Above Flood Level:		Above Flood Level:	
Yes:	No:	Yes:	No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 15  
 Revision  
 Date:

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	1 MINUTE
Plant I.D. Number: TE-3-1290C	Temperature (°F)	103
Component: TEMPERATURE ELEMENT	Pressure (PSIA)	14.7
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	
Function/Service: LEAK DETECTION FOR RWCU ROOM	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RWCU ROOM	Submergence	NA
Elevation 545' 6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	1 MINUTE
Plant I.D. Number: TE-3-1290D	Temperature (°F)	103
Component: TEMPERATURE ELEMENT	Pressure (PSIA)	14.7
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: LEAK DETECTION FOR RWCU ROOM	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RWCU ROOM	Submergence	NA
Elevation 545' 6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 16  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System:	Operating Time		1 MINUTE
Plant I.D. Number: TE-3-1290E	Temperature (°F)		103
Component: TEMPERATURE ELEMENT	Pressure (PSIA)		14.7
Manufacturer:	Relative Humidity (%)		100
Model Number:	Chemical Spray		NA
Purchase Order Number:	Radiation (Rad)		<1.0 E04
Function/Service: LEAK DETECTION FOR RWCU ROOM	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location RWCU ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System:	Operating Time		1 MINUTE
Plant I.D. Number: TE-3-1290F	Temperature (°F)		103
Component: TEMPERATURE ELEMENT	Pressure (PSIA)		14.7
Manufacturer:	Relative Humidity (%)		100
Model Number:	Chemical Spray		NA
Purchase Order Number:	Radiation (Rad)		<1.0 E04
Function/Service: LEAK DETECTION FOR RWCU ROOM	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location RWCU ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 17  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System:	Operating Time		1 MINUTE
Plant I.D. Number: TE-3-1290G	Temperature (°F)		103
Component: TEMPERATURE ELEMENT	Pressure (PSIA)		14.7
Manufacturer:	Relative Humidity (%)		100
Model Number:	Chemical Spray		NA
Purchase Order Number:	Radiation (Rad)		<1.0 E04
Function/Service: LEAK DETECTION FOR RWCU ROOM	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location RWCU ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System:	Operating Time		1 MINUTE
Plant I.D. Number: TE-3-1290H	Temperature (°F)		103
Component: TEMPERATURE ELEMENT	Pressure (PSIA)		14.7
Manufacturer:	Relative Humidity (%)		100
Model Number:	Chemical Spray		NA
Purchase Order Number:	Radiation (Rad)		<1.0 E04
Function/Service: LEAK DETECTION FOR RWCU ROOM	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location RWCU ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Component Sheet No: 18  
 Revision O  
 Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>  Plant I.D. Number: 3-1401A&B Component: <b>PUMP-MOTOR DRIVEN</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: 5106338XC23A 5K6637XC71A Purchase Order Number: GE-92081 SPEC 21A5580 Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	14.7		REF. (B)			
	Relative Humidity (%)	100		REF. (B)			
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.0 E06		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. GE TEST REPORT 22A4722 IS AVAILABLE BECHTEL TO VERIFY DATA

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 19  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	CORE SPRAY		Operating Time	12 DAYS
Plant I.D. Number:	3-1401A		Temperature (°F)	150
Component:	PUMP-MOTOR DRIVEN		Pressure (PSIA)	14.7
Manufacturer:	GENERAL ELECTRIC		Relative Humidity (%)	100
Model Number:	5106338XC23A 5K6637XC71A		Chemical Spray	NA
Purchase Order Number:	GE-92081 SPEC 21A5580		Radiation (Rad)	2.5 E06
Function/Service:	CORE SPRAY INJECTION TO REACTOR-A LOOP		Aging	NOT REQD.
Accuracy:	Spec: NA	Demo: NA	Submergence	NA
Location	SE CORNER ROOM		Flood Level	
Elevation	476'6"		Elevation:	NA
Above Flood Level:	Yes: No:		Above Flood Level:	

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	CORE SPRAY		Operating Time	12 DAYS
Plant I.D. Number:	3-1401B		Temperature (°F)	150
Component:	PUMP-MOTOR DRIVEN		Pressure (PSIA)	14.7
Manufacturer:	GENERAL ELECTRIC		Relative Humidity (%)	100
Model Number:	5106338XC23A 5K6637XC71A		Chemical Spray	NA
Purchase Order Number:	SPEC 21A5580		Radiation (Rad)	3.0 E06
Function/Service:	CORE SPRAY INJECTION TO REACTOR-B LOOP		Aging	NOT REQD.
Accuracy:	Spec: NA	Demo: NA	Submergence	NA
Location	SW CORNER ROOM		Flood Level	
Elevation	476'6"		Elevation:	NA
Above Flood Level:	Yes: No:		Above Flood Level:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 20  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>  Plant I.D. Number: MO-3-1402-3A&B Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> AC MOTOR Model Number: SMB-0-15  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	12 DAYS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	307	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	27.0	74.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.2 E07		REF. (D)			SEE NOTE (3)
	Aging						SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. 338164-FC2485-01 TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR-BRAKE ASSEMBLY BOTH WITH CLASS B INSULATION UNDER SIMULATED REACTOR CONTAINMENT POST ACCIDENT STEAM AND CHEMICAL ENVIRONMENT. C. SPECIAL REPORT NO. 37, REV 1, FEB 1975	1. TEST CALLED OUT SATURATED ATMOSPHERE BUT HUMIDITY WAS NOT MEASURED DURING TEST. 2. UNIT OPERATED FIRST DAY, AFTER 6 DAYS IN STEAM ENVIRONMENT MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS AT 228 DEGREES F AT 5 PSIG. INVESTIGATE EXISTENCE OF MORE DATA. 3. INVESTIGATE EXISTENCE OF QUALIFICATION DATA

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 21  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
D. BECHTEL RADIATION STUDY	WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 22  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT		EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR		Parameter	FSAR
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS	System: <b>CORE SPRAY</b>	Operating Time	12 DAYS
Plant I.D. Number: MO-3-1402-3A	Temperature (°F)	242	Plant I.D. Number: MO-3-1402-3B	Temperature (°F)	242
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	27.0	Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>LIMITORQUE (PEERLESS) AC MOTOR</b>	Relative Humidity (%)	100	Manufacturer: <b>LIMITORQUE (PEERLESS) AC MOTOR</b>	Relative Humidity (%)	100
Model Number: SMB-O-15	Chemical Spray	NA	Model Number: SMB-O-15	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.2 EO7	Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.2 EO7
Function/Service: <b>PUMP 3-1401-ASUCTION VALVE</b>	Aging	NOT REQD.	Function/Service: <b>PUMP 3-1401-B SUCTION VALVE</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA	Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>TOP OF TORUS</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:		Elevation 491'5"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 23  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>  Plant I.D. Number: MO-3-1402-4A&B Component: <b>MOTOR OPERATED GLOBE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number:  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	340	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	27.0	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.2 E07		REF. (D)		INDIVIDUAL TEST	SEE NOTE (3)
	Aging					INDIVIDUAL TEST	SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 5.2.11 & 5.2.12 B. REPORT NO 338164-FC2485-01 TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR-BRAKE ASSEMBLY, BOTH WITH CLASS B INSULATION UNDER SIMULATED REACTOR CONTAINMENT POST-ACCIDENT STEAM AND CHEMICAL ENVIRONMENT C. SPECIAL REPORT NO 37, REV 1, FEB 1975	1. UNIT OPERATED FIRST DAY AFTER 6 MORE DAYS IN STEAM ENVIRONMENT MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS 228F AT 5 PSIG 2. TEST CALLED OUT SATURATED ATMOSPHERE BUT HUMIDITY WAS NOT MEASURED DURING TESTS

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 24  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
D. BECHTEL RADIATION STUDY	3. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 25  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	12 DAYS	
Temperature (°F)	242	
Pressure (PSIA)	27.0	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	3.2 E07	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	12 DAYS	
Temperature (°F)	242	
Pressure (PSIA)	27.0	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	3.2 E07	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 26  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: MO-3-1402-24A&B	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>LIMITORQUE (RELIANCE)</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
AC MOTOR	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>LIMITORQUE</b>	Chemical Spray	NA	NA	NA	NA	NA	
Model Number:	Radiation (Rad)	6.3 E05		REF. (C)			SEE NOTE (1)
Purchase Order Number: 3447-141 SPEC K-2205	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Function/Service: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTANCE OF RADIATION QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 27  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS
Plant I.D. Number: MO-3-1402-24A	Temperature (°F)	103
Component: <b>LIMITORQUE (RELIANCE)</b>	Pressure (PSIA)	14.7
AC MOTOR	Relative Humidity (%)	100
Manufacturer: <b>LIMITORQUE</b>	Chemical Spray	NA
Model Number:	Radiation (Rad)	6.1 EO5
Purchase Order Number: 3447-141	Aging	NOT REQD.
SPEC K-2205	Submergence	NA
Function/Service: PUMP 3-1401-A		
Accuracy: Spec: NA		
Location BETWEEN COL. 47&48		
6'-0" S OF COL. H		
Elevation 554'6"		
Flood Level Elevation: NA		
Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS
Plant I.D. Number: MO-3-1402-24B	Temperature (°F)	103
Component: <b>LIMITORQUE (RELIANCE)</b>	Pressure (PSIA)	14.7
AC MOTOR	Relative Humidity (%)	100
Manufacturer: <b>LIMITORQUE</b>	Chemical Spray	NA
Model Number:	Radiation (Rad)	6.3 EO5
Purchase Order Number: 3447-141	Aging	NOT REQD.
SPEC K-2205	Submergence	NA
Function/Service: PUMP 3-1401-B		
Accuracy: Spec: NA		
Location BETWEEN COL. 47&48		
ALONG COL. M		
Elevation 554'6"		
Flood Level Elevation: NA		
Above Flood Level: Yes: No:		

G-0858-03

Component Sheet No: 28  
 Revision O  
 Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>  Plant I.D. Number: MO-3-1402-25A,B Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (RELIANCE)</b> <b>AC MOTOR</b> Model Number: <b>TYPE SMB-1</b>  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (*F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	6.6 E05		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 5.2.11 & 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF RADIATION QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 29  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
		ENVIRONMENT
System:	Parameter	
CORE SPRAY	Operating Time	12 DAYS
Plant I.D. Number: MO-2-1402-25A	Temperature (°F)	103
Component: MOTOR OPERATED GATE VALVE	Pressure (PSIA)	14.7
Manufacturer: LIMITORQUE (RELIANCE) AC MOTOR	Relative Humidity (%)	100
Model Number: TYPE SMB-1	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	6.1 E05
Function/Service: CONTAINMENT ISOLATION PUMP 2-1401-A DISCHARGE	Aging	NOT REOD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location 10'-0" E OF COL. 41 BETWEEN COL. L & M Elevation 560'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time	12 DAYS	
Temperature (°F)	103	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	6.1 E05	
Aging	NOT REOD.	
Submergence	NA	

EQUIPMENT DESCRIPTION		
		ENVIRONMENT
System:	Parameter	
CORE SPRAY	Operating Time	12 DAYS
Plant I.D. Number: MO-3-1402-25B	Temperature (°F)	103
Component: MOTOR OPERATED GATE VALVE	Pressure (PSIA)	14.7
Manufacturer: LIMITORQUE (RELIANCE) AC MOTOR	Relative Humidity (%)	100
Model Number: TYPE SMB-1	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	6.6 E05
Function/Service: CONTAINMENT ISOLATION PUMP 3-1401-B DISCHARGE	Aging	NOT REOD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location NEAR COLUMN 47 BETWEEN COL. H & J Elevation 560'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 30  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>  Plant I.D. Number: MO-3-1402-38A,B Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (RELIANCE)</b> AC MOTOR Model Number: <b>TYPE SMB-000</b>  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	12 DAYS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	250	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	27.0	39.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.2 EO7	2.0 EO7	REF. (B)	REF. (B)	INDIVIDUAL TEST	SEE NOTE (2)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: Yes No:							

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975 B. 600461-B0003 QUALIFICATION TYPE TEST REPORT-LIMITORQUE VALVE ACTUATORS C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.2.6	1. ESTABLISH QUALIFICATION TEST TIME.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 31  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: CORE SPRAY	Operating Time	12 DAYS
Plant I.D. Number: MO-3-1402-38A	Temperature (°F)	242
Component: MOTOR OPERATED GATE VALVE	Pressure (PSIA)	27.0
Manufacturer: LIMITORQUE (RELIANCE) AC MOTOR	Relative Humidity (%)	100
Model Number: TYPE SMB-000	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.2 E07
Function/Service: DIVERT FLOW TO RECIRCULATION LINE ON LOW FLOW FROM PUMP 3-1401-A	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location TOP OF TORUS	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: CORE SPRAY	Operating Time	12 DAYS
Plant I.D. Number: MO-3-1402-38B	Temperature (°F)	242
Component: MOTOR OPERATED GATE VALVE	Pressure (PSIA)	27.0
Manufacturer: LIMITORQUE (RELIANCE) AC MOTOR	Relative Humidity (%)	100
Model Number: TYPE SMB-000	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.2 E07
Function/Service: DIVERT FLOW TO RECIRCULATION LINE ON LOW FLOW FROM PUMP 3-1401-B	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location TOP OF TORUS	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 32  
 Revision 0  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>  Plant I.D. Number: PT-3-1460A, B Component: <b>PRESSURE TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: 4532K-1101 CAT. #1032EAAL1 Purchase Order Number: GE-H-0389  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.3 E06		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 5.2.11 & 5.2.12 B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 33  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Temperature (°F)	150
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	1.3 E06
Aging	NOT REQD.	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Temperature (°F)	150
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	1.3 E06
Aging	NOT REQD.	Submergence	NA

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Temperature (°F)	150
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	1.3 E06
Aging	NOT REQD.	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 34  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CORE SPRAY</b>  Plant I.D. Number: <b>FT-3-1461A,B</b> Component: <b>FLOW TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: <b>4532K-1101</b> <b>CAT. #1032EAAL1</b> Purchase Order Number: <b>GE-H-0422</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.3 E06		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 5.2.11 & 5.2.12 B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF RADIATION QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 35  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>FT-3-1461A</b>	Temperature (°F)	150
Component: <b>FLOW TRANSMITTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>4532K-1101</b> CAT. #1032EAAL1	Chemical Spray	NA
Purchase Order Number: <b>GE-H10422</b>	Radiation (Rad)	1.3 E06
Function/Service: <b>PUMP 3-1401-A</b> <b>DISCHARGE FLOW, SEND SIGNAL TO FS-1464-A</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-19A SE CORNER ROOM Elevation 476'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>FT-3-1461B</b>	Temperature (°F)	150
Component: <b>FLOW TRANSMITTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>4532K-1101</b> CAT. #1032EAAL1	Chemical Spray	NA
Purchase Order Number: <b>GE-H-0422</b>	Radiation (Rad)	1.3 E06
Function/Service: <b>PUMP 3-1401-B</b> <b>DISCHARGE FLOW, SEND SIGNAL TO FS-1464-B</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-19B SW CORNER ROOM Elevation 476'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 36  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CORE SPRAY	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
Plant I.D. Number: FS-3-1464A,B	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
Component: FLOW SWITCH	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: BARTON	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: 288	Chemical Spray	NA	NA	NA	NA	NA	NA
Purchase Order Number: GE-H-0979	Radiation (Rad)	1.3 E06		REF. (C)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	NA
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 5.2.11 & 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY	1. GE TEST REPORT DV145C BECHTEL TO VERIFY DATA.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 37  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>FS-3-1464A</b>	Temperature (°F)	150
Component: <b>FLOW SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>288</b>	Chemical Spray	NA
Purchase Order Number: <b>GE-H-0979</b>	Radiation (Rad)	1.3 E06
Function/Service: <b>MO-3-1402-38A ON LOW FLOW</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-19A SE CORNER ROOM Elevation 476'-6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CORE SPRAY</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>FS-3-1464B</b>	Temperature (°F)	150
Component: <b>FLOW SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>288</b>	Chemical Spray	NA
Purchase Order Number: <b>GE-H-0979</b>	Radiation (Rad)	1.3 E06
Function/Service: <b>MO-3-1402-38B ON LOW FLOW</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-19B SW CORNER ROOM Elevation 476'-6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 38  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CORE SPRAY	Operating Time						SEE NOTE (1)
Plant I.D. Number: PS-3-1466A,B,C,D	Temperature (°F)						SEE NOTE (1)
Component: PRESSURE SWITCH	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence						NA
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 39  
 Revision  
 Date: - - -

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: CORE SPRAY		Operating Time	
Plant I.D. Number: PS-3-1466A		Temperature (°F)	
Component: PRESSURE SWITCH		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: CORE SPRAY		Operating Time	
Plant I.D. Number: PS-3-1466B		Temperature (°F)	
Component: PRESSURE SWITCH		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	
Elevation		Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 40  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>CORE SPRAY</b>		Operating Time	
Plant I.D. Number: <b>PS-3-1466C</b>		Temperature (°F)	
Component: <b>PRESSURE SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Location	Demo:	Submergence	
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>CORE SPRAY</b>		Operating Time	
Plant I.D. Number: <b>PS-3-1466D</b>		Temperature (°F)	
Component: <b>PRESSURE SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Location	Demo:	Submergence	
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3.  
 Docket No: 50-249

Component Sheet No: 41  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-3 Component: <b>MOTOR-OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> DC MOTOR Model Number: SMB-3-100  Purchase Order Number: 3447-141 SPEC. K-2205 Function/Service: <b>STEAM TO TURBINE STOP VALVE</b>  Accuracy: Spec: NA Demo: NA Location: HPCI ROOM Elevation: 485'0"  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.0 E07		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 42  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-4 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (RELIANCE)</b> AC MOTOR Model Number: SMB-1-60  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>STEAM SUPPLY LINE INBOARD ISOLATION VALVE</b>	Operating Time	12 DAYS	16 DAYS	REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMAL 150 LOCA 281	250	REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	39.7	REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Relative Humidity (%)	100	100	REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.0 E08	2.0 E07	REF. (C)	REF. (B)	INDIVIDUAL TEST	
	Aging		165 F FOR 199.8 HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	SEE NOTE (1)
Flood Level Elevation: 505' 6" Above Flood Level: Yes: X No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 AND TABLE 5.2.2 B. REPORT NO 600461-B0003, QUALIFICATION TYPE TEST REPORT FOR LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE CONTAINMENT C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER 2. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 43  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System:  HIGH PRESSURE COOLANT INJECTION  Plant I.D. Number: MO-3-2301-5 Component: MOTOR-OPERATED GATE VALVE Manufacturer: LIMITORQUE (PEERLESS) DC MOTOR Model Number: SMB-3-100  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: STEAM SUPPLY LINE ISOLATION VALVE  Accuracy: Spec: NA Demo: NA Location: ABOVE TORUS NEAR 90 AZMIUTH, PENX115A Elevation: 513'9"	Operating Time	12 DAYS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMAL 103 HELB 242	340	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	NORMAL 14.7 HELB 27	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.2 E07	1.0 E07	REF. (D)	REF. (B)	INDIVIDUAL TEST	SEE NOTE (3)
	Aging	NOT REQD.	185C FOR 100 HOURS		REF. (B)	INDIVIDUAL TEST	
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. REPORT NO 600426-B0009, QUALIFICATION TYPE TEST REPORT - LIMITORQUE DC VALVE ACTUATORS. ONLY THE MOTOR WAS THERMALLY AGED. LIMITORQUE USES THESE UNITS AT TEMPERATURES OF 300 F CONTINUOUSLY. THEREFORE AGING WAS CONSIDERED NECESSARY FOR THE MOTORS ONLY.	1. RESOLVE QUALIFICATION TEST TIME 2. TEST PROCEDURE REQUIRES A SATURATED ATMOSPHERE, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST. 3. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 44  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. SPECIAL REPORT NO 37, REV 1, FEB 1975 D. BECHTEL RADIATION STUDY	

Component Sheet No: 45  
 Revision O  
 Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-6 Component: MOTOR-OPERATED GATE VALVE Manufacturer: LIMITORTQUE (PEERLESS) DC MOTOR Model Number: SMB-O-25  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: HPCI PUMP SUCTION VALVE FROM CONDENSATE STORAGE TANK	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.3 E06		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 46  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Quat.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-8 Component: <b>MOTOR-OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> DC MOTOR Model Number: SMB-3-80  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>HPCI PUMP DISCHARGE ISOLATION VALVE</b>	Operating Time	1 MINUTE		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	340	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	27.0	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	1.0 E07	REF. (D)	REF. (B)	INDIVIDUAL TEST	
	Aging	NOT REQD.	185C FOR 100 HOURS	REF. (E)	REF. (B)	INDIVIDUAL TEST	SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. REPORT NO 600426-B0009, QUALIFICATION TYPE TEST REPORT - LIMITORQUE DC ACTUATORS. ONLY THE MOTOR WAS THERMALLY AGED. LIMITORQUE CORP USES THESE UNITS AT TEMPERATURES OF 300 F CONTINUOUSLY. THEREFORE AGING WAS CONSIDERED NECESSARY FOR THE MOTORS ONLY.	1. RESOLVE QUALIFICATION TEST TIME 2. THE TEST PROCEDURE CALLS OUT A SATURATED ATMOSPHERE, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST. 3. RESOLVE AGING REQUIREMENTS

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 47  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. SPECIAL REPORT NO 37, REV1, FEB1975 D. BECHTEL RADIATION STUDY E. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 48  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-9 Component: <b>MOTOR-OPERATED GATE VALVE (DC)</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> DC MOTOR Model Number: SMB.2-80  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>HPCI PUMP DISCHARGE VALVE</b>  Accuracy: Spec: NA Demo: NA Location: <b>HPCI ROOM</b>  Elevation: 490'3"	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.7 E04		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.3 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 49  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-10 Component: <b>MOTOR OPERATED GLOBE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> DC MOTOR Model Number: SMB-3-150  Purchase Order Number:  Function/Service: <b>TEST RETURN LINE ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: HPCI ROOM  Elevation: 488'0"	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.4 E05		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.3 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUILIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 50  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3--2301-14 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number: SMB-0-25  Purchase Order Number:  Function/Service: <b>TEST RETURN LINE ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: 9'0" S OF COL N 4'6" W OF COL 44 Elevation: 483'3"	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT RE		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.4 E05		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 5.1  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-15 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> DC MOTORS Model Number: L210226T2-AT  Purchase Order Number:  Function/Service: <b>TEST RETURN LINE ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: <b>HPCI PUMP ROOM</b>  Elevation: 485'0"	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.7 E04		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR TABLE 8.2.3 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 52  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-35 Component: <b>MOTOR-OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> DC MOTOR Model Number: SMB-0-25  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>HPCI PUMP SUCTION ISOLATION VALVE FROM TORUS</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	5.9 E06		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 53  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-2301-48 Component: MOTOR OPERATED GATE VALVE Manufacturer: LIMITORQUE (PEERLESS) DC MOTOR Model Number: SMB-000-5  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service:	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.0 E07		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 54  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>MO-3-2301-49</b> Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number:  Purchase Order Number:  Function/Service:	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	5.9 E06		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:	()						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Component Sheet No: 55  
 Revision O  
 Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: SO-3-2301-29 Component: <b>SOLENOID VALVE</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service: <b>PILOT VALVE FOR STEAM LINE DRAIN ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: <b>HPCI PUMP ROOM</b>  Elevation: 476' O"	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 56  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>SO-3-2301-30</b> Component: <b>SOLENOID VALVE</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service: <b>PILOT VALVE FOR STEAM LINE DRAIN ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: HPCI PUMP ROOM  Elevation: 476' 0"	Operating Time	1MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 57  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time		NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: SO-2-2301-32	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer:	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	NA
Purchase Order Number:	Radiation (Rad)		NOT REQD.	REF. (C)	NOT REQD.		
Function/Service: <b>PILOT VALVE-ACTUATES CONDENSER DRAIN POT DRAIN VALVE</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>HPCI PUMP ROOM</b>	Submergence	NA	NA	NA	NA	NA	NA
Elevation: 476' O"							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Component Sheet No: 58  
 Revision O  
 Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	PARAMETER	FSAR	Qualification	FSAR	Qual.		
<b>System:</b> <b>HIGH PRESSURE COOLANT INJECTION</b>  <b>Plant I.D. Number:</b> MO-3-2301-36 <b>Component:</b> <b>MOTOR-OPERATED GATE VALVE</b> <b>Manufacturer:</b> <b>LIMITORQUE (PEERLESS)</b> <b>DC MOTOR</b> <b>Model Number:</b> <b>SMB-O-25</b>  <b>Purchase Order Number:</b> 3447-141, SPEC K-2205 <b>Function/Service:</b> <b>HPCI PUMP SUCTION VALVE</b>  <b>Accuracy:</b> Spec: NA Demo: NA <b>Location:</b> SW CORNER ROOM  <b>Elevation:</b> 480'0"  <b>Flood Level</b> <b>Elevation:</b> NA <b>Above Flood Level:</b> Yes: No:	Operating Time	12 DAYS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	150	340	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	14.7	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.3 E06		REF. (D)	REF. (B)	INDIVIDUAL TEST	
	Aging		180C FOR 100 HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. REPORT NO.600426-B0009, QUALIFICATION TYPE TEST REPORT-LIMITORQUE DC VALVE ACTUATORS. ONLY THE MOTOR WAS THERMALLY AGED. LIMITORQUE CORP. USES THESE UNITS AT TEMPERATURES OF 300F CONTINUOUSLY. THEREFORE, AGING WAS CONSIDERED NECESSARY FOR THE MOTOR ONLY.	1. RESOLVE QUALIFICATION TEST TIME. 2. TEST PROCEDURE REQUIRED SATURATED STEAM ATMOSPHERE BUT HUMIDITY WAS NOT MEASURED DURING THE TEST. 3. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 59  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. FSAR SECTION 6.2.3.2 D. BECHTEL RADIATION STUDY.	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 60  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: SO-3-2301-64 Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: CAT# HT8320  Purchase Order Number:  Function/Service: PILOT VALVE TO STEAM LINE CONDENSATE DRAIN VALVE TO SUPPRESSION CHAMBER  Accuracy: Spec: NA Demo: NA Location: HPCI ROOM  Elevation: 478'0"	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 61  
 Revision O  
 Date: 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: SO-3-2301-65 Component: <b>SOLENOID VALVE</b>  Manufacturer: <b>ASCO</b>  Model Number: <b>CAT# HT8320</b>  Purchase Order Number:  Function/Service:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4:3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 62  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: SV12	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>TURBINE STOP VALVE</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer:	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	1.2 E07		REF. (C)			SEE NOTE (1)
Function/Service: <b>ISOLATE HPCI TURBINE</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: NA Demo: NA	Submergence	NA	NA	NA	NA	NA	
Location: <b>HPCI ROOM</b>							
Elevation: 485' 0"							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 63  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number:	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>TURBINE GLAND SEAL CONDENSER DRAIN PUMP</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: <b>5B225A3525</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	7.4 E05		REF. (C)			SEE NOTE (1)
Function/Service:	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: NA Demo: NA	Submersion	NA	NA	NA	NA	NA	
Location: <b>HPCI ROOM</b>							
Elevation: <b>472' 0"</b>							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 64  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: HIGH PRESSURE COOLANT INJECTION	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: DIFFERENTIAL PRESSURE INDICATING SWITCH	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: BARTON	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE H0705	Radiation (Rad)	3.2 E05		REF. (C)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 65  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Operating Time	12 DAYS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.2 E05	Radiation (Rad)	3.2 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Operating Time	12 DAYS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.2 E05	Radiation (Rad)	3.2 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 66  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>NONE</b> Component: <b>MOTOR SPEED CHANGER</b>  Manufacturer: <b>G. E. GEAR</b>  Model Number: <b>TYPE M-304-A</b> <b>SN. 138347</b> Purchase Order Number:  Function/Service: <b>CONTROL HPCI TURBINE SPEED</b>  Accuracy: Spec: Demo: Location: <b>HPCI ROOM</b>  Elevation: <b>476'6"</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.2 E06		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 67  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>FT-3-2358</b> Component: <b>FLOW TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: <b>4532K13001</b>  Purchase Order Number: <b>GE HO950</b>  Function/Service: <b>HPCI PUMP DISCHARGE FLOW TRANSMITTER</b>  Accuracy: Spec: Demo: Location: <b>RACK 2203-29</b> SW CORNER ROOM Elevation: <b>476' 6"</b>	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.1 E06		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Component Sheet No: 68  
 Revision O  
 Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>PT-3-2359</b> Component: <b>PRESSURE TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: <b>4532K11001</b>  Purchase Order Number: <b>GE H0950</b> <b>CAT 50-551032GAAK1</b> Function/Service: <b>TRANSMIT SIGNAL TO PRESSURE SWITCH</b>  Accuracy: Spec: Demo: Location: <b>RACK 2203-29</b> <b>SW CORNER ROOM</b> Elevation: <b>476'6"</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	150		REF. (B)			SEE NOTE (2)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (C)	NOT REQD.		
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.1 E06		REF. (C)			SEE NOTE (2)
	Aging						SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	2. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 69  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: HIGH PRESSURE COOLANT INJECTION	Operating Time						SEE NOTE (1)
Plant I.D. Number: LSH-2-2369	Temperature (°F)						SEE NOTE (1)
Component: LEVEL SWITCH (HIGH)	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: MAGNETROL	Relative Humidity (%)						SEE NOTE (1)
Model Number: 402-513H4	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE HO804 SPEC 21A1136	Radiation (Rad)						SEE NOTE (1)
Function/Service: CONTACT CLOSES ON HIGH DRAIN POT WATER LEVEL, OPENS SO 2301-32	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: HPCI PUMP ROOM							
Elevation: 482'0"							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 70  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: <b>TYPE F-7 76-B</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>GE H0752</b>	Radiation (Rad)	1.6 E07		REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 71  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2370A	Temperature (°F)	103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F-7 76-B</b>	Chemical Spray	NA
Purchase Order Number: GE H0752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSES ON HIGH TEMPERATURE + CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2370B	Temperature (°F)	103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F-7 76-B</b>	Chemical Spray	NA
Purchase Order Number: GE H0752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSES ON HIGH TEMPERATURE + CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 72  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	HIGH PRESSURE COOLANT INJECTION
Plant I.D. Number:	TS-3-2370C
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC CONTROLS
Model Number:	TYPE F-7 76-B
Purchase Order Number:	GE HO752
Function/Service:	CONTACT CLOSES ON HIGH TEMPERATURE & CLOSES ISOLATION VALVES
Accuracy:	Spec: Demo:
Location	HPCI ROOM
Elevation	483'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	12 DAYS
Temperature (°F)	103
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	1.6 E07
Aging	NOT REQD.
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	HIGH PRESSURE COOLANT INJECTION
Plant I.D. Number:	TS-3-2370D
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC CONTROLS
Model Number:	TYPE F-7 76-B
Purchase Order Number:	GE HO752
Function/Service:	CONTACT CLOSES ON HIGH TEMPERATURE & CLOSES ISOLATION VALVES
Accuracy:	Spec: Demo:
Location	HPCI ROOM
Elevation	483'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 73  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2371A	Temperature (°F)	103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: TYPE F-7 76-B	Chemical Spray	NA
Purchase Order Number: GE H0752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSES ON HIGH TEMPERATURE &amp; CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location: <b>HPCI ROOM</b>	Submergence	NA
Elevation 483'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2371B	Temperature (°F)	103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: TYPE F-7 76-B	Chemical Spray	NA
Purchase Order Number: GE H0752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSES ON HIGH TEMPERATURE &amp; CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location: <b>HPCI ROOM</b>	Submergence	NA
Elevation 483'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 74  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	HIGH PRESSURE COOLANT INJECTION
Plant I.D. Number:	TS-3-2371C
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC CONTROLS
Model Number:	TYPE F-7 76-B
Purchase Order Number:	GE HO752
Function/Service:	CONTACT CLOSES ON HIGH TEMPERATURE & CLOSES ISOLATION VALVES
Accuracy: Spec:	
Location	HPCI ROOM
Elevation	483'0"
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	12 DAYS
Temperature (°F)	103
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	1.6 E07
Aging	NOT REQD.
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	HIGH PRESSURE COOLANT INJECTION
Plant I.D. Number:	TS-3-2371D
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC CONTROLS
Model Number:	TYPE F-7 76-B
Purchase Order Number:	GE HO752
Function/Service:	CONTACT CLOSES ON HIGH TEMPERATURE & CLOSES ISOLATION VALVES
Accuracy: Spec:	
Location	HPCI ROOM
Elevation	483'0"
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 75  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS		
Temperature (°F)	103		
Pressure (PSIA)	14.7		
Relative Humidity (%)	100		
Chemical Spray	NA		
Radiation (Rad)	1.6 E07		
Aging	NOT REQD.		
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS		
Temperature (°F)	103		
Pressure (PSIA)	14.7		
Relative Humidity (%)	100		
Chemical Spray	NA		
Radiation (Rad)	1.6 E07		
Aging	NOT REQD.		
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 76  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2372C	Temperature (°F)	103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F-7 76-B</b>	Chemical Sprey	NA
Purchase Order Number: GE HO752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSES ON HIGH TEMPERATURE &amp; CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2372D	Temperature (°F)	103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F-7 76-B</b>	Chemical Spray	NA
Purchase Order Number: GE HO752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSES ON HIGH TEMPERATURE &amp; CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 77  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH TEMPERATURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2373A	Temperature (°F)	103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F-7 76-B</b>	Chemical Spray	NA
Purchase Order Number: GE H0752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSES ON HIGH TEMPERATURE &amp; CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH TEMPERATURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2373B	Temperature (°F)	- 103
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>UNITED ELECTRIC CONTROLS</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F-7 76-B</b>	Chemical Spray	NA
Purchase Order Number: GE H0752	Radiation (Rad)	1.6 E07
Function/Service: <b>CONTACT CLOSE ON HIGH TEMPERATURE &amp; CLOSES ISOLATION VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 78  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: HIGH TEMPERATURE COOLANT INJECTION	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2373C	Temperature (°F)	103
Component: TEMPERATURE SWITCH	Pressure (PSIA)	14.7
Manufacturer: UNITED ELECTRIC CONTROLS	Relative Humidity (%)	100
Model Number: TYPE F-7 76-B	Chemical Spray	NA
Purchase Order Number: GE HO752	Radiation (Rad)	1.6 E07
Function/Service: CONTACT CLOSES ON HIGH TEMPERATURE & CLOSES ISOLATION VALVES	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: HIGH TEMPERATURE COOLANT INJECTION	Operating Time	12 DAYS
Plant I.D. Number: TS-3-2373D	Temperature (°F)	103
Component: TEMPERATURE SWITCH	Pressure (PSIA)	14.7
Manufacturer: UNITED ELECTRIC CONTROLS	Relative Humidity (%)	100
Model Number: TYPE F-7 76-B	Chemical Spray	NA
Purchase Order Number: GE HO752	Radiation (Rad)	1.6 E07
Function/Service: CONTACT CLOSES ON HIGH TEMPERATURE & CLOSES ISOLATION VALVES	Aging	NOT REQD.
Accuracy: Spec: Demo: Location HPCI ROOM	Submergence	NA
Elevation 483'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 79  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>PT-3-2382</b>	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
Component: <b>PRESSURE TRANSMITTER</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: <b>4532K11001</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>GE HO950</b>	Radiation (Rad)	2.1 E06		REF. (C)			SEE NOTE (1)
Function/Service: <b>TRANSMIT SIGNAL TO PRESSURE SWITCH</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>RACK 2203-29 SW CORNER ROOM</b>							
Elevation: <b>476' 6"</b>							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 80  
 Revision O  
 Date C4-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number:	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>MOTOR GEAR UNIT</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: <b>5CD14D19A111620</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	1.2 E06		REF. (C)			SEE NOTE (1)
Function/Service: <b>HPCI PUMP TORQUE SPEED CONTROL</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: NA Demo: NA	Submergence	NA	NA	NA	NA	NA	
Location: <b>HPCI ROOM</b>							
Elevation: <b>483'0"</b>							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2, 11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 81  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: HIGH PRESSURE COOLANT INJECTION	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number:	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: EMERGENCY OIL PUMP MOTOR DRIVEN	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: 5CD218E252	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service: PROVIDE LUBRICATING OIL TO TURBINE	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: NA Demo: NA	Submergence	NA	NA	NA	NA	NA	
Location: HPCI ROOM							
Elevation: 476' 6"							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 82  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number:	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>AUXILIARY OIL PUMP</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: 5CB326E765	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service: <b>PROVIDE LUBRICATING OIL TO TURBINE</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: NA Demo: NA	Submergence	NA	NA	NA	NA	NA	
Location: HPCI ROOM							
Elevation: 476' 6"							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 83  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	PARAMETER	FSAR	Qualification	FSAR	Qual.		
System: HIGH PRESSURE COOLANT INJECTION	Operating Time	12 DAYS	NOT REQD.	REF. (A)			
Plant I.D. Number:	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: GLAND STEAM EXHAUSTER FAN	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: 5BC74AV2193	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service:	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: NA Demo: NA	Submergence	NA	NA	NA	NA	NA	
Location: HPCI ROOM							
Elevation: 476'6"							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 84  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS		REF. (A)			SEE NOTE (1)
Plant I.D. Number: TE-3-2374A,B,C,D	Temperature (°F)						SEE NOTE (1)
Component: <b>TEMPERATURE ELEMENT</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: SCAM	Relative Humidity (%)						SEE NOTE (1)
Model Number: 855-1	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 85  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>TE-3-2374A</b>	Temperature (°F)	
Component: <b>TEMPERATURE ELEMENT</b>	Pressure (PSIA)	
Manufacturer: <b>SCAM</b>	Relative Humidity (%)	
Model Number: <b>855-1</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>TE-3-2374B</b>	Temperature (°F)	
Component: <b>TEMPERATURE ELEMENT</b>	Pressure (PSIA)	
Manufacturer: <b>SCAM</b>	Relative Humidity (%)	
Model Number: <b>855-1</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 86  
 Revision O  
 Date: 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>TE-3-2374C</b>	Temperature (°F)	
Component: <b>TEMPERATURE ELEMENT</b>	Pressure (PSIA)	
Manufacturer: <b>SCAM</b>	Relative Humidity (%)	
Model Number: <b>855-1</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>TE-3-2374D</b>	Temperature (°F)	
Component: <b>TEMPERATURE ELEMENT</b>	Pressure (PSIA)	
Manufacturer: <b>SCAM</b>	Relative Humidity (%)	
Model Number: <b>855-1</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 87  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: <b>PS-3-2389A,B,C,D</b>	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: <b>B2T-12SS-GE</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	3.2 E05		REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 AND 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 88  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Operating Time	12 DAYS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.2 E05	Radiation (Rad)	3.2 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Operating Time	12 DAYS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.2 E05	Radiation (Rad)	3.2 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 89  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Temperature (°F)	103
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	3.2 E05
Aging	NOT REQD.	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Temperature (°F)	103
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	3.2 E05
Aging	NOT REQD.	Submergence	NA

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	12 DAYS	Temperature (°F)	103
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	3.2 E05
Aging	NOT REQD.	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 90  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>POS-3-2301-29</b> Component: <b>POSITION SWITCH</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 91  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: POS-3-2301-30	Temperature (°F)						SEE NOTE (1)
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Location: Elevation: Flood Level Elevation: Above Flood Level: Yes: No:	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 92  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>POS-3-2301-64</b> Component: <b>POSITION SWITCH</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes:     No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 93  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>POS-3-2301-65</b> Component: <b>POSITION SWITCH</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 94  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: 3-2386 Component: HPCI MOTOR CONTROL SIGNAL CONVERTER Manufacturer:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 95  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>PS-3-2360</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Location: Demo:	Submergence						SEE NOTE (1)
Elevation:	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 96  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: LS-3-2351A,B	Temperature (°F)						SEE NOTE (1)
Component: <b>LEVEL SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence						SEE NOTE (1)
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 97  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>		Operating Time	
Plant I.D. Number: <b>LS-3-2351A</b>		Temperature (°F)	
Component: <b>LEVEL SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo:		Submergence	
Location		Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>		Operating Time	
Plant I.D. Number: <b>LS-3-2351B</b>		Temperature (°F)	
Component: <b>LEVEL SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo:		Submergence	
Location		Flood Level Elevation: Above Flood Level: Yes: No:	
Elevation			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 98  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>FS-3-2354</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>FLOW SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Location: Demo:	Submergence						SEE NOTE (1)
Elevation:	Flood Level Elevation: Above Flood Level: Yes: No:						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	<p>1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 99  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: PS-3-2368A,B Component: <b>PRESSURE SWITCH</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service: <b>'SEE ATTACHED SHEETS'</b>  Accuracy: Spec: Demo: Location: <b>'SEE ATTACHED SHEETS'</b>  Elevation: <b>'SEE ATTACHED SHEETS'</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 100  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>		Operating Time	
Plant I.D. Number: <b>PS-3-2368A</b>		Temperature (°F)	
Component: <b>PRESSURE SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>		Operating Time	
Plant I.D. Number: <b>PS-3-2368B</b>		Temperature (°F)	
Component: <b>PRESSURE SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	
Elevation		Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Component Sheet No: 101  
Revision  
Date

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>LS-LCS-1</b> Component: <b>LEVEL SWITCH</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes:     No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	<p>1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 102  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>HIGH PRESSURE COOLANT INJECTION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>LS-2/3-2350A,B,C,D</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>LEVEL SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence						SEE NOTE (1)
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 103  
 Revision  
 Date:

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time			
Temperature (°F)			
Pressure (PSIA)			
Relative Humidity (%)			
Chemical Spray			
Radiation (Rad)			
Aging			
Submergence			
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time			
Temperature (°F)			
Pressure (PSIA)			
Relative Humidity (%)			
Chemical Spray			
Radiation (Rad)			
Aging			
Submergence			
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 104  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>		Operating Time	
Plant I.D. Number: L-2/3-2350C		Temperature (°F)	
Component: <b>LEVEL SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>HIGH PRESSURE COOLANT INJECTION</b>		Operating Time	
Plant I.D. Number: L-2/3-2350D		Temperature (°F)	
Component: <b>LEVEL SWITCH</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	
Elevation		Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 105  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>  Plant I.D. Number: <b>A0-3-203-1&amp;2A-D</b> Component: <b>MSIV AND SOLENOID FOR AIR OPERATOR</b> Manufacturer: <b>AUTOMATIC VALVE CO.</b>  Model Number: <b>C5512</b>  Purchase Order Number: <b>GE H-0049 SPEC 21A5644AB</b> Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	10.5 SECONDS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	NORMAL 150 LOCA 281		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray			REF. (C)			SEE NOTE (1)
	Radiation (Rad)	5.8 E04		REF. (D)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.7.2.D B. FSAR FIGURES 5.2.11&5.2.12&FSAR TABLE 5.2.1 C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 106  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	NORMAL 150 LOCA 281	
Pressure (PSIA)	NORMAL 14.7 LOCA 63	
Relative Humidity (%)	100	
Chemical Spray	DEMIN WATER	
Radiation (Rad)	5.8 EO4	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	10.5 SECONDS	
Temperature (°F)	NORMAL 150 LOCA 281	
Pressure (PSIA)	NORMAL 14.7 LOCA 63	
Relative Humidity (%)	100	
Chemical Spray	DEMIN WATER	
Radiation (Rad)	5.8 EO4	
Aging		
Submergence	NA	
Flood Level Elevation: 505'6" Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 107  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	10.5	SECONDS
Temperature (°F)	NORMAL 150 LOCA 281	
Pressure (PSIA)	NORMAL 14.7 LOCA 63	
Relative Humidity (%)	100	
Chemical Spray	DEMIN WATER	
Radiation (Rad)	5.8 E04	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	10.5	SECONDS
Temperature (°F)	NORMAL 150 LOCA 281	
Pressure (PSIA)	NORMAL 14.7 LOCA 63	
Relative Humidity (%)	100	
Chemical Spray	DEMIN WATER	
Radiation (Rad)	5.8 E04	
Aging		
Submergence	NA	
Flood Level Elevation: 505'6" Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 108  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM		Operating Time	10.5 SECONDS
Plant I.D. Number: AO-3-203-2A		Temperature (°F)	NORMAL 120 HELB 242
Component: MSIV AND SOLENOID FOR AIR OPERATOR		Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: AUTOMATIC VALVE CO.		Relative Humidity (%)	100
Model Number: C5512		Chemical Spray	NA
Purchase Order Number: GE H-0049 SPEC 21A5644AB		Radiation (Rad)	<1.0 EO4
Function/Service: PILOT SOLENOID VALVE FOR OUTBOARD MSIV ON A STEAM LINE		Aging	
Accuracy: Spec: NA Demo: NA		Submergence	NA
Location STEAM TUNNEL NEAR DRYWELL PENETRATION		Flood Level	
Elevation 515'6"		Elevation: NA	
Above Flood Level: Yes: No:		Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM		Operating Time	10.5 SECONDS
Plant I.D. Number: AO-3-203-2B		Temperature (°F)	NORMAL 120 HELB 242
Component: MSIV AND SOLENOID FOR AIR OPERATOR		Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: AUTOMATIC VALVE CO.		Relative Humidity (%)	100
Model Number: C5512		Chemical Spray	NA
Purchase Order Number: GE H-0049 SPEC 21A5644AB		Radiation (Rad)	<1.0 EO4
Function/Service: PILOT SOLENOID VALVE FOR OUTBOARD MSIV ON B STEAM LINE		Aging	
Accuracy: Spec: NA Demo: NA		Submergence	NA
Location STEAM TUNNEL NEAR DRYWELL PENETRATION		Flood Level	
Elevation 515'6"		Elevation: NA	
Above Flood Level: Yes: No:		Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 109  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	10.5 SECONDS
Plant I.D. Number: AO-3-203-2C	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>MSIV AND SOLENOID FOR AIR OPERATOR</b>	Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: AUTOMATIC VALVE CO.	Relative Humidity (%)	100
Model Number: C5512	Chemical Spray	NA
Purchase Order Number: GE H-0049 SPEC 21A5644AB	Radiation (Rad)	<1.0 E04
Function/Service: <b>PILOT SOLENOID VALVE FOR OUTBOARD MSIV ON C STEAM LINE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location STEAM TUNNEL NEAR DRYWELL PENETRATION Elevation 515'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	10.5 SECONDS
Plant I.D. Number: AO-3-203-2D	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>MSIV AND SOLENOID FOR AIR OPERATOR</b>	Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: AUTOMATIC VALVE CO.	Relative Humidity (%)	100
Model Number: C5512	Chemical Spray	
Purchase Order Number: GE H-0049 SPEC 21A5644AB	Radiation (Rad)	<1.0 E04
Function/Service: <b>PILOT SOLENOID VALVE FOR OUTBOARD MSIV ON D STEAM LINE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location STEAM TUNNEL NEAR DRYWELL PENETRATION Elevation 515'6"	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 110  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>  Plant I.D. Number: 3-203-3A Component: <b>SAFETY RELIEF VALVE AND SOLENOID</b> Manufacturer: DRESSER INDUSTRIES  Model Number: C5450-5  Purchase Order Number: GE H-0270 SPEC 21A5482 Function/Service: <b>SAFETY RELIEF VALVE FOR REACTOR PRESSURE VESSEL</b>  Accuracy: Spec: Demo: Location: <b>INSIDE DRYWELL ON A MAIN STEAM LINE</b> Elevation: 539'0"  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS		REF. (A)		SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMAL 150 LOCA 281	300	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	NORMAL 14.7 LOCA 63	76.7	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (3)
	Radiation (Rad)	1.0 E08		REF. (D)			SEE NOTE (3)
	Aging						SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11&5.2.12&FSAR TABLE 5.2.1 B. PEP#42963 PROJECT ENGINEER PROGRAM TEST-DRESSER RELIEF VALVE ACTUATOR. C. FSAR SECTION 6.2.4.2.B. D. BECHTEL RADIATION STUDY.	1. RESOLVE QUALIFICATION TEST TIME 2. RESOLV HUMIDITY DURING TEST 3. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 111  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>  Plant I.D. Number: 3-203-3B-E Component: <b>ELECTROMATIC RELIEF VALVE AND SOLENOID</b> Manufacturer: <b>DRESSER INDUSTRIES</b>  Model Number: <b>TYPE 1525VX</b>  Purchase Order Number: GE H-0270 SPEC 21A5482 Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS		REF. (A)		SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMA 150 LOCA 281	300	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	NORMAL 14.7 LOCA 63	62	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100			REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (2)
	Radiation (Rad)	1.0 E08		REF. (D)			SEE NOTE (2)
	Aging						SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11&5.2.12&FSAR TABLE 5.2.1 B. PEP#42963 PROJECT ENGINEER PROGRAM TEST-DRESSER RELIEF VALVE ACTUATOR. C. FSAR SECTION 6.2.4.2.B. D. BECHTEL RADIATION STUDY.	1. RESOLVE QUALIFICATION TEST TIME 2. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 112  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time	12 DAYS
Plant I.D. Number: 3-203-3B	Temperature (°F)	NORMAL 150 LOCA 281
Component: ELECTROMATIC RELIEF VALVE AND SOLENOID	Pressure (PSIA)	NORMAL 14.7 LOCA 63
Manufacturer: DRESSER INDUSTRIES	Relative Humidity (%)	100
Model Number: TYPE 1525VX	Chemical Spray	DEMIN WATER
Purchase Order Number: TYPE 1525VX	Radiation (Rad)	1.0 E08
Function/Service: RELIEF VALVE FOR REACTOR PRESSURE VESSEL	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location INSIDE DRYWELL ON B MAIN STEAM LINE	Flood Level	
Elevation 539'0"	Elevation:	NA
Above Flood Level: Yes: No:	Above Flood Level:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time	12 DAYS
Plant I.D. Number: 3-203-3C	Temperature (°F)	NORMAL 150 LOCA 281
Component: ELECTROMATIC RELIEF VALVE AND SOLENOID	Pressure (PSIA)	NORMAL 14.7 LOCA 63
Manufacturer: DRESSER INDUSTRIES	Relative Humidity (%)	100
Model Number: TYPE 1525VX	Chemical Spray	DEMIN WATER
Purchase Order Number: TYPE 1525VX	Radiation (Rad)	1.0 E08
Function/Service: RELIEF VALVE FOR REACTOR PRESSURE VESSEL	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location INSIDE DRYWELL ON C MAIN STEAM LINE	Flood Level	
Elevation 539'0"	Elevation:	505'6"
Above Flood Level: Yes: No:	Above Flood Level:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 113  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	12 DAYS	
Temperature (°F)	NORMAL 150 LOCA 281	
Pressure (PSIA)	NORMAL 14.7 LOCA 63	
Relative Humidity (%)	100	
Chemical Spray	DEMIN WATER	
Radiation (Rad)	1.0 EO8	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	12 DAYS	
Temperature (°F)	NORMAL 150 LOCA 281	
Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	
Relative Humidity (%)	100	
Chemical Spray	DEMIN WATER	
Radiation (Rad)	1.0 EO8	
Aging		
Submergence	NA	
Flood Level Elevation: 505'6" Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 114  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>  Plant I.D. Number: <b>MO-3-220-1</b> Component: <b>MOTOR OPERATED GLOBE VALVE</b> Manufacturer: <b>LIMITORQUE (RELIANCE)</b>  Model Number: <b>SMB-00-7.5 SN. 73861A</b> Purchase Order Number: <b>3447-141 SPEC K-2205</b> Function/Service: <b>MAIN STEAM LINE DRAIN CONTAINMENT ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: <b>INSIDE DRYWELL NEAR 0 AZIMUTH</b> Elevation: <b>515'0"</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1 MINUTE	16 DAYS	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Temperature (°F)	NORMAL 150 LOCA 281	250	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63	39.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Relative Humidity (%)	100	100		REF. (B)	SIMULTANEOUS TEST	
	Chemical Spray	DEMIN WATER		REF. (D)			
	Radiation (Rad)	3.3 E06	2E07	REF. (E)	REF. (B)	INDIVIDUAL TEST	SEE NOTE (2)
	Aging		165F 199.8HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	NA

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REPORT NO. 600461-B0003 QUALIFICATION TYPE TEST REPORT-LIMITORQUE VALVE ACTUATORS FOR CLASS 1E SERVI -CE OUTSIDE PRIMARY CONTAINMENT. C. FSAR FIGURES 5.2.11 & 5.2.12 D. FSAR SECTION 6.2.4.2.B. E. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF ADDITIONAL QUALIFICATION DATA WITH MANUFACTURER. 2. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 115  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>  Plant I.D. Number: <b>MO-3-220-2</b> Component: <b>MOTOR OPERATED GLOBE VALVE</b> Manufacturer: <b>LIMITORQUE (RELIANCE A</b>  Model Number: <b>SMB-00-7.5</b>  Purchase Order Number: <b>3447-141</b> <b>SPEC K-2205</b> Function/Service: <b>MAIN STEAM LINE DRAIN CONTAINMENT ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: <b>STEAM TUNNEL NEAR DRYWELL PENETRATION</b> Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1 MINUTE	16 DAYS	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Temperature (°F)	NORMAL 120 LOCA 281	250	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63	39.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Chemical Spray	DEMIN WATER		REF. (D)			SEE NOTE (1)
	Radiation (Rad)		2E07	REF. (E)	REF. (B)	INDIVIDUAL TEST	
	Aging		165F 199.8HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	NA

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REPORT NO. 600461-B0003 QUALIFICATION TYPE TEST REPORT-LIMITORQUE VALVE ACTUATORS FOR CLASS 1E SERVI -CE OUTSIDE PRIMARY CONTAINMENT. C. FSAR FIGURES 5.2.11 & 5.2.12 D. FSAR SECTION 6.2.4.2.B. E. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF ADDITIONAL QUALIFICATION DATA WITH MANUFACTURER. 2. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 116  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time	<1 MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
Component: DIFFERENTIAL PRESSURE INDICATING SWITCH	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: BARTON	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: 278/224	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE H-0953 SPEC 21A1155AC	Radiation (Rad)	<1.0 E04		REF. (C)			
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (2)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
<p>A. THESE SENSORS ARE UTILIZED TO DETECT A MAIN STEAM LINE BREAK BY- MEASURING HIGH STEAM LINE FLOWW. AS SOON AS A STEAM LINE BREAK OCCURS, THE SENSORS DETECT HIGH STEAM LINE-FLOW &amp; THEIR FUNCTION IS COMPLETED. ONE MINUTE WAS CONSERVATIVELY ASSUMED.</p> <p>B. FSAR SECTION 6.2.3.2.</p>	

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 117  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. BECHTEL RADIATION STUDY.	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 118  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>DPIS-3-261-2A</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>278/224</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H0953 SPEC 21A1155AC</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>STEAM LINE HIGH FLOW SENSOR &amp; TRIP SIGNAL</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location: <b>SW CORNER ROOM</b>		
Elevation <b>491'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>DPIS-3-261-2B</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>278/224</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H0953 SPEC 21A1155AC</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>STEAM LINE HIGH FLOW SENSOR &amp; TRIP SIGNAL</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location: <b>SW CORNER ROOM</b>		
Elevation <b>491'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 119  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>DPIS-3-261-2C</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>278/224</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H0953</b> <b>SPEC 21A1155AC</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>STEAM LINE HIGH FLOW SENSOR &amp; TRIP SIGNAL</b>	Aging	
Accuracy: Spec: Demo: Location SW CORNER ROOM	Submergence	NA
Elevation 491'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>DPIS-3-261-2D</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>278/224</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H0953</b> <b>SPEC 21A1155AC</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>STEAM LINE HIGH FLOW SENSOR &amp; TRIP SIGNAL</b>	Aging	
Accuracy: Spec: Demo: Location SW CORNER ROOM	Submergence	NA
Elevation 491'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 120  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION MAIN STEAM
Plant I.D. Number:	DPIS-3-261-2E
Component:	DIFFERENTIAL PRESSURE INDICATING SWITCH
Manufacturer:	BARTON
Model Number:	278/224
Purchase Order Number:	GE HO953 SPEC 21A1155AC
Function/Service:	STEAM LINE HIGH FLOW SENSOR & TRIP SIGNAL
Accuracy:	Spec: Demo:
Location	SW CORNER ROOM
Elevation	491'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION MAIN STEAM
Plant I.D. Number:	DPIS-3-261-2F
Component:	DIFFERENTIAL PRESSURE INDICATING SWITCH
Manufacturer:	BARTON
Model Number:	278/224
Purchase Order Number:	GE HO953 SPEC 21A1155AC
Function/Service:	STEAM LINE HIGH FLOW SENSOR & TRIP SIGNAL
Accuracy:	Spec: Demo:
Location	SW CORNER ROOM
Elevation	491'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	
Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 121  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System: AUTO DEPRESSURIZATION MAIN STEAM	ENVIRONMENT
Operating Time	FSAR
<1 MINUTE	
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 EO4
Aging	
Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	
System: AUTO DEPRESSURIZATION MAIN STEAM	ENVIRONMENT
Operating Time	FSAR
<1 MINUTE	
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 EO4
Aging	
Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 EO4
Aging	
Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 122  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time	<1 MINUTE
Plant I.D. Number: -3-261-21	Temperature (°F)	150
Component: DIFFERENTIAL PRESSURE INDICATING SWITCH	Pressure (PSIA)	14.7
Manufacturer: BARTON	Relative Humidity (%)	100
Model Number: 278/224	Chemical Spray	NA
Purchase Order Number: GE HO953 SPEC 21A115AC	Radiation (Rad)	<1.0 E04
Function/Service: STEAM LINE HIGH FLOW SENSOR & TRIP SIGNAL	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location SW CORNER ROOM		
Elevation 491'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time	<1 MINUTE
Plant I.D. Number: DPIS-3-261-2K	Temperature (°F)	150
Component: DIFFERENTIAL PRESSURE INDICATING SWITCH	Pressure (PSIA)	14.7
Manufacturer: BARTON	Relative Humidity (%)	100
Model Number: 278/224	Chemical Spray	NA
Purchase Order Number: GE HO953 SPEC 21A115AC	Radiation (Rad)	<1.0 E04
Function/Service: STEAM LINE HIGH FLOW SENSOR & TRIP SIGNAL	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location SW CORNER ROOM		
Elevation 491'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 123  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	<1 MINUTE	Temperature (°F)	150
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	<1.0 E04
Aging		Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	<1 MINUTE	Temperature (°F)	150
Pressure (PSIA)	14.7	Relative Humidity (%)	100
Chemical Spray	NA	Radiation (Rad)	<1.0 E04
Aging		Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 124  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION MAIN STEAM
Plant I.D. Number:	DPIS-3-261-2N
Component:	DIFFERENTIAL PRESSURE INDICATING SWITCH
Manufacturer:	BARTON
Model Number:	278/224
Purchase Order Number:	GE HO953 SPEC 21A1155AC
Function/Service:	STEAM LINE HIGH FLOW SENSOR & TRIP SIGNAL
Accuracy:	Spec: Demo:
Location	SW CORNER ROOM
Elevation	491'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION MAIN STEAM
Plant I.D. Number:	DPIS-3-261-2P
Component:	DIFFERENTIAL PRESSURE INDICATING SWITCH
Manufacturer:	BARTON
Model Number:	278/224
Purchase Order Number:	GE HO953 SPEC 21A1155AC
Function/Service:	STEAM LINE HIGH FLOW SENSOR & TRIP SIGNAL
Accuracy:	Spec: Demo:
Location	SW CORNER ROOM
Elevation	491'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 125  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	1 MINUTE
Plant I.D. Number: <b>DPIS-3-261-2R</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>278/224</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO953 SPEC 21A1155AC</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>STEAM LINE HIGH FLOW SENSOR &amp; TRIP SIGNAL</b>	Aging	
Accuracy: Spec: Demo:	Submergence	
Location <b>SW CORNER ROOM</b>		
Elevation <b>491'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>DPIS-3-261-2S</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>278/224</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO953 SPEC 21A1155AC</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>STEAM LINE HIGH FLOW SENSOR &amp; TRIP SIGNAL</b>	Aging	
Accuracy: Spec: Demo:	Submergence	
Location <b>SW CORNER ROOM</b>		
Elevation <b>491'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 126  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time	<1 MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	NORMAL 120 HELB 242		REF. (B)			SEE NOTE (1)
Component: TEMPERATURE SWITCH	Pressure (PSIA)	NORMAL 14.7 HELB 27.0		REF. (B)			SEE NOTE (1)
Manufacturer: UNITED ELECTRIC	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: TYPE F7 MODEL 76B	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE H-1398 CATALOG T-4 REV A	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. THESE SENSORS ARE UTILIZED TO DETECT A MAIN STEAM LINE BREAK IN THE STEAM TUNNEL BY MEASURING INCREASED TEMPERATURE. AS SOON AS A STEAM LINE B. FSAR SECTION 10.11 AND SPECIAL REPORT NO.37 REV. 1 ,FEB 1975. C. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 127  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	1 MINUTE
Plant I.D. Number: <b>TS-2-261-16B</b>	Temperature (°F)	NORMAL 120 LOCA 281
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63
Manufacturer: <b>UNITED ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F7 MODEL 76B</b>	Chemical Spray	
Purchase Order Number: <b>GE H-1398 CATALOG T-4, REV A</b>	Radiation (Rad)	
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	Aging	
Accuracy: Spec: Demo:	Submergence	
Location <b>STEAM TUNNEL</b>		
Elevation <b>537'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>TS-3-261-15A</b>	Temperature (°F)	NORMAL 120 HELB242
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	NORMAL 14.7 HELB27.0
Manufacturer: <b>UNITED ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F7 MODEL 76B</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H-1398 CATALOG T-4, REV A</b>	Radiation (Rad)	<1.0 EO4
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	Aging	
Accuracy: Spec: Demo:	Submergence	
Location <b>STEAM TUNNEL</b>		
Elevation <b>529'6"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 128  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System: AUTO DEPRESSURIZATION MAIN STEAM	ENVIRONMENT
Plant I.D. Number: TS-3-261-15B	Parameter FSAR
Component: TEMPERATURE SWITCH	Operating Time <1 MINUTE
Manufacturer: UNITED ELECTRIC	Temperature (°F) NORMAL 120 HELB242
Model Number: TYPE F7 MODEL 76B	Pressure (PSIA) NORMAL 14.7 HELB27.0
Purchase Order Number: GE H-1398 CATALOG T-4, REV A	Relative Humidity (%) 100
Function/Service: MAIN STEAM LINE LEAK DETECTION	Chemical Spray NA
Accuracy: Spec: Demo:	Radiation (Rad) <1.0 E04
Location STEAM TUNNEL	Aging
Elevation 529'6"	Submergence NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	
System: AUTO DEPRESSURIZATION MAIN STEAM	ENVIRONMENT
Plant I.D. Number: TS-3-261-15C	Parameter FSAR
Component: TEMPERATURE SWITCH	Operating Time <1 MINUTE
Manufacturer: UNITED ELECTRIC	Temperature (°F) NORMAL 120 HELB242
Model Number: TYPE F7 MODEL 76B	Pressure (PSIA) NORMAL 14.7 HELB27.0
Purchase Order Number: GE H-1398 CATALOG T-4, REV A	Relative Humidity (%) 100
Function/Service: MAIN STEAM LINE LEAK DETECTION	Chemical Spray NA
Accuracy: Spec: Demo:	Radiation (Rad) <1.0 E04
Location STEAM TUNNEL	Aging
Elevation 529'6"	Submergence NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 129  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	<1 MINUTE	Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242	Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0	Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 E04	Radiation (Rad)	<1.0 E04
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	<1 MINUTE	Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242	Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0	Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 E04	Radiation (Rad)	<1.0 E04
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 130  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>TS-3-261-16C</b>	Temperature (°F)	NORMAL 120 HELB242
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	NORMAL 14.7 HELB27.0
Manufacturer: <b>UNITED ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F7 MODEL 76B</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H-1398 CATALOG T-4, REV A</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location <b>STEAM TUNNEL</b>		
Elevation <b>537'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>TS-3-261-16D</b>	Temperature (°F)	NORMAL 120 HELB242
Component: <b>TEMPERATURE SWITCH</b>	Pressure (PSIA)	NORMAL 14.7 HELB27.0
Manufacturer: <b>UNITED ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>TYPE F7 MODEL 76B</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H-1398 CATALOG T-4, REV A</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location <b>STEAM TUNNEL</b>		
Elevation <b>537'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 131  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION
MAIN STEAM	
Plant I.D. Number:	TS-3-261-17A
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC
Model Number:	TYPE F7 MODEL 76B
Purchase Order Number:	GE H-1398 CATALOG T-4, REV A
Function/Service:	MAIN STEAM LINE LEAK DETECTION
Accuracy:	Spec: Demo:
Location	STEAM TUNNEL
Elevation	539'6"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 EO4
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION
MAIN STEAM	
Plant I.D. Number:	TS-3-261-17B
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC
Model Number:	TYPE F7 MODEL 76B
Purchase Order Number:	GE H-1398 CATALOG T-4, REV A
Function/Service:	MAIN STEAM LINE LEAK DETECTION
Accuracy:	Spec: Demo:
Location	STEAM TUNNEL
Elevation	539'6"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 EO4
Aging	
Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 132  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	
Plant I.D. Number: <b>TS-3-261-17C</b>	
Component: <b>TEMPERATURE SWITCH</b>	
Manufacturer: <b>UNITED ELECTRIC</b>	
Model Number: <b>TYPE F7 MODEL 76B</b>	
Purchase Order Number: <b>GE H-1398 CATALOG T-4,REV A</b>	
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	
Accuracy: Spec: Demo:	
Location <b>STEAM TUNNEL</b>	
Elevation <b>539' 6"</b>	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	
Plant I.D. Number: <b>TS-3-261-17D</b>	
Component: <b>TEMPERATURE SWITCH</b>	
Manufacturer: <b>UNITED ELECTRIC</b>	
Model Number: <b>TYPE F7 MODEL 76B</b>	
Purchase Order Number: <b>GE H-1398 CATALOG T-4,REV A</b>	
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	
Accuracy: Spec: Demo:	
Location <b>STEAM TUNNEL</b>	
Elevation <b>539' 6"</b>	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	
Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 133  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION
MAIN STEAM	
Plant I.D. Number:	TS-3-261-18A
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC
Model Number:	TYPE F7 MODEL 76B
Purchase Order Number:	GE H-1398 CATALOG T-4, REV A
Function/Service:	MAIN STEAM LINE LEAK DETECTION
Accuracy:	Spec: Demo:
Location	STEAM TUNNEL
Elevation	519'6"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	AUTO DEPRESSURIZATION
MAIN STEAM	
Plant I.D. Number:	TS-3-261-18B
Component:	TEMPERATURE SWITCH
Manufacturer:	UNITED ELECTRIC
Model Number:	TYPE F7 MODEL 76B
Purchase Order Number:	GE H-1398 CATALOG T-4, REV A
Function/Service:	MAIN STEAM LINE LEAK DETECTION
Accuracy:	Spec: Demo:
Location	STEAM TUNNEL
Elevation	519'6"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	<1 MINUTE
Temperature (°F)	NORMAL 120 HELB242
Pressure (PSIA)	NORMAL 14.7 HELB27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	
Submergence	NA

G-085B-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 134  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	ENVIRONMENT
Plant I.D. Number: <b>TS-3-261-18C</b>	Parameter FSAR
Component: <b>TEMPERATURE SWITCH</b>	Operating Time 1 MINUTE
Manufacturer: <b>UNITED ELECTRIC</b>	Temperature (°F) NORMAL 120 HELB242
Model Number: <b>TYPE F7 MODEL 76B</b>	Pressure (PSIA) NORMAL 14.7 HELB27.0
Purchase Order Number: <b>GE H-1398 CATALOG T-4, REV A</b>	Relative Humidity (%) 100
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	Chemical Spray NA
Accuracy: Spec: Demo:	Radiation (Rad) <1.0 EO4
Location <b>STEAM TUNNEL</b>	Aging
Elevation <b>519'6"</b>	Submergence NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	ENVIRONMENT
Plant I.D. Number: <b>TS-3-261-18D</b>	Parameter FSAR
Component: <b>TEMPERATURE SWITCH</b>	Operating Time <1 MINUTE
Manufacturer: <b>UNITED ELECTRIC</b>	Temperature (°F) NORMAL 120 HELB242
Model Number: <b>TYPE F7 MODEL 76B</b>	Pressure (PSIA) NORMAL 14.7 HELB27.0
Purchase Order Number: <b>GE H-1398 CATALOG T-4, REV A</b>	Relative Humidity (%) 100
Function/Service: <b>MAIN STEAM LINE LEAK DETECTION</b>	Chemical Spray NA
Accuracy: Spec: Demo:	Radiation (Rad) <1.0 EO4
Location <b>STEAM TUNNEL</b>	Aging
Elevation <b>519'6"</b>	Submergence NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time	10.5 SEC		REF. (A)			SEE NOTE (1)
Plant I.D. Number: POS-3-203-1&2A-D Component:	Temperature (°F)	NORMAL 150 LOCA 281		REF. (B)			SEE NOTE (1)
Manufacturer:	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0		REF. (B)			SEE NOTE (1)
Model Number:	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Purchase Order Number:	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Radiation (Rad)	5.8 E04		REF. (D)			SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Elevation: SEE ATTACHED SHEETS	Submergence	NA					
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.7.2(D) B. FSAR TABLE 5.2.1 & FSAR FIGURES 5.2.11 & 5.2.12 C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 136  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	10.5 SEC	Operating Time	10.5 SEC
Temperature (°F)	NORMAL PSO LOCA 281	Temperature (°F)	NORMAL 150 LOCA 281
Pressure (PSIA)	NORMAL 14.7 LOCAL 63	Pressure (PSIA)	NORMAL 14.7 LOCAL 63
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	DEMIN WATER	Chemical Spray	DEMIN WATER
Radiation (Rad)	5.8 EO4	Radiation (Rad)	5.8 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:		Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	10.5 SEC	Operating Time	10.5 SEC
Temperature (°F)	NORMAL 150 LOCA 281	Temperature (°F)	NORMAL 150 LOCA 281
Pressure (PSIA)	NORMAL 14.7 LOCAL 63	Pressure (PSIA)	NORMAL 14.7 LOCAL 63
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	DEMIN WATER	Chemical Spray	DEMIN WATER
Radiation (Rad)	5.8 EO4	Radiation (Rad)	5.8 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:		Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 137  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	10.5 SEC
Plant I.D. Number: <b>POS-3-203-1C</b>	Temperature (°F)	NORMAL 150 LOCA 281
Component:	Pressure (PSIA)	NORMAL 14.7 LOCA 63
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	DEMIN WATER
Purchase Order Number:	Radiation (Rad)	5.8 EO4
Function/Service: <b>POSITION INDICATION FOR AO-3-203-1-C</b>	Aging	
Accuracy: Spec: Demo: Location <b>INSIDE DRYWELL NEAR O AZIMUTH</b> Elevation <b>515'6"</b>	Submergence	NA
Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>AUTO DEPRESSURIZATION MAIN STEAM</b>	Operating Time	10.5 SEC
Plant I.D. Number: <b>POS-3-203-1D</b>	Temperature (°F)	NORMAL 150 LOCA 281
Component:	Pressure (PSIA)	NORMAL 14.7 LOCA 63
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	DEMIN WATER
Purchase Order Number:	Radiation (Rad)	5.8 EO4
Function/Service: <b>POSITION INDICATION FOR AO-3-203-1D</b>	Aging	
Accuracy: Spec: Demo: Location <b>INSIDE DRYWELL NEAR O AZIMUTH</b> Elevation <b>515'6"</b>	Submergence	
Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 138  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time		10.5 SEC
Plant I.D. Number: POS-3-203-2A	Temperature (°F)	NORMAL 120 HELB 242	
Component:	Pressure (PSIA)	NORMAL 14.7 HELB 27.0	
Manufacturer:	Relative Humidity (%)	100	
Model Number:	Chemical Spray	NA	
Purchase Order Number:	Radiation (Rad)	<1.0 E04	
Function/Service: POSITION INDICATION FOR AO-3-203-2A	Aging		
Accuracy: Spec: Demo:	Submergence		
Location STEAM TUNNEL NEAR DRYWELL PENETRATION Elevation 515'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM	Operating Time		10.5 SEC
Plant I.D. Number: POS-3-203-2B	Temperature (°F)	NORMAL 150 HELB 242	
Component:	Pressure (PSIA)	NORMAL 14.7 HELB 27.0	
Manufacturer:	Relative Humidity (%)	100	
Model Number:	Chemical Spray	NA	
Purchase Order Number:	Radiation (Rad)	<1.0 E04	
Function/Service: POSITION INDICATION FOR AO-3-203-2B	Aging		
Accuracy: Spec: Demo:	Submergence		
Location STEAM TUNNEL NEAR DRYWELL PENETRATION Elevation 515'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 139  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	10.5 SEC	Operating Time	10.5 SEC
Temperature (°F)	NORMAL 150 HELB 242	Temperature (°F)	NORMAL 150 HELB 242
Pressure (PSIA)	NORMAL 14.7 HELB 27.0	Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 EO4	Radiation (Rad)	<1.0 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: AUTO DEPRESSURIZATION MAIN STEAM		System: AUTO DEPRESSURIZATION MAIN STEAM	
Plant I.D. Number: POS-3-203-2C		Plant I.D. Number: POS-3-203-2D	
Component:		Component:	
Manufacturer:		Manufacturer:	
Model Number:		Model Number:	
Purchase Order Number:		Purchase Order Number:	
Function/Service: POSITION INDICATION FOR AO-3-203-2C		Function/Service: POSITION INDICATION FOR AO-3-203-2D	
Accuracy: Spec: Demo:		Accuracy: Spec: Demo:	
Location STEAM TUNNEL NEAR DRYWELL PENETRATION		Location STEAM TUNNEL NEAR DRYWELL PENETRATION	
Elevation 515'6"		Elevation 515'6"	
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

Component Sheet No: 140  
Revision  
Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: SEE ATTACHED SHEETS	Operating Time						
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)						
Component:	Pressure (PSIA)						
Manufacturer:	Relative Humidity (%)						
Model Number:	Chemical Spray						
Purchase Order Number:	Radiation (Rad)						
Function/Service: SEE ATTACHED SHEETS	Aging						
Accuracy: Spec: Demo:	Submergence						
Location: SEE ATTACHED SHEETS							
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 141  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System:		Operating Time	
Plant I.D. Number:		Temperature (°F)	
Component:		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Location	Demo:	Submergence	
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System:		Operating Time	
Plant I.D. Number:		Temperature (°F)	
Component:		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Location	Demo:	Submergence	
Elevation		Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 142  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:		Operating Time	
Plant I.D. Number:		Temperature (°F)	
Component:		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Location	Demo:	Submergence	
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:		Operating Time	
Plant I.D. Number:		Temperature (°F)	
Component:		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Location	Demo:	Submergence	
Elevation		Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 143  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: LOW PRESSURE COOLANT INJECTION	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: 3-A,B,C,D-1501-44	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
Component: PUMP-MOTOR DRIVEN	Pressure (PSIA)	14.7		NA			
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100		REF. (A)			
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 205H0834	Radiation (Rad)	<1.0 E04		REF. (B)			
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (2)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY	1. GE TEST REPORT 22A4722 AVAILABLE, BECHTEL TO VERIFY DATA 2. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 144  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION		
Plant I.D. Number: 3-A-1501-44	Parameter	FSAR
Component: PUMP-MOTOR DRIVEN	Operating Time	LONG TERM INTERMITTANT
Manufacturer: GENERAL ELECTRIC	Temperature (°F)	150
Model Number:	Pressure (PSIA)	14.7
Purchase Order Number: 205H0834	Relative Humidity (%)	100
Function/Service: PUMP COOLING WATER TO CONTAINMENT COOLERS	Chemical Spray	NA
Accuracy: Spec: NA Demo: NA	Radiation (Rad)	<1.0 E04
Location 5'0"N OF COL D 5'0"E OF COL 49 Elevation 495'0"	Aging	
Flood Level Elevation: NA Above Flood Level: Yes: No:	Submergence	NA

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION		
Plant I.D. Number: 3-B-1501-44	Parameter	FSAR
Component: PUMP-MOTOR DRIVEN	Operating Time	CONTINUOUS
Manufacturer: GENERAL ELECTRIC	Temperature (°F)	150
Model Number:	Pressure (PSIA)	14.7
Purchase Order Number: 205H0834	Relative Humidity (%)	100
Function/Service: PUMP COOLING WATER TO CONTAINMENT COOLERS	Chemical Spray	NA
Accuracy: Spec: NA Demo: NA	Radiation (Rad)	<1.0 E04
Location TURBINE BLDG CRIB HOUSE Elevation 495'0"	Aging	
Flood Level Elevation: Above Flood Level: Yes: No:	Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 145  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION		
<b>Plant I.D. Number:</b> 3-C-1501-44		
<b>Component:</b> PUMP-MOTOR DRIVEN		
<b>Manufacturer:</b> GENERAL ELECTRIC		
<b>Model Number:</b>		
<b>Purchase Order Number:</b> 205H0834		
<b>Function/Service:</b> PUMP COOLING WATER TO CONTAINMENT COOLERS		
<b>Accuracy:</b>	<b>Spec:</b>	NA
	<b>Demo:</b>	NA
<b>Location</b> TURBINE BLDG CRIB HOUSE <b>Elevation</b> 495'0"		
<b>Flood Level</b> Elevation: NA <b>Above Flood Level:</b> Yes: No:		

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 EO4
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION <td data-kind="ghost"></td> <td data-kind="ghost"></td>		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	150	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0 EO4	
Aging		
Submergence	NA	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 146  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: LOW PRESSURE COOLANT INJECTION	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: 3-A,B,C,D-1502	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
Component: PUMP-MOTOR DRIVEN	Pressure (PSIA)	14.7		REF. (A)			
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100		REF. (A)			
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE HO179 SPEC 21A5735	Radiation (Rad)	3.0 E06		REF. (B)			
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (2)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: SEE ATTACHED SHEETS							
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY	<ol style="list-style-type: none"> <li>1. GE TEST REPORT 22A4722 AVAILABLE. BECHTEL TO VERIFY DATA.</li> <li>2. RESOLVE AGING REQUIREMENT AND ESTABLISH QUALIFICATION DATA.</li> </ol>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 147  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION		
Plant I.D. Number: 3-A-1502	Parameter	FSAR
Component: PUMP-MOTOR DRIVEN	Operating Time	CONTINUOUS
Manufacturer: GENERAL ELECTRIC	Temperature (°F)	150
Model Number:	Pressure (PSIA)	14.7
Purchase Order Number: G.E. HO179 SPEC 21A5735	Relative Humidity (%)	100
Function/Service: LOW PRESSURE COOLANT INJECTION TO REACTOR	Chemical Spray	NA
Accuracy: Spec: N/A Demo: N/A	Radiation (Rad)	2.1 E06
Location SE CORNER ROOM	Aging	
Elevation 476'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	150	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	2.1 E06	
Aging		
Submergence	NA	

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION		
Plant I.D. Number: 3-B-1502	Parameter	FSAR
Component: PUMP-MOTOR DRIVEN	Operating Time	
Manufacturer: GENERAL ELECTRIC	Temperature (°F)	150
Model Number:	Pressure (PSIA)	14.7
Purchase Order Number: G.E. HO179 SPEC 21A5735	Relative Humidity (%)	100
Function/Service: LOW PRESSURE COOLANT INJECTION TO REACTOR	Chemical Spray	NA
Accuracy: Spec: N/A Demo: N/A	Radiation (Rad)	2.5 E06
Location SE CORNER ROOM	Aging	
Elevation 476'6"	Submergence	NA
Flood Level Elevation: \$NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 148  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	3-C-1502
Component:	PUMP-MOTOR DRIVEN
Manufacturer:	GENERAL ELECTRIC
Model Number:	
Purchase Order Number:	GE HO179 SPEC 21A5735
Function/Service:	LOW PRESSURE COOLANT INJECTION TO REACTOR
Accuracy:	Spec: N/A Demo: N/A
Location	SW CORNER ROOM
Elevation	476'6"
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	3.0 E06
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	3-D-1502
Component:	PUMP-MOTOR DRIVEN
Manufacturer:	GENERAL ELECTRIC
Model Number:	
Purchase Order Number:	GE HO179 SPEC 21A5735
Function/Service:	LOW PRESSURE COOLANT INJECTION TO REACTOR
Accuracy:	Spec: N/A Demo: N/A
Location	SW CORNER ROOM
Elevation	476'6"
Flood Level	
Elevation:	\$NA
Above Flood Level:	
Yes:	No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 149  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: 3-1501-3A&B Component: <b>MOTOR OPERATED GLOBE VALVE</b> Manufacturer: <b>LIMITORQUE AC MOTORS</b>  Model Number:  Purchase Order Number: 3447-145 SPEC K-2213/K-2202 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS TEST	
	Temperature (°F)	150	250	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Pressure (PSIA)	14.7	39.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Chemical Spray.	NA	NA	NA	NA	NA	
	Radiation (Rad)	4.4 E06	2.0 E07	REF. (C)	REF. (A)	INDIVIDUAL TEST	
	Aging		165 FOR 199.8 HOURS		REF. (A)	INDIVIDUAL TEST	SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO. 600461-B0003 QUALIFICATION TYPE TEST REPORT-LIMITORQUE VALVE ACTIVATORS FOR CLASS 1E SERVICE OUTSIDE PRIMARY CONTAINMENT. B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 150  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	MO-3-1501-3A
Component:	MOTOR OPERATED GLOBE VALVE
Manufacturer:	LIMITORQUE AC MOTORS
Model Number:	
Purchase Order Number:	
3447-145	
SPEC K-2213/K-2202	
Function/Service:	CONTAINMENT COOLING HEAT EXCHANGER
3A-1503 FLOW CONTROL VALVE, SERVICE WATER	
Accuracy:	Spec: N/A Demo: N/A
Location	SE CORNER ROOM
Elevation	490'0"
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	4.4 E06
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	MO-3-1501-3B
Component:	MOTOR OPERATED GLOBE VALVE
Manufacturer:	LIMITORQUE AC MOTORS
Model Number:	
Purchase Order Number:	
3447-145	
SPEC K-2213/K-2202	
Function/Service:	CONTAINMENT COOLING HEAT EXCHANGER
3B-1503 FLOW CONTROL VALVE, SERVICE WATER OUTLET	
Accuracy:	Spec: NA Demo: NA
Location	SW CORNER ROOM
Elevation	490'0"
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	4.4 E06
Aging	
Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 151  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>MO-3-1501-5A,B,C,D</b> Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> AC MOTORS Model Number: <b>SMB-OO-15</b>  Purchase Order Number: <b>3447-141</b> <b>SPEC K-2205</b> Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS	SEE NOTE (1)
	Temperature (°F)	150	307	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	14.7	74.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	4.4 E06		REF. (C)			
	Aging						SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO 338164-FC2485-01 TEST OF LIMITORQUE VALVE OPERATOR AND MOTOR-BRAKE ASSEMBLY BOTH WITH CL B INSULATION UNDER SIMULATED REACTOR CONTAINMENT POST ACCIDENT STEAM AND CHEMICAL ENVIRONMENT. B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. UNIT OPERATED SATISFACTORILY ON FIRST DAY, AFTER 6 DAYS IN A STEAM ENVIRONMENT THE MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS AT 228 F AT 5 PSIG. TEST PROCEDURE CALLED OUT A SATURATED STEAM ENVIRONMENT, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 152  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
	2. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 153  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>LOW PRESSURE COOLANT INJECTION</b>		
<b>Plant I.D. Number:</b> <b>MO-3-1501-5A</b>		
<b>Component:</b> <b>MOTOR OPERATED GATE VALVE</b>		
<b>Manufacturer:</b> <b>LIMITORQUE (PEERLESS) AC MOTORS</b>		
<b>Model Number:</b> <b>SMB-00-15</b>		
<b>Purchase Order Number:</b> <b>3447-141</b> <b>SPEC K-2205</b>		
<b>Function/Service:</b> <b>LPCI PUMP 3-A-1502 SUCTION VALVE</b>		
<b>Accuracy:</b> Spec: N/A Demo: N/A		
<b>Location</b> <b>SE CORNER ROOM</b>		
<b>Elevation</b> <b>480'0"</b>		
<b>Flood Level</b> <b>Elevation: NA</b> <b>Above Flood Level:</b> <b>Yes: No:</b>		

ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	150	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.8 EO6	
Aging		
Submergence	NOT REQD.	

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>LOW PRESSURE COOLANT INJECTION</b>		
<b>Plant I.D. Number:</b> <b>MO-3-1501-5B</b>		
<b>Component:</b> <b>MOTOR OPERATED GATE VALVE</b>		
<b>Manufacturer:</b> <b>LIMITORQUE (PEERLESS) AC MOTORS</b>		
<b>Model Number:</b> <b>SMB-00-15</b>		
<b>Purchase Order Number:</b> <b>3447-141</b> <b>SPEC K-2205</b>		
<b>Function/Service:</b> <b>LPCI PUMP 3-B-1502 SUCTION VALVE</b>		
<b>Accuracy:</b> Spec: N/A Demo: N/A		
<b>Location</b> <b>SE CORNER ROOM</b>		
<b>Elevation</b> <b>480'0"</b>		
<b>Flood Level</b> <b>Elevation: NA</b> <b>Above Flood Level:</b> <b>Yes: No:</b>		

ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	150	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	3.0 EO6	
Aging		
Submergence	NA	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 154  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System: LOW PRESSURE COOLANT INJECTION	
Plant I.D. Number: MO-3-1501-5C	
Component: MOTOR OPERATED GATE VALVE	
Manufacturer: LIMITORQUE (PEERLESS) AC MOTORS	
Model Number: SMB-00-15	
Purchase Order Number: 3447-141 SPEC K-2205	
Function/Service: LPCI PUMP 3-C-1502 SUCTION VALVE	
Accuracy: Spec: NA Demo: NA	
Location SW CORNER ROOM	
Elevation 480'0"	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	4.4 E06
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System: LOW PRESSURE COOLANT INJECTION	
Plant I.D. Number: MO-3-1501-5D	
Component: MOTOR OPERATED GATE VALVE	
Manufacturer: LIMITORQUE (PEERLESS) AC MOTORS	
Model Number: SMB-00-15	
Purchase Order Number: 3447-141 SPEC K-2205	
Function/Service: LPCI PUMP 3-D-1502 SUCTION VALVE	
Accuracy: Spec: N/A Demo: N/A	
Location SW CORNER ROOM	
Elevation 480'0"	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 155  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
<b>System:</b> <b>LOW PRESSURE COOLANT INJECTION</b>  <b>Plant I.D. Number:</b> MO-3-1501-11A,B <b>Component:</b> MOTOR OPERATED GATE VALVE <b>Manufacturer:</b> LIMITORQUE (RELIANCE) AC MOTOR <b>Model Number:</b> SMB-1-40  <b>Purchase Order Number:</b> 3447-141 SPEC K-2205 <b>Function/Service:</b> SEE ATTACHED SHEETS	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS TEST	
	Temperature (°F)	150	250	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Pressure (PSIA)	14.7	39.7	NA	REF. (A)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.1 E06	2.0 E07	REF. (C)	REF. (A)	INDIVIDUAL TEST	
	Aging		165 F FOR 199.8 HOURS		REF. (A)	INDIVIDUAL TEST	SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO 600461-B0003, QUALIFICATION TYPE TEST REPORT - LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. RESOLVE AGING REQUIREMENT

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 156  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION		
<b>Plant I.D. Number:</b> MO-3-1501-11A		
<b>Component:</b> MOTOR OPERATED GATE VALVE		
<b>Manufacturer:</b> LIMITORQUE (RELIANCE) AC MOTOR		
<b>Model Number:</b> SMB-1-40		
<b>Purchase Order Number:</b> 3447-141 SPEC K-2205		
<b>Function/Service:</b> HEAT EXCHANGER 3-A-1503 BYPASS		
<b>Accuracy:</b>	<b>Spec:</b>	N/A
<b>Location</b>	<b>Demo:</b>	N/A
SE CORNER ROOM		
Elevation		
487'0"		
<b>Flood Level</b>		
Elevation: NA		
Above Flood Level:		
Yes: No:		

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	2.1 E06
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION		
<b>System:</b> LOW PRESSURE COOLANT INJECTION		
<b>Plant I.D. Number:</b> MO-3-1501-11B		
<b>Component:</b> MOTOR OPERATED GATE VALVE		
<b>Manufacturer:</b> LIMITORQUE (RELIANCE) AC MOTOR		
<b>Model Number:</b> SMB-1-40		
<b>Purchase Order Number:</b> 3447-141 SPEC K-2205		
<b>Function/Service:</b> HEAT EXCHANGER 3-B-1503 BYPASS		
<b>Accuracy:</b>	<b>Spec:</b>	N/A
<b>Location</b>	<b>Demo:</b>	N/A
SW CORNER ROOM		
Elevation		
487'0"		
<b>Flood Level</b>		
Elevation: NA		
Above Flood Level:		
Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 157  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-1501-13A,B Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> AC MOTOR Model Number: SMB-000-2  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	307	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	27.0	74.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Relative Humidity (%)	100	100	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.9 E07		REF. (C)			SEE NOTE (2)
	Aging						SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO 338164-FC2485-01, TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR BRAKE ASSEMBLY, UNDER SIMULATED REACTOR CONTAINMENT POST-ACCIDENT STEAM AND CHEMICAL ENVIRONMENT B. SPECIAL REPORT NO 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY	1. UNIT OPERATED SATISFACTORILY ON FIRST DAY. AFTER 6 DAYS IN A STEAM ENVIRONMENT THE MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS AT 228 F AT 5 PSIG. TEST PROCEDURE CALLED OUT A SATURATED STEAM ENVIRONMENT, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 158  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
	<p>2. INVESTIGATE EXISTENCE OF QUALIFICATION &amp; DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 159  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>LOW PRESSURE COOLANT INJECTION</b>		
<b>Plant I.D. Number:</b> MO-3-1501-13A		
<b>Component:</b> <b>MOTOR OPERATED GATE VALVE</b>		
<b>Manufacturer:</b> <b>LIMITORQUE (PEERLESS)</b> <b>AC MOTOR</b>		
<b>Model Number:</b> SMB-000-2		
<b>Purchase Order Number:</b> 3447-141 SPEC K-2205		
<b>Function/Service:</b> <b>LPCI MINIMUM FLOW SHUTOFF VALVE, A LINE</b>		
<b>Accuracy:</b> Spec: N/A Demo: N/A		
<b>Location</b> <b>TOP OF TORUS</b>		
<b>Elevation</b> 485'0"		
<b>Flood Level</b> Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	242
Pressure (PSIA)	27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	3.9 E07
Aging	
Submergence	NA

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	242
Pressure (PSIA)	27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	3.9 E07
Aging	
Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 160  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: LOW PRESSURE COOLANT INJECTION	Operating Time	1 MINUTE		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
Plant I.D. Number: MO-3-1501-18A,B	Temperature (°F)	242	307	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
Component: MOTOR OPERATED GLOBE VALVE	Pressure (PSIA)	27.0	74.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
Manufacturer: LIMITORQUE (PEERLESS) AC MOTOR	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
Model Number: SMB-00-10	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.3 E05		REF. (D)			SEE NOTE (2)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (2)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: SEE ATTACHED SHEETS							
Elevation: SEE ATTACHED SHEETS							
Flood Level: Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 8.2.5 B. REPORT NO 338164-FC2485-01, TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR BRAKE ASSEMBLY, UNDER SIMULATED REACTOR CONTAINMENT POST-ACCIDENT STEAM AND CHEMICAL ENVIRONMENT C. SPECIAL REPORT NO 37, REV 1, FEB 1975 D. BECHTEL RADIATION STUDY	1. UNIT OPERATED SATISFACTORILY ON FIRST DAY; AFTER 6 DAYS IN A STEAM ENVIRONMENT THE MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS AT 228 F AT 5 PSIG. TEST PROCEDURE CALLED OUT A SATURATED STEAM ENVIRONMENT, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 161  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
	2. INVESTIGATE EXISTENCE OF QUALIFICATIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 162  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	
Temperature (°F)	242	
Pressure (PSIA)	27.0	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	3.3 E05	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	
Temperature (°F)	242	
Pressure (PSIA)	27.0	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	3.3 E05	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 163  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-1501-19A,B Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> AC MOTOR Model Number: SMB-000-5  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	1 MINUTE		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	307	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Pressure (PSIA)	27.0	74.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.3 E05		REF. (D)			SEE NOTE (2)
	Aging						SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: Yes No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 8.2.5 B. REPORT NO 338164-FC2485-01, TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR BRAKE ASSEMBLY, UNDER SIMULATED REACTOR CONTAINMENT POST-ACCIDENT STEAM AND CHEMICAL ENVIRONMENT C. SPECIAL REPORT NO 37, REV 1, FEB 1975 D. BECHTEL RADIATION STUDY	1. UNIT OPERATED SATISFACTORILY ON FIRST DAY, AFTER 6 DAYS IN A STEAM ENVIRONMENT THE MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS AT 228 F AT 5 PSIG. TEST PROCEDURE CALLED OUT A SATURATED STEAM ENVIRONMENT, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 164  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
	2. INVESTIGATE EXISTENCE OF QUALIFICATION\$ WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 165  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	LOW PRESSURE COOLANT INJECTION		Operating Time	1 MINUTE
Plant I.D. Number:	MO-3-1501-19A		Temperature (°F)	242
Component:	MOTOR OPERATED GATE VALVE		Pressure (PSIA)	27.0
Manufacturer:	LIMITORQUE (PEERLESS) AC MOTOR		Relative Humidity (%)	100
Model Number:	SMB-000-5		Chemical Spray	NA
Purchase Order Number:	3447-141		Radiation (Rad)	3.3 E05
	SPEC K-2205		Aging	
Function/Service:	LPCI A TEST LINE SHUT OFF VALVE		Submergence	NA
Accuracy:	Spec: N/A	Demo: N/A		
Location	TOP OF TORUS NEAR PEN X-311A			
Elevation	513'9"			
Flood Level	Elevation: NA			
	Above Flood Level:			
	Yes: No:			

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	LOW PRESSURE COOLANT INJECTION		Operating Time	1 MINUTE
Plant I.D. Number:	MO-3-1501-19B		Temperature (°F)	242
Component:	MOTOR OPERATED GATE VALVE		Pressure (PSIA)	27.0
Manufacturer:	LIMITORQUE (PEERLESS) AC MOTOR		Relative Humidity (%)	100
Model Number:	SMB-000-5		Chemical Spray	NA
Purchase Order Number:	3447-141		Radiation (Rad)	3.3 E05
	SPEC K-2205		Aging	
Function/Service:	LPCI B TEST LINE SHUTOFF VALVE		Submergence	NA
Accuracy:	Spec: N/A	Demo: N/A		
Location	TOP OF TORUS NEAR SW CORNER ROOM			
Elevation	513'9"			
Flood Level	Elevation: NA			
	Above Flood Level:			
	Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 166  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-1501-21A,B Component: <b>MOTOR OPERATED STOP CHECK VALVE</b> Manufacturer: <b>LIMITORQUE (RELIANCE)</b> AC MOTOR Model Number: <b>#CONTINUOUS</b>  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	1 MINUTE		NA		SIMULTANEOUS TEST	
	Temperature (°F)	242	250	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	27.0	39.7	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.9 E07	2.0 E07	REF. (C)			SEE NOTE (1)
	Aging		165 F FOR 199.8 HOURS				SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975 B. REPORT NO 600461-B0003, QUALIFICATION TYPE TEST REPORT - LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF ADDITIONAL\$ QUALIFICATION DATA WITH MANUFACTURER. 2. RESOLVE AGING REQUIREMENT.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 166  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System:  LOW PRESSURE COOLANT INJECTION  Plant I.D. Number: MO-3-1501-21A,B Component: MOTOR OPERATED STOP CHECK VALVE Manufacturer: LIMITORQUE (RELIANCE) AC MOTOR Model Number: #CONTINUOUS  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: SEE ATTACHED SHEETS	Operating Time	1 MINUTE		NA		SIMULTANEOUS TEST	
	Temperature (°F)	242	250	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	27.0	39.7	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.9 E07	2.0 E07	REF. (C)			SEE NOTE (1)
	Aging		165° F FOR 199.8 HOURS				SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975 B. REPORT NO 600461-B0003, QUALIFICATION TYPE TEST REPORT - LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF ADDITIONAL\$ QUALIFICATION DATA WITH MANUFACTURER. 2. RESOLVE AGING REQUIREMENT.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 167  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT		EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR		Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS	System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: MO-3-1501-21A	Temperature (°F)	242	Plant I.D. Number: MO-3-1501-21B	Temperature (°F)	242
Component: <b>MOTOR OPERATED STOP CHECK VALVE</b>	Pressure (PSIA)	27.0	Component: <b>MOTOR OPERATED STOP CHECK VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>LIMITORQUE (RELIANCE) AC MOTOR</b>	Relative Humidity (%)	100	Manufacturer: <b>LIMITORQUE (RELIANCE) AC MOTOR</b>	Relative Humidity (%)	100
Model Number: <b>#CONTINUOUS</b>	Chemical Spray	NA	Model Number: <b>#CONTINUOUS</b>	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.9 E07	Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.9 E07
Function/Service: <b>LPCI INJECTION TO REACTOR, SHUTOFF VALVE, A LINE</b>	Aging		Function/Service: <b>LPCI INJECTION TO REACTOR, SHUTOFF VALVE, B LINE</b>	Aging	
Accuracy: Spec: N/A Demo: N/A	Submergence	NA	Accuracy: Spec: N/A Demo: N/A	Submergence	NA
Location <b>EXTENDS ABOVE FLOOR SLAB NEAR PEN X-116A</b> Elevation 518'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:		Location <b>EXTENDS ABOVE FLOOR SLAB NEAR PEN X-116B</b> Elevation 518'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 168  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-1501-22A,B Component: MOTOR OPERATED GATE VALVE Manufacturer: LIMITORQUE (PEERLESS) AC MOTOR Model Number:  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	1 MINUTE		NA	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	307	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (2)
	Pressure (PSIA)	27.0	74.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (2)
	Relative Humidity (%)	100	100	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.9 E07		REF. (C)			
	Aging						SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO 338164-FC2485-01, TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR BRAKE ASSEMBLY, UNDER SIMULATED REACTOR CONTAINMENT POST-ACCIDENT STEAM AND CHEMICAL ENVIRONMENT B. SPECIAL REPORT NO 37.REV 1, FEB 1975 C. BECHTEL RADIATION STUDY	1. UNIT OPERATED SATISFACTORILY ON FIRST DAY, AFTER 6 DAYS IN A STEAM ENVIRONMENT THE MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS AT 228 F AT 5 PSIG. TEST PROCEDURE CALLED OUT A SATURATED STEAM ENVIRONMENT, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 169  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
	2. RESOLVE AGING REQUIREMENT.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 170  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	1 MINUTE
Plant I.D. Number: <b>MO-3-1501-22A</b>	Temperature (°F)	242
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>LIMITORQUE (PEERLESS) AC MOTOR</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>3447-141</b> <b>SPEC K-2205</b>	Radiation (Rad)	3.9 E07
Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE A</b> <b>LINE INJECTION TO REACTOR</b>	Aging	
Accuracy: Spec: N/A Demo: N/A	Submergence	NA
Location <b>TOP OF TORUS</b> <b>NEAR PEN X-116A</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	1 MINUTE
Plant I.D. Number: <b>MO-3-1501-22B</b>	Temperature (°F)	242
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>LIMITORQUE (PEERLESS) AC MOTOR</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>3447-141</b> <b>SPEC K-2205</b>	Radiation (Rad)	3.9 E07
Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE B</b> <b>LINE INJECTION TO REACTOR</b>	Aging	
Accuracy: Spec: N/A Demo: N/A	Submergence	NA
Location <b>TOP OF TORUS</b> <b>NEAR PEN X-116B</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 171  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: MO-3-1501-27A,B Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> AC MOTOR Model Number: SMB-0-15  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS	NOT REQD	NA	NOT REQD		
	Temperature (°F)	103	NOT REQD	REF. (A)	NOT REQD		
	Pressure (PSIA)	14.7	NOT REQD	REF. (A)	NOT REQD		
	Relative Humidity (%)	100	NOT REQD	REF. (A)	NOT REQD		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION\$ DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 172  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
<b>System:</b> <b>LOW PRESSURE COOLANT INJECTION</b>	
Plant I.D. Number: MO-3-1501-27A	Parameter
Component: MOTOR OPERATED GATE VALVE	Operating Time
Manufacturer: LIMITORQUE (PEERLESS) AC MOTOR	Temperature (°F)
Model Number: SMB-0-15	Pressure (PSIA)
Purchase Order Number: 3447-141 SPEC K-2205	Relative Humidity (%)
Function/Service: CONTAINMENT SPRAY A LINE, FIRST OUTBOARD ISOLATION VALVE	Chemical Spray
Accuracy: Spec: N/A Demo: N/A	Radiation (Rad)
Location OUTSIDE DRYWELL NEAR PEN X-150A Elevation 527'0"	Aging
Flood Level Elevation: NA Above Flood Level: Yes: No:	Submergence

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	103
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	1.6 E06
Aging	NOT REQD.
Submergence	NA

EQUIPMENT DESCRIPTION	
<b>System:</b> <b>LOW PRESSURE COOLANT INJECTION</b>	
Plant I.D. Number: MO-3-1501-27B	Parameter
Component: MOTOR OPERATED GATE VALVE	Operating Time
Manufacturer: LIMITORQUE (PEERLESS) AC MOTOR	Temperature (°F)
Model Number: SMB-0-15	Pressure (PSIA)
Purchase Order Number: 3447-141 SPEC K-2205	Relative Humidity (%)
Function/Service: CONTAINMENT SPRAY B LINE, FIRST OUTBOARD ISOLATION VALVE	Chemical Spray
Accuracy: Spec: N/A Demo: N/A	Radiation (Rad)
Location OUTSIDE DRYWELL NEAR PEN X-145 Elevation 548'0"	Aging
Flood Level Elevation: NA Above Flood Level: Yes: No:	Submergence

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 173  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: LOW PRESSURE COOLANT INJECTION	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
Plant I.D. Number: MO-3-1501-28A,B	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
Component: MOTOR OPERATED GATE VALVE	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
Manufacturer: LIMITORQUE (PEERLESS) DC MOTOR	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
Model Number: SMB-O-15	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	1.3 E06		REF. (B)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: SEE ATTACHED SHEETS							
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: .Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATIONS DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 174  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
		ENVIRONMENT
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Parameter	FSAR
Plant I.D. Number: MO-3-1501-28A	Operating Time	CONTINUOUS
Component: <b>MOTOR OPERATED GATE VALVE</b>	Temperature (°F)	103
Manufacturer: <b>LIMITORQUE (PEERLESS) DC MOTOR</b>	Pressure (PSIA)	14.7
Model Number: SMB-O-15	Relative Humidity (%)	100
Purchase Order Number: 3447-141 SPEC K-2205	Chemical Spray	NA
Function/Service: <b>CONTAINMENT SPRAY A LINE, SECOND OUTBOARD ISOLATION VALVE</b>	Radiation (Rad)	1.3 E06
Accuracy: Spec: N/A Demo: N/A	Aging	NOT REQD.
Location <b>OUTSIDE DRYWELL NEAR PEN X-150A</b> Elevation 527'0"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	103	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.3 E06	
Aging	NOT REQD.	
Submergence	NA	

EQUIPMENT DESCRIPTION		
		ENVIRONMENT
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Parameter	FSAR
Plant I.D. Number: MO-3-1501-28B	Operating Time	CONTINUOUS
Component: <b>MOTOR OPERATED GATE VALVE</b>	Temperature (°F)	103
Manufacturer: <b>LIMITORQUE (PEERLESS) DC MOTOR</b>	Pressure (PSIA)	14.7
Model Number: SMB-O-15	Relative Humidity (%)	100
Purchase Order Number: 3447-141 SPEC K-2205	Chemical Spray	NA
Function/Service: <b>CONTAINMENT SPRAY B LINE, SECOND OUTBOARD ISOLATION VALVE</b>	Radiation (Rad)	1.3 E06
Accuracy: Spec: N/A Demo: N/A	Aging	NOT REQD.
Location <b>OUTSIDE DRYWELL NEAR PEN X-145</b> Elevation 548'0"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 175  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>MO-3-1501-32A&amp;B</b> Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE(RELIANCE A</b>	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	150	250	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Pressure (PSIA)	14.7	39.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.3 E06	2.0 E07	REF. (C)	REF. (A)	INDIVIDUAL TEST	
	Aging		165 F FOR 199.8 HOURS		REF. (A)	INDIVIDUAL TEST	SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO. 600461-B0003 QUALIFICATION TYPE TEST REPORT-LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. DETERMINE TEST TIME. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 176  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	
Temperature (°F)	150	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	2.3 E06	
Aging		
Submergence		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	
Temperature (°F)	150	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	2.3 E06	
Aging		
Submergence		
Flood Level Elevation: \$NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 177  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS#	SEE NOTE (1)
Plant I.D. Number: <b>POT-2-1501-3A&amp;B</b>	Temperature (°F)	150	250	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
Component: <b>POSITION TRANSMITTER</b>	Pressure (PSIA)	14.7	39.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
Manufacturer: <b>LIMITORQUE</b>	Relative Humidity (%)	100	100	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
Model Number: <b>INTEGRAL WITH OPERATOR</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	4.4 E06		REF. (C)	REF. (A)	INDIVIDUAL TEST	SEE NOTE (2)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging		165 F FOR 199.8 HOURS		REF. (A)	INDIVIDUAL TEST	SEE NOTE (3)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO. 600461-B0003 QUALIFICATION TYPE TEST REPORT-LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. RESOLVE QUALIFICATION TEST TIME. 2. INVESTIGATE EXISTENCE OF QUALIFICATIONS DATA WITH MANUFACTURER. 3. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 178  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>POT-3-1501-3A</b>	Temperature (°F)	150
Component: <b>POSITION TRANSMITTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>LIMITORQUE</b>	Relative Humidity (%)	100
Model Number: <b>INTEGRAL WITH OPERATOR</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	4.4 EO6
Function/Service: <b>POSITION INDICATION &amp; CONTROL FOR VALVE MO-3-1501-3A</b>	Aging	
Accuracy: Spec: Demo:	Submergence	
Location <b>SE CORNER ROOM</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>POT-3-1501-3B</b>	Temperature (°F)	150
Component: <b>POSITION TRANSMITTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>LIMITORQUE</b>	Relative Humidity (%)	100
Model Number: <b>INTEGRAL WITH OPERATOR</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	4.4 EO6
Function/Service: <b>POSITION INDICATION &amp; CONTROL FOR VALVE MO-3-1501-3B</b>	Aging	
Accuracy: Spec: Demo:	Submergence	
Location <b>SW CORNER ROOM</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 179  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: <b>FT-3-1542A&amp;B</b>	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
Component: <b>FLOW TRANSMITTER</b>	Pressure (PSIA)	14.7		NA	REF. (A)		SEE NOTE (1)
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100		NA	REF. (A)		SEE NOTE (1)
Model Number: <b>4532K-13001</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>GE HO950</b>	Radiation (Rad)	2.5 E06		REF. (B)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging			REF. (C)			SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH THE MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 180  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: LOW PRESSURE COOLANT INJECTION		Operating Time	CONTINUOUS
Plant I.D. Number: FT-3-1542A		Temperature (°F)	150
Component: FLOW TRANSMITTER		Pressure (PSIA)	14.7
Manufacturer: GENERAL ELECTRIC		Relative Humidity (%)	100
Model Number: 4532K-13001		Chemical Spray	NA -
Purchase Order Number: G.E. HO950		Radiation (Rad)	2.5 E06
Function/Service: FLOW INDICATION FOR CONTAINMENT COOLING SERVICE WATER A LINE		Aging	
Accuracy: Spec: Demo:		Submergence	NA
Location RACK 2202-19A SE CORNER ROOM Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: LOW PRESSURE COOLANT INJECTION		Operating Time	CONTINUOUS
Plant I.D. Number: FT-3-1542B		Temperature (°F)	150
Component: FLOW TRANSMITTER		Pressure (PSIA)	14.7
Manufacturer: GENERAL ELECTRIC		Relative Humidity (%)	100
Model Number: 4532K-13001		Chemical Spray	NA
Purchase Order Number: G.E. HO950		Radiation (Rad)	2.5 E06
Function/Service: FLOW INDICATION FOR CONTAINMENT COOLING SERVICE WATER B LINE		Aging	
Accuracy: Spec: Demo:		Submergence	NA
Location RACK 2202-19B SW CORNER ROOM Elevation		Flood Level Elevation: \$NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 181  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: <b>DPT-3-1543A&amp;B</b> Component: <b>DIFFERENTIAL PRESSURE TRANSMITTER</b> Manufacturer: <b>BARTON</b>  Model Number: <b>368</b>  Purchase Order Number: <b>GE H0950</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7		NA	REF. (A)		SEE NOTE (1)
	Relative Humidity (%)	100		NA	REF. (A)		SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.5 E06		REF. (B)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH THE MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 182  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>DPT-3-1543A</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE TRANSMITTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>368</b>	Chemical Spray	NA
Purchase Order Number: <b>G.E. H0950</b>	Radiation (Rad)	2.5 E06
Function/Service: <b>OPENS&amp;CLOSES VALVE MO-3-1501-3A ON DIFFERENTIAL PRESSURE</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2202-19A SE CORNER ROOM Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>DPT-3-1543B</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE TRANSMITTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number: <b>368</b>	Chemical Spray	NA
Purchase Order Number: <b>G.E. H0950</b>	Radiation (Rad)	2.5 E06
Function/Service: <b>OPENS &amp; CLOSES VALVE MO-3-1501-3B ON DIFFERENTIAL PRESSURE</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2202-19B SW CORNER ROOM Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 183  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: <b>FT-3-1549A&amp;B</b>	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
Component: <b>FLOW TRANSMITTER</b>	Pressure (PSIA)	14.7		NA	REF. (A)		SEE NOTE (1)
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100		NA	REF. (A)		SEE NOTE (1)
Model Number: <b>4532K-13001</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>GE H1227</b>	Radiation (Rad)	2.5 E06		REF. (B)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.					SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH THE MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 184  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	150	Temperature (°F)	150
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.5 EO6	Radiation (Rad)	2.5 EO6
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>		System: <b>LOW PRESSURE COOLANT INJECTION</b>	
Plant I.D. Number: <b>FT-3-1549A</b>		Plant I.D. Number: <b>FT-3-1549B</b>	
Component: <b>FLOW TRANSMITTER</b>		Component: <b>FLOW TRANSMITTER</b>	
Manufacturer: <b>GENERAL ELECTRIC</b>		Manufacturer: <b>GENERAL ELECTRIC</b>	
Model Number: <b>4532K-13001</b>		Model Number: <b>4532K-13001</b>	
Purchase Order Number: <b>G.E. H1227</b>		Purchase Order Number: <b>G.E. H1227</b>	
Function/Service: <b>OUTPUT TO FLOW RECORDER IN CONTROL ROOM</b>		Function/Service: <b>OUTPUT TO FLOW RECORDER IN CONTROL ROOM</b>	
Accuracy: Spec: Demo:		Accuracy: Spec: Demo:	
Location <b>RACK 2202-19A SE CORNER ROOM</b>		Location <b>RACK 2202-19B SW CORNER ROOM</b>	
Elevation		Elevation	
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 185  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: FT-3-1551A&B Component: <b>FLOW TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: 4532K-13001  Purchase Order Number: GE HO950  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	REF. (A)	NA	NA	
	Radiation (Rad)	2.5 E06		REF. (B)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 186  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	150	Temperature (°F)	150
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.5 E06	Radiation (Rad)	2.5 E06
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: LOW PRESSURE COOLANT INJECTION		System: LOW PRESSURE COOLANT INJECTION	
Plant I.D. Number: FT-3-1551A		Plant I.D. Number: FT-3-1551B	
Component: FLOW TRANSMITTER		Component: FLOW TRANSMITTER	
Manufacturer: GENERAL ELECTRIC		Manufacturer: GENERAL ELECTRIC	
Model Number: 4532K-13001		Model Number: 4532K-13001	
Purchase Order Number: G.E. HO950		Purchase Order Number: G.E. HO950	
Function/Service: INDICATION OF SYSTEM FLOW(A LOOP) TO REACTOR IN CONTROL ROOM		Function/Service: INDICATION OF SYSTEM FLOW (B LOOP) TO REACTOR IN CONTROL ROOM	
Accuracy: Spec: Demo:		Accuracy: Spec: Demo:	
Location RACK 2202-19A SE CORNER ROOM		Location RACK 2202-19B SW CORNER ROOM	
Elevation		Elevation	
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 187  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: LOW PRESSURE COOLANT INJECTION	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
Component: PRESSURE SWITCH	Pressure (PSIA)	14.7		REF. (A)			SEE NOTE (1)
Manufacturer: STATIC-O-RING	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
Model Number: CAT 5N-AA3	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	2.5 E06		REF. (B)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 188  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	PS-3-1554A
Component:	PRESSURE SWITCH
Manufacturer:	STATIC-O-RING
Model Number:	CAT 5N-AA3
Purchase Order Number:	
Function/Service:	LPCI PUMP 3-A-1502
SWITCH	
Accuracy:	Spec: Demo:
Location	RACK 2202-19A SE CORNER ROOM
Elevation	
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	150
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	2.5 E06
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	PS-3-1554B
Component:	PRESSURE SWITCH
Manufacturer:	STATIC-O-RING
Model Number:	CAT 5N-AA3
Purchase Order Number:	
Function/Service:	LPCI PUMP 3-5-1502
SWITCH	
Accuracy:	Spec: Demo:
Location	RACK 2202-19A SE CORNER ROOM
Elevation	
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 189  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS		
Temperature (°F)	150		
Pressure (PSIA)	14.7		
Relative Humidity (%)	100		
Chemical Spray	NA		
Radiation (Rad)	2.5 E06		
Aging			
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS		
Temperature (°F)	150		
Pressure (PSIA)	14.7		
Relative Humidity (%)	100		
Chemical Spray	NA		
Radiation (Rad)	2.5 E06		
Aging			
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 190  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-1554E</b>	Temperature (°F)	150
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>CAT 5N-AA3</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	2.5 E06
Function/Service: <b>LPCI PUMP 3-A-1502</b>	Aging	
SWITCH	Submergence	NA
Accuracy: Spec: Demo: Location RACK 2202-19A SE CORNER ROOM Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-1554F</b>	Temperature (°F)	150
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>CAT 5N-AA3</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	2.5 E06
Function/Service: <b>LPCI PUMP 3-B-1502</b>	Aging	
SWITCH	Submergence	NA
Accuracy: Spec: Demo: Location RACK 2202-19A SE CORNER ROOM Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 191  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: PS-3-1554J Component: <b>PRESSURE SWITCH</b>  Manufacturer: <b>STATIC-O-RING</b>  Model Number: <b>CAT 5N-AA3</b>  Purchase Order Number:  Function/Service: <b>LPCI PUMP 3-D-1502</b>  <b>SWITCH</b>  Accuracy: Spec: Demo: Location RACK 2202-19B SW CORNER ROOM Elevation	Operating Time	CONTINUOUS
	Temperature (°F)	150
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	
	Aging	
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>  Plant I.D. Number: PS-3-1554H Component: <b>PRESSURE SWITCH</b>  Manufacturer: <b>STATIC-O-RING</b>  Model Number: <b>CAT 5N-AA3</b>  Purchase Order Number:  Function/Service: <b>LPCI PUMP 3-C-1502</b>  <b>SWITCH</b>  Accuracy: Spec: Demo: Location RACK 2202-19B SW CORNER ROOM Elevation	Operating Time	CONTINUOUS
	Temperature (°F)	150
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	2.5 E06
	Aging	
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 192  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
Plant I.D. Number: MO-3-1501-20A,B	Temperature (°F)	242	250	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	27.0	39.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	
Manufacturer: <b>LIMITORQUE (RELIANCE) AC MOTOR</b>	Relative Humidity (%)	100	100	NA	REF. (A)	SIMULTANEOUS TEST	
Model Number: SMB-2-80	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	3.9 E07	2.0 E07	REF. (C)		INDIVIDUAL TEST	SEE NOTE (2)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging		165 F FOR 199.8 HOURS			INDIVIDUAL TEST	SEE NOTE (3)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. REPORT NO. 600461-B0003-QUALIFICATION TYPE TEST REPORT-LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. B. SPECIAL REPORT NO. 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY	1. RESOLVE QUALIFICATION TEST TIME. 2. INVESTIGATE EXISTENCE OF ADDITIONAL\$ QUALIFICATION DATA WITH MANUFACTURER. 3. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3.  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 193  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	242	Temperature (°F)	242
Pressure (PSIA)	27.0	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.9 E07	Radiation (Rad)	3.9 E07
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>		System: <b>LOW PRESSURE COOLANT INJECTION</b>	
Plant I.D. Number: MO-3-1501-20A		Plant I.D. Number: MO-3-1501-20B	
Component: <b>MOTOR OPERATED GATE VALVE</b>		Component: <b>MOTOR OPERATED GATE VALVE</b>	
Manufacturer: <b>LIMITORQUE (RELIANCE)</b>		Manufacturer: <b>LIMITORQUE (RELIANCE)</b>	
AC MOTOR		AC MOTOR	
Model Number: SMB-2-80		Model Number: SMB-2-80	
Purchase Order Number: 3447-141		Purchase Order Number: 3447-141	
SPEC K-2205		SPEC K-2205	
Function/Service: <b>FIRST OUTBOARD CONTAINMENT ISOLATION VALVE FOR TORUS PENETRATION X-310A</b>		Function/Service: <b>FIRST OUTBOARD CONTAINMENT ISOLATION VALVE FOR TORUS PENETRATION X-310A</b>	
Accuracy: Spec: NA Demo: NA		Accuracy: Spec: NA Demo: NA	
Location <b>TOP OF TORUS NEAR PEN X-310A</b>		Location <b>TOP OF TORUS NEAR PEN X-310B</b>	
Elevation 509'0"		Elevation 509'0"	
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0859-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 194  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS		NA	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
Plant I.D. Number: <b>MO-3-1501-38A&amp;B</b>	Temperature (°F)	242	307	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (2)
Component: <b>MOTOR OPERATED GLOBE VALVE</b>	Pressure (PSIA)	27.0	74.7	REF. (B)	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (2)
Manufacturer: <b>LIMITORQUE (PEERLESS) AC MOTOR</b>	Relative Humidity (%)	100	100	NA	REF. (A)	SIMULTANEOUS TEST	SEE NOTE (1)
Model Number: <b>SMB-3</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
<p>A. REPORT NO. 338164-FC2485-01 TESTS LIMITORQUE VALVE OPERATOR AND MOTOR-BRAKE ASSEMBLY, BOTH WITH CLASS B INSULATION, UNDER SIMULATED REACTOR CONTAINMENT POST ACCIDENT STEAM AND CHEMICAL ENVIRONMENT.</p> <p>B. FSAR SECTION 6.2.3.2 AND SPECIAL REPORT NO. 37, REV 1, FEB 1975</p>	<p>1. TEST CALLED OUT SATURATED STEAM BUT HUMIDITY WAS NOT MEASURED. FIRST DAY OF TEST, UNIT OPERATED SATISFACTORILY. AFTER SIX DAYS IN STEAM ENVIRONMENT, MOTOR OR BRAKE DID NOT FUNCTION. CHAMBER WAS AT 228°F AT 5PSIG. ESTABLISH FURTHER DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 195  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. BECHTEL RADIATION STUDY	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 196  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	MO-3-1501-38A
Component:	MOTOR OPERATED GLOBE VALVE
Manufacturer:	LIMITORQUE (PEERLESS) AC MOTOR
Model Number:	SMB-3
Purchase Order Number:	3447-141 SPEC K-2205
Function/Service:	SECOND OUTBOARD CONTAINMENT ISOLATION VALVE FOR TORUS PENETRATION X-310A
Accuracy:	Spec: NA Demo: NA
Location	TOP OF TORUS NEAR PEN X-116A
Elevation	513'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	242
Pressure (PSIA)	27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	3.9 E07
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	LOW PRESSURE COOLANT INJECTION
Plant I.D. Number:	MO-3-1501-38B
Component:	MOTOR OPERATED GLOBE VALVE
Manufacturer:	LIMITORQUE (PEERLESS) AC MOTOR
Model Number:	SMB-3
Purchase Order Number:	3447-141 SPEC K-2205
Function/Service:	SECOND OUTBOARD CONTAINMENT ISOLATION VALVE FOR TORUS PENETRATION X-310B
Accuracy:	Spec: NA Demo: NA
Location	TOP OF TORUS NEAR PEN X-116B
Elevation	513'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	PARAMETER	FSAR	Qualification	FSAR	Qual.		
System: LOW PRESSURE COOLANT INJECTION	Operating Time	CONTINUOUS					SEE NOTE (1)
Plant I.D. Number: FS-3-1501-58A,B	Temperature (°F)						SEE NOTE (1)
Component: FLOW SWITCH	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)	SEE NOTE (1)					SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence						SEE NOTE (1)
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 198  
 Revision  
 Date: - -

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>FS-3-1501-58A</b>	Temperature (°F)	
Component: <b>FLOW SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>MONITOR PUMP FLOW</b>	Aging	
Accuracy: Spec: Demo: Location	Submergence	
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>LOW PRESSURE COOLANT INJECTION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>FS-3-1501-58B</b>	Temperature (°F)	
Component: <b>FLOW SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>MONITOR PUMP FLOW</b>	Aging	
Accuracy: Spec: Demo: Location	Submergence	
Elevation	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 199  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: <b>SEE ATTACHED SHEETS</b> Component: <b>POSITION SWITCH</b>  Manufacturer: <b>NAMCO</b> <b>SNAP-LOCK</b> Model Number: <b>MARK II-D1200G</b>  Purchase Order Number:	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.1 E05		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (2)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE B.2.5 B. SPECIAL REPORT NO. 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER. 2. RESOLVE AGING REQUIREMENTS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 200  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1 MINUTE
Plant I.D. Number: <b>POS-3-1601-20A</b>	Temperature (°F)	242
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	27.0
Manufacturer: <b>NAMCO</b> <b>SNAP-LOCK</b>	Relative Humidity (%)	100
Model Number: <b>MARK II-D1200G</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	1.1 E05
Function/Service: <b>POSITION INDICATION FOR VALVE</b> <b>A0-3-1601-20A</b>	Aging	
Accuracy: Spec: Demo: Location <b>TOP OF TORUS</b>	Submergence	NA
Elevation <b>513'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>POS-3-1601-20B</b>	Temperature (°F)	242
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	27.0
Manufacturer: <b>NAMCO</b> <b>SNAP-LOCK</b>	Relative Humidity (%)	100
Model Number: <b>MARK II-D1200G</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	1.1 E05
Function/Service: <b>POSITION INDICATION FOR VALVE</b> <b>A0-3-1601-20B</b>	Aging	
Accuracy: Spec: Demo: Location <b>TOP OF TORUS</b>	Submergence	NA
Elevation <b>513'0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 201  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System:	Operating Time	1MINUTE	
PRESSURE SUPPRESSION	Temperature (°F)	242	
Plant I.D. Number: POS-3-1601-21	Pressure (PSIA)	27.0	
Component: POSITION SWITCH	Relative Humidity (%)	100	
Manufacturer: NAMCO SNAP-LOCK	Chemical Spray	NA	
Model Number: MARK II-D1200G	Radiation (Rad)	1.1 E05	
Purchase Order Number: 3447-167 SPEC K-2256	Aging		
Function/Service: POSITION INDICATION FOR VALVE AO-3-1601-21	Submergence	NA	
Accuracy: Spec: Demo: Location TOP OF TORUS	Flood Level Elevation: NA Above Flood Level: Yes: No:		
Elevation 513'0"			
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System:	Operating Time	1 MINUTE	
PRESSURE SUPPRESSION	Temperature (°F)	242	
Plant I.D. Number: POS-3-1601-22	Pressure (PSIA)	27.0	
Component: POSITION SWITCH	Relative Humidity (%)	100	
Manufacturer: NAMCO SNAP-LOCK	Chemical Spray	NA	
Model Number: MARK II-D1200G	Radiation (Rad)	1.1 E05	
Purchase Order Number: 3447-167 SPEC K-2256	Aging		
Function/Service: POSITION INDICATION FOR VALVE AO-3-1601-22	Submergence	NA	
Accuracy: Spec: Demo: Location TOP OF TORUS NEAR PEN X-148	Flood Level Elevation: NA Above Flood Level: Yes: No:		
Elevation 513'0"			
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-085B-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 202  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1 MINUTE
Plant I.D. Number: POS-3-1601-23	Temperature (°F)	103
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: NAMCO SNAP-LOCK	Relative Humidity (%)	100
Model Number: MARK II-D1200G	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: <b>POSITION INDICATION FOR VALVE</b> AO-3-1601-23	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location <b>NEAR COLUMNS L &amp; 40</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 572'0"		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1 MINUTE
Plant I.D. Number: POS-3-1601-24	Temperature (°F)	103
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: NAMCO SNAP-LOCK	Relative Humidity (%)	100
Model Number: MARK II-D1200G	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: <b>POSITION INDICATION FOR VALVE</b> AO-3-1601-24	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location <b>NEAR COLUMN K BETWEEN COLUMNS 45&amp;46</b>	Flood Level Elevation: Above Flood Level: Yes: No:	
Elevation		

0-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 203  
 Revision O  
 Date: 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:	PRESSURE SUPPRESSION	Operating Time	1 MINUTE
Plant I.D. Number:	AO-2-1601-55	Temperature (°F)	242
Component:	POSITION SWITCH	Pressure (PSIA)	27.0
Manufacturer:	NAMCO SNAP-LOCK	Relative Humidity (%)	100
Model Number:	MARK II-D1200G	Chemical Spray	NA
Purchase Order Number:	3447-167 SPEC K-2256	Radiation (Rad)	1.1 E05
Function/Service:	POSITION INDICATION FOR VALVE	Aging	
Accuracy:	Spec: Demo:	Submergence	NA
Location	TOP OF TORUS	Flood Level	
Elevation		Elevation	NA
Above Flood Level:	Yes: No:	Above Flood Level:	NA

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:	PRESSURE SUPPRESSION	Operating Time	1 MINUTE
Plant I.D. Number:	POS-3-1601-56	Temperature (°F)	242
Component:	POSITION SWITCH	Pressure (PSIA)	27.0
Manufacturer:	NAMCO SNAP-LOCK	Relative Humidity (%)	100
Model Number:	MARK II-D1200G	Chemical Spray	NA
Purchase Order Number:		Radiation (Rad)	1.1 E05
Function/Service:	POSITION INDICATION FOR VALVE AO-3-1601-56	Aging	
Accuracy:	Spec: Demo:	Submergence	NA
Location	TOP OF TORUS	Flood Level	
Elevation	513'0"	Elevation	NA
Above Flood Level:	Yes: No:	Above Flood Level:	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 204  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	PRESSURE SUPPRESSION
Plant I.D. Number:	.POS-3-1601-60
Component:	POSITION SWITCH
Manufacturer:	NAMCO SNAP-LOCK
Model Number:	MARK II-D1200G
Purchase Order Number:	
Function/Service:	POSITION INDICATION FOR VALVE AO-3-1601-60
Accuracy:	Spec: Demo:
Location	TOP OF TORUS
Elevation	512'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	1 MINUTE
Temperature (°F)	242
Pressure (PSIA)	27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	1.1 E05
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	PRESSURE SUPPRESSION
Plant I.D. Number:	POS-3-1601-63
Component:	POSITION SWITCH
Manufacturer:	NAMCO SNAP-LOCK
Model Number:	MARK II-D1200G
Purchase Order Number:	
Function/Service:	POSITION INDICATION FOR VALVE AO-3-1601-63
Accuracy:	Spec: Demo:
Location	NEAR COLUMN K BETWEEN COLUMNS 45&46
Elevation	578'0"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 205  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)						SEE NOTE (1)
Component: <b>AIR OPERATED VALVE POSITION SWITCH ONLY</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: NAMCO & SNAP-LOCK	Relative Humidity (%)						SEE NOTE (1)
Model Number: MARK II-D1200G	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 206  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
<b>System:</b> <b>PRESSURE SUPPRESSION</b>	
Plant I.D. Number: POS-3-1601-58	
Component: <b>AIR OPERATED VALVE POSITION SWITCH ONLY</b>	
Manufacturer: NAMCO & SNAP-LOCK	
Model Number: <b>MARK II-D1200G</b>	
Purchase Order Number:	
Function/Service: <b>POSITION INDICATION FOR VALVE</b>	
Accuracy:	Spec: Demo:
Location <b>NEAR COLUMNS 43 &amp; K</b>	
Elevation <b>513'0"</b>	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

EQUIPMENT DESCRIPTION	
<b>System:</b> <b>PRESSURE SUPPRESSION</b>	
Plant I.D. Number: POS-3-1601-59	
Component: <b>AIR OPERATED VALVE POSITION SWITCH ONLY</b>	
Manufacturer: NAMCO & SNAP-LOCK	
Model Number: <b>MARK II-D1200G</b>	
Purchase Order Number:	
Function/Service: <b>POSITION INDICATION FOR VALVE</b>	
Accuracy:	Spec: Demo:
Location	
Elevation <b>513'0"</b>	
Flood Level Elevation: Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 207  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: PRESSURE SUPPRESSION	Operating Time						SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)			REF. (A)			SEE NOTE (1)
Component: AIR OPERATED VALVE POSITION SWITCH ONLY	Pressure (PSIA)			REF. (A)			SEE NOTE (1)
Manufacturer: CRANE COMPANY	Relative Humidity (%)			REF. (A)			SEE NOTE (1)
Model Number:	Chemical Sprey	NA	NA	NA	NA	NA	
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)			REF. (B)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 208  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time			
Temperature (°F)			
Pressure (PSIA)			
Relative Humidity (%)			
Chemical Spray			
Radiation (Rad)			
Aging			
Submergence			
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time			
Temperature (°F)			
Pressure (PSIA)			
Relative Humidity (%)			
Chemical Spray			
Radiation (Rad)			
Aging			
Submergence			
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 209  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: MO-3-1601-57 Component: <b>MOTOR OPERATED GLOBE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number: <b>TYPE SMB-000 SN.83720A</b> Purchase Order Number: <b>3447-146 SPEC. K-2205</b> Function/Service: <b>AIR MAKE-UP SYSTEM INBOARD ISOLATION VALVE</b>  Accuracy: Spec: NA Demo: NA Location: <b>TOP OF TORUS</b>  Elevation: <b>513'0"</b>	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1. 1E05		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 210  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: <b>SEE ATTACHED SHEETS</b> Component: <b>SOLENOID VALVE</b>  Manufacturer: <b>ASCO</b>  Model Number: <b>HT831614</b>  Purchase Order Number:  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.1E05		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 211  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: <b>SO-3-1601-66</b>	Temperature (°F)	242
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100
Model Number: <b>HT831614</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	1.1E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-58</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>TOP OF TORUS</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: <b>SO-3-1601-67</b>	Temperature (°F)	242
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100
Model Number: <b>HT831614</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	1.1E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-59</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>TOP OF TORUS</b>	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 212  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION			ENVIRONMENT	
	Parameter	FSAR		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE		
Plant I.D. Number: SO-3-1601-69	Temperature (°F)	242		
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0		
Manufacturer: ASCO	Relative Humidity (%)	100		
Model Number: HT831614	Chemical Spray	NA		
Purchase Order Number:	Radiation (Rad)	1.1E05		
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-61</b>	Aging			
Accuracy: Spec: NA Demo: NA	Submergence	NA		
Location <b>TOP OF TORUS</b>				
Elevation 513' 0"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

EQUIPMENT DESCRIPTION			ENVIRONMENT	
	Parameter	FSAR		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE		
Plant I.D. Number: SO-3-1601-70	Temperature (°F)	242		
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0		
Manufacturer: ASCO	Relative Humidity (%)	100		
Model Number: HT831614	Chemical Spray	NA		
Purchase Order Number:	Radiation (Rad)	<1.0E04		
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-62</b>	Aging			
Accuracy: Spec: NA Demo: NA	Submergence	NA		
Location <b>NEAR COLUMNS L&amp;48</b>				
Elevation 574' 0"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 213  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: SO-3-1601-? Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: CAT #8317A29 SN. S19879 Purchase Order Number:  Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-55</b>  Accuracy: Spec: NA Demo: NA Location: <b>NEAR COLUMNS 41-42 &amp; H</b> Elevation: <b>514'0"</b>	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.1E05		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	NA
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 214  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: SO-3-8501-2A&B Component: <b>SOLENOID VALVE</b>  Manufacturer: <b>ASCO</b>  Model Number:  Purchase Order Number: 3447-214 SPEC Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.1E05		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	NA

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 215  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>PRESSURE SUPPRESSION</b>		
Plant I.D. Number: SO-3-8501-2A	Parameter	FSAR
Component: <b>SOLENOID VALVE</b>	Operating Time	1MINUTE
Manufacturer: ASCO	Temperature (°F)	242
Model Number:	Pressure (PSIA)	27.0
Purchase Order Number: 3447-214	Relative Humidity (%)	100
Function/Service: PILOT SOLENOID FOR VALVE AO-3-8501-1A	Chemical Spray	NA
Accuracy: Spec: NA Demo: NA	Radiation (Rad)	1.1E05
Location TOP OF TORUS	Aging	
Elevation 545' 6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time	1MINUTE	
Temperature (°F)	242	
Pressure (PSIA)	27.0	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.1E05	
Aging		
Submergence	NA	

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>PRESSURE SUPPRESSION</b>		
Plant I.D. Number: SO-3-8501-2B	Parameter	FSAR
Component: <b>SOLENOID VALVE</b>	Operating Time	1MINUTE
Manufacturer: ASCO	Temperature (°F)	242
Model Number:	Pressure (PSIA)	27.0
Purchase Order Number: 3447-214	Relative Humidity (%)	100
Function/Service: PILOT SOLENOID FOR VALVEAO-3-8501-1B	Chemical Spray	NA
Accuracy: Spec: NA Demo: NA	Radiation (Rad)	1.1E05
Location TOP OF TORUS	Aging	
Elevation 545' 6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 216  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time		NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: <b>SO-3-8501-4A&amp;B</b>	Temperature (°F)	242	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>CAT#8320A19</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number: <b>8320A19</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>3447-214</b>	Radiation (Rad)	3.3E05		REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	NA
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 217  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: SO-3-8501-4A	Temperature (°F)	103
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	14.7
Manufacturer: CAT#8320A19	Relative Humidity (%)	100
Model Number: 8320A19	Chemical Spray	NA
Purchase Order Number: 3447-214	Radiation (Rad)	3.3E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-8501-3A</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>DRYWELL, SOUTH SIDE</b>		
Elevation 530'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: SO-3-8501-4B	Temperature (°F)	103
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	14.7
Manufacturer: CAT#8320A19	Relative Humidity (%)	100
Model Number: 8320A19	Chemical Spray	NA
Purchase Order Number: 3447-214	Radiation (Rad)	3.3E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-8501-3B</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>DRYWELL, SOUTH SIDE</b>		
Elevation 530'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: SO-249

Component Sheet No: 218  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: SO-2-8501-6A&B Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: CAT#8320A19 SN. 66027S Purchase Order Number: 3447-214  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 219  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>SO-3-8501-6A</b>	Temperature (°F)	
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	
Model Number: <b>CAT#8320A19</b> SN. 66027S	Chemical Spray	
Purchase Order Number: <b>3447-214</b>	Radiation (Rad)	
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-8501-5A</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>NEAR COLUMNS 39,40 &amp; K,L</b> Elevation <b>547'6"</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>SO-3-8501-6B</b>	Temperature (°F)	
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	
Model Number: <b>CAT#8320A19</b> SN. 66027S	Chemical Spray	
Purchase Order Number: <b>3447-214</b>	Radiation (Rad)	
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-8501-5B</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>NEAR COLUMNS 39,40 &amp; K,L</b> Elevation <b>547'6"</b>	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 220  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	NORMAL 120 HELB242		REF. (B)			SEE NOTE (1)
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	NORMAL 14.7 HELB 27.0		REF. (B)			SEE NOTE (1)
Manufacturer: ASCO	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: LB 8314	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 3447-214	Radiation (Rad)	<1.0E04	NOT REQD.	REF. (C)	NOT REQD.		
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REV 1, FEB 1975. REV 1. C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 221  
 Revision O  
 Date: 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>PRESSURE SUPPRESSION</b>		ENVIRONMENT
Parameter	FSAR	
Operating Time	1MINUTE	
Temperature (°F)	NORMAL 120 HELB 242	
Pressure (PSIA)	NORMAL 14.7 HELB 242	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0EO4	
Aging		
Submergence	NA	
<b>Flood Level</b>		
Elevation: NA		
Above Flood Level:		
Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1MINUTE	
Temperature (°F)	NORMAL 120 HELB 242	
Pressure (PSIA)	NORMAL 14.7 HELB 242	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0EO4	
Aging		
Submergence	NA	
<b>Flood Level</b>		
Elevation: NA		
Above Flood Level:		
Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 222  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: SO-3-9204A	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	NORMAL 14.7 HELB 242
Manufacturer: ASCO	Relative Humidity (%)	100
Model Number: LB 8314	Chemical Spray	NA
Purchase Order Number: 3447-214	Radiation (Rad)	<1.OEO4
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-9206A</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>STEAM TUNNEL</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 514'0"		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: SO-3-9204B	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	NORMAL 14.7 HELB 242
Manufacturer: ASCO	Relative Humidity (%)	100
Model Number: LB 8314	Chemical Spray	NA
Purchase Order Number: 3447-214	Radiation (Rad)	<1.OEO4
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-9206B</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>STEAM TUNNEL</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 514'0"		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 223  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: DPT-3-1602-12 Component: <b>DIFFERENTIAL PRESSURE TRANSMITTER</b> Manufacturer:	Operating Time						SEE NOTE (1)
	Temperature (°F)	150		REF. (A)			SEE NOTE (2)
	Pressure (PSIA)	14.7		REF. (A)			SEE NOTE (2)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)			REF. (B)			SEE NOTE (2)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. DETERMINE EQUIPMENT OPERATING TIME. 2. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 224  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	12DAYS		REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>DPIS-3-1622A&amp;B</b>	Temperature (°F)	150		REF. (B)			SEE NOTE (1)
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)			
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>GE H1002</b>	Radiation (Rad)	1.3E06		REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11. AND 5.2.12. B. FSAR SECTION 6.2.3.2 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 225  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>DPIS-3-1622A</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE H1002</b>	Radiation (Rad)	1.3 E06
Function/Service: <b>ACTUATES PRESSURE SUPPRESSION SYSTEM TORUS RELIEF VALVE 1601-20A&amp;B</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-19A SE CORNER ROOM Elevation 476'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	12 DAYS
Plant I.D. Number: <b>DPIS-3-1622B</b>	Temperature (°F)	150
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARTON</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE H1002</b>	Radiation (Rad)	1.3 E06
Function/Service: <b>ACTUATES PRESSURE SUPPRESSION SYSTEM TORUS RELIEF VALVE 1601-20A&amp;B</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-19B SW CORNER ROOM Elevation 476'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 226  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: LT-3-1626 Component: <b>LEVEL TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: GE/MAC 553  Purchase Order Number: GE H0950  Function/Service: <b>TORUS WATER LEVEL MONITORING</b>  Accuracy: Spec: Demo: Location: RACK 2202-19A S.E. CORNER ROOM Elevation: 480'0"	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.5 · E06		REF. (B)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.2.3.2 B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 227  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 228  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: PS-3-1501-62A,B,C,D	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
Manufacturer: BARKSDALE	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
Model Number: D2X-H18-UL	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE H0314	Radiation (Rad)			REF. (B)			SEE NOTE (2)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. RESOLVE OPERATING TIME. 2. ESTABLISH RADIATION DOSE.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 229  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)		Radiation (Rad)	
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)		Radiation (Rad)	
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 230  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1501-62C</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>D2X-H18-UL</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-5 COLUMNS 49 & K Elevation 545' 6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1501-62D</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>D2X-H18-UL</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-6 COLUMNS 47 & M Elevation 545' 6"	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 231  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>PS-3-1620</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: <b>MELETRON</b>	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	NA
Purchase Order Number: <b>GE HO314</b>	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>DRYWELL PRESSURE SWITCH</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>RACK 2202-5</b> <b>COLUMNS 39&amp;K</b> Elevation: <b>545' 6"</b>	Submergence	NA	NA	NA	NA	NA	NA
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 232  
 Revision 0  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
Model Number: 12N-K4	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE H0314 & H1491	Radiation (Rad)			REF. (B)			SEE NOTE (2)
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. RESOLVE OPERATING TIME. 2. ESTABLISH RADIATION DOSE.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 233  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1621A</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>12N-K4</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314 &amp; H1491</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1621B</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>12N-K4</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314 &amp; H1491</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 234  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: PS-3-1621C	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: 12N-K4	Chemical Spray	NA
Purchase Order Number: GE H0314 & H1491	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 47 & M Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: PS-3-1621D	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: 12N-K4	Chemical Spray	NA
Purchase Order Number: GE H0314 & H1491	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 47 & M Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 235  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1628A</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>12N-K4</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1628B</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>12N-K4</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 236  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1629A</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>12N-K4</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 47 & M Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: <b>PS-3-1629B</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: <b>12N-K4</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO314</b>	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 47 & M Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 237  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
<b>System:</b> <b>PRESSURE SUPPRESSION</b>  <b>Plant I.D. Number:</b> PT-3-1625 <b>Component:</b> <b>PRESSURE TRANSMITTER</b>  <b>Manufacturer:</b> GENERAL ELECTRIC  <b>Model Number:</b> INSTR#4532-11001 CODE#KC-4547-262-14 <b>Purchase Order Number:</b> GE HO315  <b>Function/Service:</b> MAKE UP AIR SUPPLY PRESSURE TRANSMITTER  <b>Accuracy:</b> Spec: Demo: <b>Location:</b> RACK 2203-7 NEAR COLUMNS 49 & K <b>Elevation:</b> 517'6"	Operating Time						SEE NOTE (1)
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)			REF. (B)			SEE NOTE (2)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. RESOLVE OPERATING TIME. 2. ESTABLISH RADIATION DOSE

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 238  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>  Plant I.D. Number: PS-3-1632A,B,C,D Component: <b>PRESSURE SWITCH</b>  Manufacturer: <b>STATIC-O-RING</b>  Model Number: 12N-AA5  Purchase Order Number: GE H1197  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time				NOT REQD.		SEE NOTE (1)
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)			
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)			REF. (B)			SEE NOTE (2)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. RESOLVE OPERATING TIME. 2. ESTABLISH RADIATION DOSE.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 239  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)		Radiation (Rad)	
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)		Radiation (Rad)	
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 240  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: PS-3-1632C	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: 12N-AA5	Chemical Spray	NA
Purchase Order Number: GE H1197	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	
Plant I.D. Number: PS-3-1632D	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>STATIC-O-RING</b>	Relative Humidity (%)	100
Model Number: 12N-AA5	Chemical Spray	NA
Purchase Order Number: GE H1197	Radiation (Rad)	
Function/Service: <b>DRYWELL PRESSURE TRIP SWITCH</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location RACK 2203-6 COLUMNS 47 & M Elevation 545'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Component Sheet No: 241

Revision

Date

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: PRESSURE SUPPRESSION	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.1E05		REF. (C)			SEE NOTE (1)
	Aging						
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO.37,REV 1, FEB 1975 C. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 242

Revision

Date:

EQUIPMENT DESCRIPTION		
		ENVIRONMENT
System: <b>PRESSURE SUPPRESSION</b>	Parameter	FSAR
Plant I.D. Number: SO-3-1601-51A	Operating Time	1MINUTE
Component: <b>SOLENOID VALVE</b>	Temperature (°F)	242
Manufacturer:	Pressure (PSIA)	27.0
Model Number: VPS 2402	Relative Humidity (%)	100
Purchase Order Number:	Chemical Spray	NA
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-21</b>	Radiation (Rad)	1.1E05
Accuracy: Spec: NA Demo: NA	Aging	
Location <b>TOP OF TORUS</b>	Submergence	NA
Elevation 513' 0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT		
Parameter	FSAR	
Operating Time	1MINUTE	
Temperature (°F)	242	
Pressure (PSIA)	27.0	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.1E05	
Aging		
Submergence	NA	

EQUIPMENT DESCRIPTION		
		ENVIRONMENT
System: <b>PRESSURE SUPPRESSION</b>	Parameter	FSAR
Plant I.D. Number: SO-3-1601-52B	Operating Time	1MINUTE
Component: <b>SOLENOID VALVE</b>	Temperature (°F)	103
Manufacturer:	Pressure (PSIA)	14.7
Model Number: VPS 2402	Relative Humidity (%)	100
Purchase Order Number:	Chemical Spray	NA
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-23</b>	Radiation (Rad)	<1.0E04
Accuracy: Spec: NA Demo: NA	Aging	
Location <b>NEAR COLUMNS 48&amp;L PEN. X-125</b>	Submergence	NA
Elevation 572' 0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 243  
 Revision  
 Date:

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: SO-3-1601-65	Temperature (°F)	242
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0
Manufacturer:	Relative Humidity (%)	100
Model Number: VPS 2402	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	1.1E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-56</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>TOP OF TORUS</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 513' 0"		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE
Plant I.D. Number: SO-3-1601-68	Temperature (°F)	242
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0
Manufacturer:	Relative Humidity (%)	100
Model Number: VPS 2402	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	1.1E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-60</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>TOP OF TORUS</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 513' 0"		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 244  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
Manufacturer:	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: <b>VPS 2402</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	1.1E05		REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 245  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>			Operating Time	1MINUTE
Plant I.D. Number: SO-3-1601-50B			Temperature (°F)	242
Component: <b>SOLENOID VALVE</b>			Pressure (PSIA)	27.0
Manufacturer:			Relative Humidity (%)	100
Model Number: VPS 2402			Chemical Spray	NA
Purchase Order Number:			Radiation (Rad)	1.1E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-20B</b>			Aging	
Accuracy: Spec: NA Demo: NA			Submergence	NA
Location <b>TOP OF TORUS</b>				
Elevation 512' 0"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>			Operating Time	1MINUTE
Plant I.D. Number: SO-3-1601-50B			Temperature (°F)	242
Component: <b>SOLENOID VALVE</b>			Pressure (PSIA)	27.0
Manufacturer:			Relative Humidity (%)	100
Model Number: VPS 2402			Chemical Spray	NA
Purchase Order Number:			Radiation (Rad)	1.1E05
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-22</b>			Aging	
Accuracy: Spec: NA Demo: NA			Submergence	NA
Location <b>TOP OF TORUS</b>				
Elevation 513' 0"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 246  
 Revision  
 Date:

EQUIPMENT DESCRIPTION			ENVIRONMENT	
	Parameter	FSAR		
System: PRESSURE SUPPRESSION	Operating Time	1MINUTE		
Plant I.D. Number: SO-3-1601-71	Temperature (°F)	242		
Component: SOLENOID VALVE	Pressure (PSIA)	27.0		
Manufacturer:	Relative Humidity (%)	100		
Model Number: VPS 2402	Chemical Spray	NA		
Purchase Order Number:	Radiation (Rad)	1.1E05		
Function/Service: PILOT SOLENOID FOR VALVE AD-3-1601-63	Aging			
Accuracy: Spec: NA Demo: NA	Submergence	NA		
Location TOP OF TORUS				
Elevation 514' 0"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

EQUIPMENT DESCRIPTION			ENVIRONMENT	
	Parameter	FSAR		
System:	Operating Time			
Plant I.D. Number:	Temperature (°F)			
Component:	Pressure (PSIA)			
Manufacturer:	Relative Humidity (%)			
Model Number:	Chemical Spray			
Purchase Order Number:	Radiation (Rad)			
Function/Service:	Aging			
Accuracy: Spec: NA Demo: NA	Submergence			
Location TOP OF TORUS				
Elevation 514' 0"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 247  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
Manufacturer:	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: <b>VGS 4422</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	1.1E05		REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 248  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT		EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR			Parameter	FSAR
System: <b>PRESSURE SUPPRESSION</b>		Operating Time	1MINUTE	System: <b>PRESSURE SUPPRESSION</b>		Operating Time	1MINUTE
Plant I.D. Number: <b>SO-3-1601-51B</b>		Temperature (°F)	242	Plant I.D. Number: <b>SO-3-1601-52A</b>		Temperature (°F)	103
Component: <b>SOLENOID VALVE</b>		Pressure (PSIA)	27.0	Component: <b>SOLENOID VALVE</b>		Pressure (PSIA)	14.7
Manufacturer:		Relative Humidity (%)	100	Manufacturer:		Relative Humidity (%)	100
Model Number: <b>VGS 4422</b>		Chemical Spray	NA	Model Number: <b>VGS 4422</b>		Chemical Spray	NA
Purchase Order Number:		Radiation (Rad)	1.1E05	Purchase Order Number:		Radiation (Rad)	<1.0E04
Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-22</b>		Aging		Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1601-24</b>		Aging	
Accuracy: Spec: NA Demo: NA		Submergence	NA	Accuracy: Spec: NA Demo: NA		Submergence	NA
Location <b>TOP OF TORUS</b>		Flood Level Elevation: NA Above Flood Level: Yes: No:		Location <b>NEAR COLUMNS 45&amp;46&amp;K PEN. X-125</b>		Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation <b>513' 0"</b>				Elevation <b>578' 0"</b>			
Flood Level Elevation: NA Above Flood Level: Yes: No:							

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 249  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1MINUTE	
Temperature (°F)	103	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0E04	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1MINUTE	
Temperature (°F)	103	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.1E05	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1MINUTE	
Temperature (°F)	103	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.1E05	
Aging		
Submergence	NA	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 250  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>PRESSURE SUPPRESSION</b>		
<b>Plant I.D. Number:</b> SO-3-1601-68		
<b>Component:</b> <b>SOLENOID VALVE</b>		
<b>Manufacturer:</b>		
<b>Model Number:</b> VGS 4422		
<b>Purchase Order Number:</b>		
<b>Function/Service:</b> PILOT SOLENOID FOR VALVE AO-3-1601-60		
<b>Accuracy:</b> Spec: NA Demo: NA		
<b>Location</b> TOP OF TORUS,PEN.X318		
<b>Elevation</b> 513' 0"		
<b>Flood Level</b> Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT	
Parameter	FSAR
Operating Time	1MINUTE
Temperature (°F)	242
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	1.1E05
Aging	
Submergence	NA

ENVIRONMENT	
Parameter	FSAR
Operating Time	1MINUTE
Temperature (°F)	242
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	1.1E05
Aging	
Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 251  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PRESSURE SUPPRESSION</b>	Operating Time	1MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
Manufacturer:	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: <b>VGS 4522</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	1.1E05		REF. (C)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 252  
 Revision  
 Date:

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	PRESSURE SUPPRESSION		Operating Time	1MINUTE
Plant I.D. Number:	SO-3-1601-50A		Temperature (°F)	242
Component:	SOLENOID VALVE		Pressure (PSIA)	14.7
Manufacturer:			Relative Humidity (%)	100
Model Number:	VGS 4522		Chemical Spray	NA
Purchase Order Number:			Radiation (Rad)	1.1E05
Function/Service:	PILOT SOLENOID FOR VALVE AO-3-1601-20A		Aging	
Accuracy:	Spec: NA	Demo: NA	Submergence	NA
Location	TOP OF TORUS.		Flood Level	
Elevation	512' 0"		Elevation	NA
Above Flood Level:	Yes: No:		Above Flood Level:	NA
			Yes: No:	

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	PRESSURE SUPPRESSION		Operating Time	1MINUTE
Plant I.D. Number:	SO-3-1601-50B		Temperature (°F)	242
Component:	SOLENOID VALVE		Pressure (PSIA)	14.7
Manufacturer:			Relative Humidity (%)	100
Model Number:	VGS 4522		Chemical Spray	NA
Purchase Order Number:			Radiation (Rad)	1.1E05
Function/Service:	PILOT SOLENOID FOR VALVE AO-3-1601-20B		Aging	
Accuracy:	Spec: NA	Demo: NA	Submergence	NA
Location	TOP OF TORUS.		Flood Level	
Elevation	512' 0"		Elevation	NA
Above Flood Level:	Yes: No:		Above Flood Level:	NA
			Yes: No:	

G-0858-03



**Bechtel Power Corporation**



**Bechtel Power Corporation**  
**April 1980**

**- NOTICE -**

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

Docket # 50-249  
Deadline Return Date Control # 8005300089  
Date 4/29/80 of Document  
REGULATORY DOCKET FILE


**REGULATORY DOCKET FILE COPY**

RECORDS FACILITY BRANCH

**RESPONSE TO IE BULLETIN 79-01B**  
**DRESDEN**  
**NUCLEAR POWER STATION**  
**UNIT 3**

**Volume 3**

**Commonwealth Edison**



RESPONSE TO IE BULLETIN 79-01B  
DRESDEN NUCLEAR POWER STATION  
UNIT 3 AND COMMON

VOLUME 3

This volume contains equipment data sheets for the following Unit 3 and common systems:

1. Standby gas treatment
2. Service water
3. Diesel oil piping
4. Containment isolation
5. Control rod drive hydraulic
6. Reactor recirculation
7. Process radiation monitoring
- 8A. Reactor building ventilation
- 8B. Control room HVAC
9. Standby alternating current power
10. Standby direct current power
11. Isolation condenser
12. Generic/general use electrical equipment

Notes:

NA is used for not applicable

EO# is used for 10 to the power number (e.g., E06 =  $10^6$ )

This volume contains sheets 253 through 531

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 254  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY GAS TREATMENT  Plant I.D. Number: 2/3-A&B-7503 Component: ELECTRIC AIR HEATER  Manufacturer: NO TAG  Model Number:  Purchase Order Number: SPEC K-2215  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 255  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY GAS TREATMENT</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 2/3-A-7503	Temperature (°F)	120
Component: <b>ELECTRIC AIR HEATER</b>	Pressure (PSIA)	14.7
Manufacturer: NO TAG	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: SPEC K-2215	Radiation (Rad)	1.6 E06
Function/Service: <b>HEAT/DRY INLET GAS</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location 10'0" EAST COLUMN 44 2'0" NORTH COLUMN G Elevation 571'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY GAS TREATMENT</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 2/3-B-7503	Temperature (°F)	120
Component: <b>ELECTRIC AIR HEATER</b>	Pressure (PSIA)	14.7
Manufacturer: NO TAG	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: SPEC-K2215	Radiation (Rad)	1.6E06
Function/Service: <b>HEAT/DRY INLET GAS</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location 6'-0" WEST COLUMN 44 2'-0" NORTH COLUMN G Elevation 542'-0"	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 256  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY GAS TREATMENT  Plant I.D. Number: MO-2/3-7504A,B Component: MOTOR OPERATED DAMPER  Manufacturer:  Model Number:  Purchase Order Number: 3447-167 SPEC K-2256  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS	Operating Time	1 MINUTE		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 257  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	
Temperature (°F)	120	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0 E04	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: Above Flood Level: Yes: No:	NA	

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	
Temperature (°F)	120	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0 E04	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: Above Flood Level: Yes: No:	NA	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 258  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY GAS TREATMENT	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: MO-2/3-7505A,B	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
Component: MOTOR OPERATED DAMPER	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
Manufacturer:	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 3447-167 SPEC K-2256	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 259  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
System: STANDBY GAS TREATMENT	Operating Time	CONTINUOUS
Plant I.D. Number: MO-2/3 7505A	Temperature (°F)	120
Component: MOTOR OPERATED DAMPER	Pressure (PSIA)	14.7
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: 3447-167 SPEC K-2256	Radiation (Rad)	1.6 E06
Function/Service: INLET DAMPER	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location 6'0" EAST COLUMN 44 1'-6" SOUTH COLUMN G Elevation 542'-0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
System: STANDBY GAS TREATMENT	Operating Time	CONTINUOUS
Plant I.D. Number: MO-2/3-7505B	Temperature (°F)	120
Component: MOTOR OPERATED DAMPER	Pressure (PSIA)	14.7
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: 3447-167 SPEC K-2256	Radiation (Rad)	1.6 E06
Function/Service: INLET DAMPER	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location 6'-0" WEST COLUMN 44 1'-6" SOUTH COLUMN G Elevation 542'-0"	Flood Level Elevation: \$NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 260  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY GAS TREATMENT	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)			
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 261  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	120	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.6 E06	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	120	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.6 E06	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 262  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY GAS TREATMENT</b>  Plant I.D. Number: <b>MO-2/3-7507A,B</b> Component: <b>MOTOR OPERATED DAMPER</b>  Manufacturer:  Model Number:  Purchase Order Number: <b>3447-167 SPEC K-2256</b> Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 263  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY GAS TREATMENT	Operating Time	CONTINUOUS
Plant I.D. Number: MO-2/3-7507A	Temperature (°F)	120
Component: MOTOR OPERATED DAMPER	Pressure (PSIA)	14.7
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: 3447-167 SPEC K-2256	Radiation (Rad)	1.6 E06
Function/Service: DISCHARGE DAMPER A TRAIN	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location 8'-0" EAST COLUMN 44 1'-0" NORTH COLUMN E Elevation 546'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY GAS TREATMENT	Operating Time	CONTINUOUS
Plant I.D. Number: MO-2/3-7507B	Temperature (°F)	120
Component: MOTOR OPERATED DAMPER	Pressure (PSIA)	14.7
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: 3447-167 SPEC K-2256	Radiation (Rad)	1.6 E06
Function/Service: DISCHARGE DAMPER B TRAIN	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location 8'-0" WEST COLUMN 44 1'-0" NORTH COLUMN E Elevation 546'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 264  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY GAS TREATMENT</b>  Plant I.D. Number: TSH-2/3-7541-11A,B Component: <b>TEMPERATURE SWITCH</b> HIGH Manufacturer:  Model Number: NO TAG  Purchase Order Number: SPEC K-	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 265  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter	FSAR	
System:	Operating Time	CONTINUOUS	
STANDBY GAS TREATMENT	Temperature (°F)	120	
Plant I.D. Number: TSH-2/3-7541-11A	Pressure (PSIA)	14.7	
Component: TEMPERATURE SWITCH HIGH	Relative Humidity (%)	100	
Manufacturer:	Chemical Spray	NA	
Model Number: NO TAG	Radiation (Rad)	1.6 E06	
Purchase Order Number: SPEC K-	Aging	NOT REQD.	
Function/Service: SHUTS OFF A TRAIN HEATER ON HIGH GAS TEMPERATURE	Submergence	NA	
Accuracy: Spec: Demo:	Flood Level		
Location	Elevation		
Elevation	Elevation: NA		
Flood Level	Above Flood Level:		
	Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter	FSAR	
System:	Operating Time	CONTINUOUS	
STANDBY GAS TREATMENT	Temperature (°F)	120	
Plant I.D. Number: TSH-2/3-7541-11B	Pressure (PSIA)	14.7	
Component: TEMPERATURE SWITCH HIGH	Relative Humidity (%)	100	
Manufacturer:	Chemical Spray	NA	
Model Number: NO TAG	Radiation (Rad)	1.6 E06	
Purchase Order Number: SPEC-K	Aging	NOT REQD.	
Function/Service: SHUTS OFF B-TRAIN HEATER ON HIGH GAS TEMPERATURE	Submergence	NA	
Accuracy: Spec: Demo:	Flood Level		
Location	Elevation		
Elevation	Elevation: \$NA		
Flood Level	Above Flood Level:		
	Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 266  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY GAS TREATMENT  Plant I.D. Number: SCR-2/3-7541-36A,B Component:  Manufacturer: FOXBORO  Model Number:  Purchase Order Number: 3447-191 SPEC K-2272 Function/Service: SEE ATTACHED SHEETS	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	8.0 E05		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 267  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	8.0 E05	Radiation (Rad)	8.0 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	8.0 E05	Radiation (Rad)	8.0 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 268  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY GAS TREATMENT  Plant I.D. Number: FT-2/3-7541-40A,B Component: FLOW TRANSMITTER  Manufacturer:  Model Number:  Purchase Order Number: 3447-191 SPEC K-2272 Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 269  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	1.6 E06	Radiation (Rad)	1.6 E06
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	1.6 E06	Radiation (Rad)	1.6 E06
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 270  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY GAS TREATMENT  Plant I.D. Number: FSL-2/3-7541-41A,B Component: FLOW SWITCH LOW  Manufacturer:  Model Number:  Purchase Order Number: SPEC K-  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.6 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 271  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter	FSAR	
System:	Operating Time	CONTINUOUS	
STANDBY GAS TREATMENT	Temperature (°F)	120	
Plant I.D. Number: FSL-2/3-7541-41A	Pressure (PSIA)	14.7	
Component: FLOW SWITCH LOW	Relative Humidity (%)	100	
Manufacturer:	Chemical Spray	NA	
Model Number:	Radiation (Rad)	1.6 E06	
Purchase Order Number: SPEC K-	Aging	NOT REQD.	
Function/Service: SHUTS OFF AIR HEATER 2/3-A-7503 ON LOW FLOW	Submergence	NA	
Accuracy: Spec: Demo: Location	Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter	FSAR	
System:	Operating Time	CONTINUOUS	
STANDBY GAS TREATMENT	Temperature (°F)	120	
Plant I.D. Number: FSL-2/3-7541-4B	Pressure (PSIA)	14.7	
Component: FLOW SWITCH LOW	Relative Humidity (%)	100	
Manufacturer:	Chemical Spray	NA	
Model Number:	Radiation (Rad)	1.6 E06	
Purchase Order Number: SPEC K-	Aging	NOT REQD.	
Function/Service: SHUTS OFF AIR HEATER 2/3-B-7503 ON LOW FLOW	Submergence	NA	
Accuracy: Spec: Demo: Location	Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 272  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY GAS TREATMENT</b>  Plant I.D. Number: <b>FS-2/3-7541-45A,B</b> Component: <b>FLOW SWITCH</b>  Manufacturer: <b>MERCOID</b>  Model Number:  Purchase Order Number: <b>SPEC K-</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.3 E05		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 273  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.3 E05	Radiation (Rad)	2.3 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.3 E05	Radiation (Rad)	2.3 E05
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 274  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY GAS TREATMENT</b>  Plant I.D. Number: <b>2223-28A&amp;B</b> Component: <b>LOCAL PANEL</b>  Manufacturer:  Model Number: <b>NO TAG</b>  Purchase Order Number: <b>SPEC K-</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.3 E05		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 275  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: STANDBY GAS TREATMENT	Operating Time		CONTINUOUS
Plant I.D. Number: 2223-28A	Temperature (°F)		120
Component: LOCAL PANEL	Pressure (PSIA)		14.7
Manufacturer:	Relative Humidity (%)		100
Model Number: NO TAG	Chemical Spray		NA
Purchase Order Number: SPEC K-	Radiation (Rad)		2.3 E05
Function/Service: HOUSES AUXILIARY RELAYS AND CONTROL WIRING FOR SGTS SYSTEM	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location NEAR COLUMNS F & 44	Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: STANDBY GAS TREATMENT	Operating Time		CONTINUOUS
Plant I.D. Number: 2223-28B	Temperature (°F)		120
Component: LOCAL PANEL	Pressure (PSIA)		14.7
Manufacturer:	Relative Humidity (%)		100
Model Number: NO TAG	Chemical Spray		NA
Purchase Order Number: SPEC K-	Radiation (Rad)		2.3 E05
Function/Service: HOUSES AUXILIARY RELAYS AND CONTROL WIRING FOR SGTS SYSTEM	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location NEAR COLUMNS F & 44	Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 276  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	PARAMETER	FSAR	Qualification	FSAR	Qual.		
System: <b>SERVICE WATER</b>  Plant I.D. Number: 3&2/3-3903 Component: <b>DIESEL GENERATOR</b> <b>COOLING WATER PUMP</b> Manufacturer:  Model Number:  Purchase Order Number: 3447-140 SPEC K-2191 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	30 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	120		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
<p>A. THE DIESEL COOLING WATER PUMPS ARE REQUIRED FOR THE DURATION OF LOST OFFSITE POWER. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS</p> <p>B. FSAR SECTION 10.11</p> <p>C. BECHTEL RADIATION STUDY</p> <p>D. REPORT SECTION 4.3.6</p>	<p>1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 277  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	SERVICE WATER		Operating Time	30 DAYS
Plant I.D. Number:	3-3903		Temperature (°F)	120
Component:	DIESEL GENERATOR		Pressure (PSIA)	14.7
COOLING WATER PUMP			Relative Humidity (%)	100
Manufacturer:			Chemical Spray	NA
Model Number:			Radiation (Rad)	<1.0 E04
Purchase Order Number:	3447-140		Aging	NOT REQD.
SPEC K-2191			Submergence	NA
Function/Service:	SUPPLY COOLING WATER			
TO STANDBY DIESEL				
GENERATOR				
Accuracy:	Spec:	NA		
Demo:	NA			
Location				
DIESEL ROOM 3				
Elevation				
517'6"				
Flood Level				
Elevation:	NA			
Above Flood Level:				
Yes:	No:			

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System:	SERVICE WATER		Operating Time	30 DAYS
Plant I.D. Number:	2/3-3903		Temperature (°F)	120
Component:	DIESEL GENERATOR		Pressure (PSIA)	14.7
COOLING WATER PUMP			Relative Humidity (%)	100
Manufacturer:			Chemical Spray	NA
Model Number:			Radiation (Rad)	<1.0 E04
Purchase Order Number:	3447-140		Aging	NOT REQD.
SPEC K-2191			Submergence	NA
Function/Service:	SUPPLY COOLING WATER			
TO STANDBY DIESEL				
GENERATOR				
Accuracy:	Spec:	NA		
Demo:	NA			
Location				
DIESEL ROOM 2/3				
Elevation				
517'6"				
Flood Level				
Elevation:	NA			
Above Flood Level:				
Yes:	No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 278  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>SERVICE WATER</b>  Plant I.D. Number: 3-5746A,B Component: <b>REACTOR BLDG EMERGENCY AIR COOLER</b> Manufacturer: G-182-A	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	150		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	4.7 E06		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR PARAGRAPH 6.2.3.2 B. FSAR TABLE 5.2.2 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 279  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>SERVICE WATER</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 3-5746A	Temperature (°F)	150
Component: <b>REACTOR BLDG</b> <b>EMERGENCY AIR COOLER</b>	Pressure (PSIA)	14.7
Manufacturer: G-182-A	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: SPEC K-	Radiation (Rad)	3.4 E06
Function/Service: <b>PROVIDE COOLING TO</b> <b>LPCI ROOM</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location S.E. CORNER ROOM		
Elevation 505'-0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>SERVICE WATER</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 3-5746B	Temperature (°F)	150
Component: <b>REACTOR BLDG</b> <b>EMERGENCY AIR COOLER</b>	Pressure (PSIA)	14.7
Manufacturer: G-182-A	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: SPEC K-	Radiation (Rad)	4.7 E06
Function/Service: <b>PROVIDE COOLING TO</b> <b>LPCI ROOM</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location S.W. CORNER ROOM		
Elevation 507'-0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 280  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>SERVICE WATER</b>  Plant I.D. Number: 3-5747 Component: <b>HPCI BLDG EMERGENCY AIR COOLER</b> Manufacturer:	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (C)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.8 E06		REF. (D)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. FSAR SECTION 10.11 C. REPORT SECTION 4.3.6 D. BECHTEL RADIATION STUDY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 281  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>DIESEL OIL PIPING</b>  Plant I.D. Number: 3&2/3-5203 Component: <b>DIESEL OIL TRANSFER PUMP</b> Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: 2K182BLG239  Purchase Order Number: 3447-188  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>	Operating Time	30 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		NA			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
<p>A. THIS EQUIPMENT REQUIRED FOR THE DURATION OF LOST OFFSITE POWER. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED IN 30 DAYS.</p> <p>B. FSAR PARAGRAPH 10.11 AND SPECIAL REPORT NO. 37, REV 1, FEB 1975.</p> <p>C. BECHTEL RADIATION STUDY</p> <p>D. REPORT SECTION 4.3.6</p>	<p>1. RESOLVE QUALIFICATION REQUIREMENTS FOR TEMPERATURE. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE EFFECTS OF THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 282  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>DIESEL OIL PIPING</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 3-5203	Temperature (°F)	NORMAL 120 HELB 213
Component: <b>DIESEL OIL TRANSFER PUMP</b>	Pressure (PSIA)	NORMAL 14.7 HELB 15
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>2K182BLG239</b>	Chemical Spray	NA
Purchase Order Number: 3447-188	Radiation (Rad)	<1.0 EO4
Function/Service: <b>TRANSFER DIESEL OIL TO DAY TANK</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location UNIT 3 DG ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>DIESEL OIL PIPING</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 2/3-5203	Temperature (°F)	103
Component: <b>DIESEL OIL TRANSFER PUMP</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: <b>2K182BLG239</b>	Chemical Spray	NA
Purchase Order Number: 3447-188	Radiation (Rad)	<1.0 EO4
Function/Service: <b>TRANSFER DIESEL OIL TO DAY TANK</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location UNIT 2/3 DG ROOM NW CORNER	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 283  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>DIESEL OIL PIPING</b>  Plant I.D. Number: LS-3-5241-3 Component: <b>LEVEL SWITCH (HIGH/LOW)</b> Manufacturer: <b>MAGNETROL</b>  Model Number: A-103F SN.404600 Purchase Order Number: 3447-184 SPEC K-2258 Function/Service: <b>TRIP DIESEL OIL TRANSFER PUMP ON LOW LEVEL, START PUMP ON HIGH LEVEL</b>  Accuracy: Spec: Demo: Location: <b>UNIT 3 DG ROOM DAY TANK ROOM</b> Elevation: <b>527'0"</b>  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213	275	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9	45.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Relative Humidity (%)	100		REF. (C)	REF. (D)	SIMULTANEOUS TEST	SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (D)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (E)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
<p>A. THIS EQUIPMENT IS USED IN CONJUNCTION WITH THE DIESEL GENERATOR. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS.</p> <p>B. 9306-P04156 REPORT OF TEST ON MAGNETROL LEVEL SWITCH A-153-FEPLUPX-Y-TOM-S1M3H.</p> <p>C. FSAR SECTION 10.11 AND SPECIAL REPORT NO 37, REV 1, FEB 1975.</p>	<p>1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.</p>

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 284  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
D. BECHTEL RADIATION STUDY. E. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 285  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>DIESEL OIL PIPING</b>  Plant I.D. Number: SO-3-5202 Component: <b>SOLENOID VALVE</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service: <b>INLET SOLENOID TO DAY TANK 2-5205</b>  Accuracy: Spec: NA Demo: NA Location: <b>UNIT 3 DG ROOM DAY TANK ROOM</b> Elevation: 527'0"	Operating Time	30 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. THIS EQUIPMENT IS USED IN CONJUNCTION WITH THE DIESEL GENERATOR. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS. B. FSAR 10.11 AND SPECIAL REPORT NO. 37, REV 1, FEB, 1975. C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 286  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>DIESEL OIL PIPING</b>	Operating Time	30 DAYS		REF. (A)			SEE NOTE (1)
Plant I.D. Number: SO-2/3-5202	Temperature (°F)	NORMAL 120 HELB 213		REF. (B)			SEE NOTE (1)
Component: <b>SOLENOID</b>	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (B)			SEE NOTE (1)
Manufacturer:	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
Function/Service:	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: NA Demo: NA	Submergence	NA	NA	NA	NA	NA	
Location: <b>DIESEL GENERATOR ROOM 2/3 IN DAY TANK ROOM</b>	Flood Level						
Elevation: 527'0"	Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. THIS EQUIPMENT IS USED IN CONJUNCTION WITH THE DIESEL GENERATOR. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS. B. FSAR 10.11 AND SPECIAL REPORT NO. 37, REV 1, FEB, L975. C. BECHTEL RADIATION STUDY. D. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 287  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>DIESEL OIL PIPING</b>	Operating Time	30 DAYS		REF. (A)			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. THIS EQUIPMENT IS USED IN CONJUNCTION WITH THE DIESEL GENERATOR. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS. B. FSAR 10.11 AND SPECIAL REPORT NO. 37, REV 1, FEB, 1975. C. BECHTEL RADIATION STUDY. D. REPORT SECTION 4.3.6.	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 288  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	1 MINUTE	16 DAYS	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
Plant I.D. Number: MO-3-1001-1A&B	Temperature (°F)	NORMAL 150 LOCA 281	250	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	39.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
Manufacturer: <b>LIMITORQUE (RELIANCE) AC MOTOR</b>	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
Model Number: SMB-2-60	Chemical Spray	DEMIN WATER		REF. (D)			
Purchase Order Number: (B)	Radiation (Rad)	1.1 E05	2.0 E07	REF. (E)	REF. (B)	INDIVIDUAL TEST	SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging		165F FOR 199.8 HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (2)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REPORT NO. 600461-B0003 QUALIFICATION ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. TYPE TEST REPORT-LIMITORQUE VALVE C. FSAR FIGURES 5.2.11 & 5.2.12 & TABLE 5.2.1	1. INVESTIGATE EXISTENCE OF ADDITIONAL QUALIFICATION DATA WITH MANUFACTURER. 2. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 289  
Revision: 0  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
D. FSAR SECTION 6.2.4.2.B E. BECHTEL RADIATION STUDY	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 290  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: MO-3-1001-1A	Temperature (°F)	NORMAL 150 LOCA 281
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Manufacturer: <b>LIMITORQUE(RELIANCE) AC MOTOR</b>	Relative Humidity (%)	100
Model Number: SMB-2-60	Chemical Spray	DEMIN WATER
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	1.1 E05
Function/Service: <b>INBOARD CONTAINMENT ISOLATION VALVE, SHUTDOWN COOLING SYSTEM</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>INSIDE DRYWELL NEAR 340 AZIMUTH</b>	Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: MO-3-1001-1B	Temperature (°F)	NORMAL 150 LOCA 281
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Manufacturer: <b>LIMITORQUE(RELIANCE) AC MOTOR</b>	Relative Humidity (%)	100
Model Number: SMB-2-60	Chemical Spray	DEMIN WATER
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	1.1 E05
Function/Service: <b>INBOARD CONTAINMENT ISOLATION VALVE, SHUTDOWN COOLING SYSTEM</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>INSIDE DRYWELL NEAR 295 AZIMUTH</b>	Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN,  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 291  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: MO-3-1001-2A,B,C Component: <b>MOTOR OPERATED GATE VALVE (DC)</b> Manufacturer: <b>LIMITORQUE(PEERLESS) DC MOTOR</b> Model Number: SMB-2-60  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Temperature (°F)	103	340 F	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	14.7	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	1.0 E07	REF. (D)	REF. (B)	INDIVIDUAL TEST	
	Aging	NOT REQD.	185 C FOR 100 HOURS		REF. (B)	INDIVIDUAL TEST	
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REPORT NO. 600456-B0009-QUALIFICATION TYPE TEST REPORT-LIMITORQUE DC VALVE ACTUATORS C. FSAR SECTION 10.11 D. BECHTEL RADIATION STUDY	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 292  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: MO-3-1001-2A Component: MOTOR OPERATED GATE VALVE (DC) Manufacturer: LIMITORQUE(PEERLESS) DC MOTOR Model Number: SMB-2-60  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: OUTBOARD CONTAINMENT ISOLATION VALVE SHUTDOWN COOLING SYSTEM  Accuracy: Spec: NA Demo: NA Location SHUTDOWN COOLING PUMP ROOM Elevation 528' 6"	Operating Time	1 MINUTE
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	<1.0 E04
	Aging	NOT REQD.
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: MO-3-1001-2B Component: MOTOR OPERATED GATE VALVE (DC) Manufacturer: LIMITORQUE(PEERLESS) DC MOTOR Model Number: SMB-2-60  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: OUTBOARD CONTAINMENT ISOLATION VALVE, SHUTDOWN COOLING SYSTEM  Accuracy: Spec: NA Demo: NA Location SHUTDOWN COOLING PUMP ROOM Elevation 528' 6"	Operating Time	1 MINUTE
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	
	Radiation (Rad)	<1.0 E04
	Aging	NOT REQD.
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 293  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System:	CONTAINMENT ISOLATION
Plant I.D. Number:	MO-3-1001-2C
Component:	MOTOR OPERATED GATE VALVE (DC)
Manufacturer:	LIMITORQUE(PEERLESS) DC MOTOR
Model Number:	SMB-2-60
Purchase Order Number:	3447-141 SPEC K-2205
Function/Service:	OUTBOARD CONTAINMENT ISOLATION VALVE, SHUTDOWN COOLING SYSTEM
Accuracy:	Spec: NA Demo: NA
Location	SHUTDOWN COOLING PUMP ROOM
Elevation	528' 6"
Flood Level	
Elevation:	NA
Above Flood Level:	
Yes:	No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	1 MINUTE
Temperature (°F)	103
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	<1.0 E04
Aging	NOT REQD.
Submergence	NA

EQUIPMENT DESCRIPTION	
ENVIRONMENT	
Parameter	FSAR
System:	
Plant I.D. Number:	
Component:	
Manufacturer:	
Model Number:	
Purchase Order Number:	
Function/Service:	
Accuracy:	Spec: Demo:
Location	
Elevation	
Flood Level	
Elevation:	
Above Flood Level:	
Yes:	No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 294  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: MO-3-1001-5A&B Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number: SMB-2-60  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	1 MINUTE	16 DAYS	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Temperature (°F)	242	250	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	27.0	39.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.1 E05	2.0 E07	REF. (D)	REF. (B)	INDIVIDUAL TEST	
	Aging		165 F FOR 199.8 HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REPORT NO. 60046-80003 QUALIFICATION TYPE TEST REPORT LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE CONTAINMENT C. SPECIAL REPORT NO. 37, REV. 1, FEB 1975 D. BECHTEL RADIATION STUDY	1. RESOLVE AGING REQUIREMENTS.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 295  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: MO-3-1001-5A	Temperature (°F)	242
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>LIMITORQUE</b>	Relative Humidity (%)	100
Model Number: SMB-2-60	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	1.1 E05
Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE, SHUTDOWN COOLING SYSTEM</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location ABOVE TORUS, NEAR 90 AZIMUTH, PEN X-116A Elevation 513'9"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: MO-3-1001-5B	Temperature (°F)	242
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)	27.0
Manufacturer: <b>LIMITORQUE</b>	Relative Humidity (%)	100
Model Number: SMB-2-60	Chemical Spray	NA
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)	1.1 E05
Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE, SHUTDOWN COOLING SYSTEM</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location ABOVE TORUS, NEAR 270 AZIMUTH, PEN X-116B Elevation 513'9"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 296  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: MO-3-1201-1 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number: <b>SMB-1-25</b>  Purchase Order Number: <b>3447-141 SPEC K-2205</b> Function/Service: <b>INBOARD CONTAINMENT ISOLATION VALVE, REACTOR WATER CLEANUP SYSTEM</b>  Accuracy: Spec: NA Demo: NA Location: <b>INSIDE DRYWELL NEAR 110</b> Elevation: <b>535'0"</b>	Operating Time	1 MINUTE		REF. (A)		SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMAL 150 LOCA 281	307	REF. (B)	REF. (C)	SIMULTANEOUS TEST	
	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	74.7	REF. (B)	REF. (C)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (B)	REF. (C)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	DEMIN WATER		REF. (D)			SEE NOTE (3)
	Radiation (Rad)	1.1 E05		REF. (E)			SEE NOTE (3)
	Aging						SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR TABLE 5.2.1, FIGURE 5.2.11 & 5.2.12 C. REPORT NO. 338164-FC2485-01 TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR-BRAKE ASSEMBLY, BOTH WITH CLASS B INSULATION, UNDER SIMULATED REACTOR CONTAINMENT POST-	1. RESOLVE QUALIFICATION TEST TIME 2. THE TEST PROCEDURE CALLS OUT A SATURATED ATMOSPHERE, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST. 3. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 297  
Revision: 0  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
ACCIDENT STEAM AND CHEMICAL ENVIRONMENT D. FSAR SECTION 6.2.4.2.6 E. BECHTEL RADIATION STUDY	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 298  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: MO-3-1201-2&3 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number: <b>SMB-1-40</b>  Purchase Order Number: <b>3447-141 SPEC K-2205</b> Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	1 MINUTE		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMAL 150 LOCA 281	340	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	1.0 E07	REF. (D)	REF. (B)	INDIVIDUAL TEST	
	Aging		185 C FOR 100 HOURS 2000 CYCLES		REF. (B)	INDIVIDUAL TEST	
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REPORT NO. 600426-B0009 QUALIFICATION TYPE TEST REPORT & LIMITORQUE DC VALVE ACTUATORS. ONLY THE MOTOR WAS THERMALLY AGED. LIMITORQUE CORP. USES THESE UNITS AT 300F CONTINUOUSLY. THEREFORE, AGING WAS CONSIDERED REQUIRED FOR THE MOTOR ONLY.	1. THE TEMPERATURE PROFILE DOES NOT MEET THE REQUIREMENTS PER IEEE STANDARDS OR THAT OF THE FSAR. THE TIME TO REACH TEMPERATURE WAS 1 HOUR AND 55 MINUTES. 2. THE TEST PROCEDURE CALLS OUT A SATURATED ATMOSPHERE, BUT HUMIDITY WAS NOT MEASURED DURING TEST.

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 299

Revision: O

Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. ENVIRONMENTAL SERVICE CONDITIONS NOT ESTABLISHED. LOCA CONDITIONS FOR DRYWELL CONSERVATIVELY ASSUMED. D. BECHTEL RADIATION STUDY	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 300  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	1 MINUTE	Operating Time	1 MINUTE
Temperature (°F)	NORMAL 150 LOCA 281	Temperature (°F)	NORMAL 150 LOCA 281
Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 EO4	Radiation (Rad)	<1.0 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	1 MINUTE	Operating Time	1 MINUTE
Temperature (°F)	NORMAL 150 LOCA 281	Temperature (°F)	NORMAL 150 LOCA 281
Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 EO4	Radiation (Rad)	<1.0 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 301  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: <b>SEE ATTACHED SHEETS</b> Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number: <b>SMB-000-5</b>  Purchase Order Number: <b>3447-141</b> <b>SPEC K-2205</b> Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>	Operating Time	1 MINUTE		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	NORMAL 150 LOCA 281	307	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	74.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	DEMIN WATER	NA	REF. (D)			SEE NOTE (3)
	Radiation (Rad)	3.3 E05		REF. (E)			SEE NOTE (3)
	Aging						SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. REPORT NO. 338164-FC2485-01 TESTS OF LIMITORQUE VALVE OPERATOR AND MOTOR- BRAKE ASSEMBLY, BOTH WITH CLASS B INSULATION UNDER SIMULATED REACTOR CONTAINMENT POST-ACCIDENT STEAM AND CHEMICAL ENVIRONMENT.	1. RESOLVE QUALIFICATION TEST TIME. 2. THE TEST PROCEDURE CALLS OUT A SATURATED ATMOSPHERE, BUT HUMIDITY WAS NOT MEASURED DURING THE TEST. 3. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 302  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. FSAR TABLE 5.2.1, FIGURES 5.2.11 & 5.2.12 D. FSAR SECTION 6.2.4.2.B E. BECHTEL RADIATION STUDY	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 303  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>CONTAINMENT ISOLATION</b>		ENVIRONMENT
Plant I.D. Number: MO-3-3702		Parameter FSAR
Component: <b>MOTOR OPERATED GATE VALVE</b>		Operating Time 1 MINUTE
Manufacturer: <b>LIMITORQUE</b>		Temperature (°F) 242
Model Number: SMB-000-5		Pressure (PSIA) 27.0
Purchase Order Number: 3447-141 SPEC K-2205		Relative Humidity (%) 100
Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE, RBCCW SYSTEM</b>		Chemical Spray NA
Accuracy: Spec: NA Demo: NA		Radiation (Rad) 1.1 E05
Location ABOVE TORUS NEAR 315 AZIMUTH PEN X-123		Aging
Elevation 513'9"		Submergence NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	System: <b>CONTAINMENT ISOLATION</b>
Temperature (°F)	242	Plant I.D. Number: MO-3-3703
Pressure (PSIA)	27.0	Component: <b>MOTOR OPERATED GATE VALVE</b>
Relative Humidity (%)	100	Manufacturer: <b>LIMITORQUE</b>
Chemical Spray	NA	Model Number: SMB-000-5
Radiation (Rad)	1.1 E05	Purchase Order Number: 3447-141 SPEC K-2205
Aging		Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE, RBCCW SYSTEM</b>
Submergence	NA	Accuracy: Spec: NA Demo: NA
Location ABOVE TORUS NEAR 310 AZIMUTH PEN X-124		
Elevation 513'9"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-085B-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 304  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	1 MINUTE	Operating Time	
Temperature (°F)	NORMAL 150 LOCA 281	Temperature (°F)	
Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	Pressure (PSIA)	
Relative Humidity (%)	100	Relative Humidity (%)	
Chemical Spray	DEMIN WATER	Chemical Spray	
Radiation (Rad)	3.3 E05	Radiation (Rad)	
Aging		Aging	
Submergence	NA	Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System:		Operating Time	
Plant I.D. Number:		Temperature (°F)	
Component:		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: NA Demo: NA		Submergence	
Location INSIDE DRYWELL NEAR 310 AZIMUTH Elevation 513'9"		Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 305  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: POS-3-2001-5,6 Component: <b>POSITION SWITCH</b>  Manufacturer: NAMCO SNAP-LOCK Model Number: D1200G  Purchase Order Number:  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.3 E05		REF. (C)			
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO. 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 306  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION	
System:	CONTAINMENT ISOLATION
Plant I.D. Number:	POS-3-2001-5
Component:	POSITION SWITCH
Manufacturer:	NAMCO SNAP-LOCK
Model Number:	D1200G
Purchase Order Number:	
Function/Service:	OUTBOARD CONTAINMENT ISOLATION VALVE, RADWASTE DRAINS SYSTEM
Accuracy:	Spec: NA Demo: NA
Location	ABOVE TORUS, NEAR 45 AZIMUTH PEN X-118
Elevation	512'3"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	1 MINUTE
Temperature (°F)	242
Pressure (PSIA)	27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	3.3 E05
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
ENVIRONMENT	
Parameter	FSAR
System:	CONTAINMENT ISOLATION
Plant I.D. Number:	POS-3-2001-6
Component:	POSITION SWITCH
Manufacturer:	NAMCO SNAP-LOCK
Model Number:	D1200G
Purchase Order Number:	
Function/Service:	OUTBOARD CONTAINMENT ISOLATION VALVE, RADWASTE DRAINS SYSTEM
Accuracy:	Spec: NA Demo: NA
Location	ABOVE TORUS, NEAR 45 AZIMUTH PEN X-118
Elevation	512'3"
Flood Level	Elevation: NA Above Flood Level: Yes: No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 307  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: AO-3-2001-5 Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: CAT. 8316014 SN. 561317 Purchase Order Number:  Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE, RADWASTE DRAINS SYSTEM</b>  Accuracy: Spec: NA Demo: NA Location: ABOVE TORUS, NEAR 45 AZIMUTH PEN X-118 Elevation: 512'3"	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.3 E05		REF. (C)			
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO. 37, REV. 1, FEB 1975 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 308  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: AO-3-2001-6 Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: CAT.LHT831614 SN.S4300R2 Purchase Order Number:  Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE, RADWASTE DRAINS SYSTEM</b>  Accuracy: Spec: NA Demo: NA Location: <b>ABOVE TORUS NEAR 45 AZIMUTH PEN X-118</b> Elevation: 512' 3"	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	27					SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.3 E05		REF. (C)			
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO. 37, REV. 1, FEB 1975 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 309  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	1 MINUTE'	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 310  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: <b>POS-3-4720</b> Component: <b>POSITION SWITCH</b>  Manufacturer: <b>NAMCO</b> <b>SNAP-LOCK</b> Model Number: <b>MARK II D1200G</b>  Purchase Order Number:  Function/Service: <b>INSTRUMENT AIR</b> <b>LINE CONTAINMENT</b> <b>ISOLATION VALVE</b> <b>POSITION INDICATION</b>  Accuracy: Spec: NA Demo: NA Location: <b>CATWALK OUTSIDE</b> <b>DRYWELL ON NW SIDE</b> Elevation: <b>530'0"</b>	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 311  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	1 MINUTE	NOT REQD.	REF. (A)			
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 312  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: POS-3-4721 Component: <b>POSITION SWITCH</b>  Manufacturer: NAMCO SNAP-LOCK Model Number: MARK II-D1200G  Purchase Order Number:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 313  
 Revision O  
 Date 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: AO-3-4722 Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: 661085  Purchase Order Number:  Function/Service: <b>CONTAINMENT ISOLATION</b>  <b>INSTRUMENT AIR LINE</b>  Accuracy: Spec: NA Demo: NA Location: <b>CATWALK OUTSIDE DRYWELL ON NW SIDE</b> Elevation: 530'0"  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 EO4	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR TABLE 8.2.3 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 314  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: <b>POS-3-4722</b> Component: <b>POSITION SWITCH</b>  Manufacturer: <b>NAMCO</b> <b>SNAP-LOCK</b> Model Number:  Purchase Order Number:  Function/Service: <b>INSTRUMENT AIR</b> <b>LINE CONTAINMENT</b> <b>ISOLATION VALVE</b> <b>POSITION INDICATION</b>  Accuracy: Spec: NA Demo: NA Location: <b>CATWALK OUTSIDE</b> <b>DRYWELL ON NW SIDE</b> Elevation: <b>530'0"</b>  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR PARAGRAPH 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 315  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>	Operating Time			REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>A0-3-2001-105, 106</b>	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	27		REF. (B)			SEE NOTE (1)
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO. 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 316

Revision

Date:

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)	242	Temperature (°F)	242
Pressure (PSIA)	27	Pressure (PSIA)	27
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)		Radiation (Rad)	
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level		Flood Level	
Elevation: NA	Elevation: NA	Elevation: NA	Elevation: NA
Above Flood Level:		Above Flood Level:	
Yes: No:		Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: CONTAINMENT ISOLATION		System: CONTAINMENT ISOLATION	
Plant I.D. Number: AD-3-2001-105		Plant I.D. Number: AD-3-2001-106	
Component: SOLENOID VALVE		Component: SOLENOID VALVE	
Manufacturer: ASCO		Manufacturer: ASCO	
Model Number:		Model Number:	
Purchase Order Number:		Purchase Order Number:	
Function/Service: OUTBOARD CONTAINMENT ISOLATION VALVE RADWASTE DRAINS SYSTEM TAG DAMAGED		Function/Service: OUTBOARD CONTAINMENT ISOLATION VALVE RADWASTE DRAINS SYSTEM -HT 831614	
Accuracy: Spec: Demo:		Accuracy: Spec: Demo:	
Location ABOVE TORUS NEAR 180 AZIMUTH PEN X-117		Location ABOVE TORUS NEAR 180 AZIMUTH PEN X-117	
Elevation 512'0"		Elevation 512'0"	
Flood Level		Flood Level	
Elevation: NA	Elevation: NA	Elevation: NA	Elevation: NA
Above Flood Level:		Above Flood Level:	
Yes: No:		Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>	Operating Time			REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>POS-3-2001-105, 106</b>	Temperature (°F)	242		REF. (B)			SEE NOTE (1)
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	27		REF. (B)			SEE NOTE (1)
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: <b>HT 831614</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. SPECIAL REPORT NO. 37, REV 1, FEB 1975 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 318  
 Revision  
 Date:

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: <b>POS-3-2001-105</b>	Temperature (°F)	242
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	27
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100
Model Number: <b>HT 831614</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE RADWASTE DRAINS SYSTEM POSITION INDICATOR (TAG DAMA)</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location ABOVE TORUS NEAR 180 AZIMUTH PEN X-117 Elevation 512'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: <b>POS-3-2001-106</b>	Temperature (°F)	242
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	27
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100
Model Number: <b>HT 831614</b>	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>OUTBOARD CONTAINMENT ISOLATION VALVE RADWASTE DRAINS SYSTEM - POSITION INDICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo:	Submergence	NA
Location ABOVE TORUS NEAR 180 AZIMUTH PEN X-117 Elevation 512'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 319  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>  Plant I.D. Number: 3-700-733A,B,C,D,E Component: <b>SOLENOID BALL VALVE</b>  Manufacturer:	Operating Time		NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	104	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)			REF. (C)			
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component-Sheet No. 320  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		
System: <b>CONTAINMENT ISOLATION</b>		
Plant I.D. Number: 3-700-733A		
Component: <b>SOLENOID BALL VALVE</b>		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>		
Accuracy:	Spec:	NA
Demo:	NA	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence		

EQUIPMENT DESCRIPTION		
System: <b>CONTAINMENT ISOLATION</b>		
Plant I.D. Number: 3-700-733B		
Component: <b>SOLENOID BALL VALVE</b>		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>		
Accuracy: Spec: NA	Spec:	NA
Demo: NA	Demo:	NA
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		
Parameter	ENVIRONMENT	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 322  
 Revision  
 Date:

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-733D	Temperature (°F)	
Component: <b>SOLENOID BALL VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-733E	Temperature (°F)	
Component: <b>SOLENOID BALL VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Component Sheet No: 323

Revision

Date

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTAINMENT ISOLATION	Operating Time		NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: 3-700-736A,B,C,D,E	Temperature (°F)	104	NOT REQD.	REF. (B)	NOT REQD.		
Component: SQUIB SHEAR VALVE	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer:	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 324  
 Revision  
 Date:

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-736A	Temperature (°F)	
Component: <b>SQUIB SHEAR VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>BETWEEN COL 45&amp;46</b> <b>BETWEEN COL H&amp;J</b> Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-736B	Temperature (°F)	
Component: <b>SQUIB SHEAR VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>BETWEEN COL 45&amp;46</b> <b>BETWEEN COL H&amp;J</b> Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 325  
 Revision  
 Date: - - -

EQUIPMENT DESCRIPTION	ENVIRONMENT		EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR		Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time		System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-736C	Temperature (°F)		Plant I.D. Number: 3-700-736D	Temperature (°F)	
Component: <b>SQUIB SHEAR VALVE</b>	Pressure (PSIA)		Component: <b>SQUIB SHEAR VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)		Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray		Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)		Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging		Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence		Accuracy: Spec: NA Demo: NA	Submergence	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:		Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 326  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-736E	Temperature (°F)	
Component: <b>SQUIB SHEAR VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	
Plant I.D. Number:	Temperature (°F)	
Component:	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location Elevation	Submergence	
Flood Level Elevation: Above Flood Level: Yes: No:	Flood Level Elevation: Above Flood Level: Yes: No:	G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>	Operating Time		NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: 3-700-733A,B,C,D,E	Temperature (°F)	104	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>SOLENOID BALL VALVE</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer:	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 320  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>CONTAINMENT ISOLATION</b>  <b>Plant I.D. Number:</b> <b>3-700-733A</b> <b>Component:</b> <b>SOLENOID BALL VALVE</b>  <b>Manufacturer:</b>  <b>Model Number:</b>  <b>Purchase Order Number:</b>  <b>Function/Service:</b> <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>  <b>Accuracy:</b> Spec: NA <b>Demo:</b> NA <b>Location</b> <b>BETWEEN COL 45&amp;46</b> <b>BETWEEN COL H&amp;J</b> <b>Elevation</b> <b>522'0"</b>  <b>Flood Level</b> <b>Elevation:</b> NA <b>Above Flood Level:</b> <b>Yes:</b> <input type="checkbox"/> <b>No:</b> <input type="checkbox"/>		
ENVIRONMENT		
Parameter	FSAR	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence		

EQUIPMENT DESCRIPTION		
<b>System:</b> <b>CONTAINMENT ISOLATION</b>  <b>Plant I.D. Number:</b> <b>3-700-733B</b> <b>Component:</b> <b>SOLENOID BALL VALVE</b>  <b>Manufacturer:</b>  <b>Model Number:</b>  <b>Purchase Order Number:</b>  <b>Function/Service:</b> <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>  <b>Accuracy:</b> Spec: NA <b>Demo:</b> NA <b>Location</b> <b>BETWEEN COL 45&amp;46</b> <b>BETWEEN COL H&amp;J</b> <b>Elevation</b> <b>522'0"</b>  <b>Flood Level</b> <b>Elevation:</b> NA <b>Above Flood Level:</b> <b>Yes:</b> <input type="checkbox"/> <b>No:</b> <input type="checkbox"/>		
ENVIRONMENT		
Parameter	FSAR	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 321  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		
System: <b>CONTAINMENT ISOLATION</b>		
Plant I.D. Number: 3-700-733C		
Component: <b>SOLENOID BALL VALVE</b>		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>		
Accuracy:	Spec:	NA
Location	Demo:	NA
BETWEEN COL 45&46		
BETWEEN COL H&J		
Elevation		
522'0"		
Flood Level		
Elevation: NA		
Above Flood Level:		
Yes:	No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

EQUIPMENT DESCRIPTION		
System: <b>CONTAINMENT ISOLATION</b>		
Plant I.D. Number: 3-700-733D		
Component: <b>SOLENOID BALL VALVE</b>		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>		
Accuracy: Spec: NA		
Location	Demo:	NA
BETWEEN COL 45&46		
BETWEEN COL H&J		
Elevation		
522'0"		
Flood Level		
Elevation: NA		
Above Flood Level:		
Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 322  
 Revision  
 Date:

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-733D	Temperature (°F)	
Component: <b>SOLENOID BALL VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTAINMENT ISOLATION</b>	Operating Time	
Plant I.D. Number: 3-700-733E	Temperature (°F)	
Component: <b>SOLENOID BALL VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>TRANSVERSING IN CORE PROBE ISOLATION VALVE</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 323  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTAINMENT ISOLATION</b>	Operating Time		NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: 3-700-736A,B,C,D,E	Temperature (°F)	104	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>SQUIB SHEAR VALVE</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer:	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)			REF. (C)			
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 324  
 Revision  
 Date:

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Temperature (°F)	
Pressure (PSIA)		Relative Humidity (%)	
Chemical Spray		Radiation (Rad)	
Aging		Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Temperature (°F)	
Pressure (PSIA)		Relative Humidity (%)	
Chemical Spray		Radiation (Rad)	
Aging		Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 325  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		
System: CONTAINMENT ISOLATION		
Plant I.D. Number: 3-700-736C		
Component: SQUIB SHEAR VALVE		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service: TRANSVERSING IN CORE PROBE ISOLATION VALVE		
Accuracy:	Spec:	NA
	Demo:	NA
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

EQUIPMENT DESCRIPTION		
System: CONTAINMENT ISOLATION	Parameter	FSAR
Plant I.D. Number: 3-700-736D	Operating Time	
Component: SQUIB SHEAR VALVE	Temperature (°F)	
Manufacturer:	Pressure (PSIA)	
Model Number:	Relative Humidity (%)	
Purchase Order Number:	Chemical Spray	
Function/Service: TRANSVERSING IN CORE PROBE ISOLATION VALVE	Radiation (Rad)	
Accuracy: Spec: NA Demo: NA	Aging	
Location BETWEEN COL 45&46 BETWEEN COL H&J Elevation 522'0"	Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 326  
 Revision  
 Date: - -

EQUIPMENT DESCRIPTION		
System: CONTAINMENT ISOLATION		
Plant I.D. Number: 3-700-736E		
Component: SQUIB SHEAR VALVE		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service: TRANSVERSING IN CORE PROBE ISOLATION VALVE		
Accuracy:	Spec:	NA
Location	Demo:	NA
BETWEEN COL 45&46		
BETWEEN COL H&J		
Elevation	522'0"	
Flood Level		
Elevation:	NA	
Above Flood Level:		
Yes:	No:	

ENVIRONMENT		
Parameter	FSAR	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence		

EQUIPMENT DESCRIPTION		
System:		
Plant I.D. Number:		
Component:		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service:		
Accuracy:	Spec:	
Location	Demo:	
Elevation		
Flood Level		
Elevation:		
Above Flood Level:		
Yes:	No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No.: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 327  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	PARAMETER	FSAR	Qualification	FSAR	Qual.		
<b>System:</b> <b>CONTROL ROD DRIVE HYDRAULIC</b>  <b>Plant I.D. Number:</b> <b>SO-3-305-117</b> <b>Component:</b> <b>SOLENOID VALVE TYPICAL OF 177 UNITS</b> <b>Manufacturer:</b> <b>ASCO</b>  <b>Model Number:</b> <b>HVA90-405-2A</b>  <b>Purchase Order Number:</b>  <b>Function/Service:</b> <b>88 ON E SIDE OF RB</b> <b>89 ON W SIDE OF RB</b>	Operating Time	<1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.5 B. SAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 328  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>  Plant I.D. Number: <b>SO-3-305-118</b> Component: <b>SOLENOID VALVE TYPICAL OF 177 UNITS</b> Manufacturer: <b>ASCO</b>  Model Number: <b>HVA90-405-2A</b>  Purchase Order Number:  Function/Service: <b>88 ON E SIDE OF RB 89 ON W SIDE OF RB</b>	Operating Time	<1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 329  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>  Plant I.D. Number: <b>SO-3-0302-19A,B</b> Component: <b>SOLENOID VALVE</b>  Manufacturer: <b>ASCO</b>  Model Number: <b>3384-8-R</b>  Purchase Order Number: <b>GE 59137</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	<1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	NA
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 330  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> CONTROL ROD DRIVE HYDRAULIC		ENVIRONMENT
Plant I.D. Number: SO-3-0302-19A	Parameter	FSAR
Component: SOLENOID VALVE	Operating Time	<1 MINUTE
Manufacturer: ASCO	Temperature (°F)	103
Model Number: 3384-8-R	Pressure (PSIA)	14.7
Purchase Order Number: NEAR COLUMNS 45 & J	Relative Humidity (%)	100
Function/Service: BACKUP CONTROL ROD DRIVE SCRAM	Chemical Spray	NA
Accuracy: Spec: NA Demo: NA	Radiation (Rad)	<1.0 E04
Location ALONG NE OUTSIDE OF DRYWELL Elevation 517'0"	Aging	NOT REQD.
Flood Level Elevation: NA Above Flood Level: Yes: No:	Submergence	NA

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
System: CONTROL ROD DRIVE HYDRAULIC	Operating Time	<1 MINUTE
Plant I.D. Number: SO-3-0302-19B	Temperature (°F)	103
Component: SOLENOID VALVE	Pressure (PSIA)	14.7
Manufacturer: ASCO	Relative Humidity (%)	100
Model Number: 3384-8-R	Chemical Spray	NA
Purchase Order Number: GE 59137	Radiation (Rad)	<1.0 E04
Function/Service: BACKUP CONTROL ROD DRIVE SCRAM	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location NEAR COLUMNS 45 & J	Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 331  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROD DRIVE HYDRAULIC	Operating Time	<1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: SO-3-0302-20A&B	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: SOLENOID VALVE	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: ASCO	Relative Humidity (%)	100	NOT REQD.		NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE 59137	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.5 B. FSAR SECTION 10.11 FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 332  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>SO-3-0302-20A</b>	Temperature (°F)	103
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	14.7
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 59137</b>	Radiation (Rad)	<1.0 EO4
Function/Service: <b>CLOSES DISCHARGE VOLUME VENT AND DRAIN VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>ALONG OUTSIDE NE SIDE OF DRYWELL</b> Elevation <b>517'0"</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>SO-3-0302-20B</b>	Temperature (°F)	103
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	14.7
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 59137</b>	Radiation (Rad)	<1.0 EO4
Function/Service: <b>CLOSES DISCHARGE VOLUME VENT AND DRAIN VALVES</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>ALONG OUTSIDE NE SIDE OF DRYWELL</b> Elevation <b>517'0"</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 333  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>  Plant I.D. Number: <b>LS-3-0302-82A,B,C,D</b> Component: <b>LEVEL SWITCH</b>  Manufacturer: <b>MAGNETROL</b>  Model Number: <b>402</b>  Purchase Order Number: <b>GE HO749</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	<1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.7 E04		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 334  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>LS-3-0302-82A</b>	Temperature (°F)	103
Component: <b>LEVEL SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>MAGNETROL</b>	Relative Humidity (%)	100
Model Number: <b>402</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO749</b>	Radiation (Rad)	1.7 E04
Function/Service: <b>SCRAM DISCHARGE LEVEL VOLUME HIGH ALARM</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location <b>TIP ROOM</b>	Submergence	NA
Elevation <b>523'0"</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>	Operating Time	<1 MINUTE
Plant I.D. Number: <b>L2-3-0302-82B</b>	Temperature (°F)	103
Component: <b>LEVEL SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>MAGNETROL</b>	Relative Humidity (%)	100
Model Number: <b>402</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO749</b>	Radiation (Rad)	1.7 E04
Function/Service: <b>SCRAM DISCHARGE LEVEL VOLUME HIGH ALARM</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location <b>TIP ROOM</b>	Submergence	NA
Elevation <b>523'0"</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 335  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	<1 MINUTE	Operating Time	<1 MINUTE
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	1.7 EO4	Radiation (Rad)	1.7 EO4
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	<1 MINUTE	Operating Time	<1 MINUTE
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	1.7 EO4	Radiation (Rad)	1.7 EO4
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 336  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	<1 MINUTE		
Temperature (°F)	103		
Pressure (PSIA)	14.7		
Relative Humidity (%)	100		
Chemical Spray	NA		
Radiation (Rad)	1.7 EO4		
Aging	NOT REQD.		
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System:		Operating Time	
Plant I.D. Number: LS-3-0302-82E		Temperature (°F)	
Component: LEVEL SWITCH		Pressure (PSIA)	
Manufacturer: MAGNETROL		Relative Humidity (%)	
Model Number: 402		Chemical Spray	
Purchase Order Number: GE HO749		Radiation (Rad)	
Function/Service: SCRAM DISCHARGE LEVEL VOLUME HIGH ALARM		Aging	
Accuracy: Spec: Demo: Location TIP ROOM		Submergence	
Elevation 523'0"		Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 337  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROD DRIVE HYDRAULIC	Operating Time						SEE NOTE (1)
Plant I.D. Number: POS-3-302-21A,B	Temperature (°F)						SEE NOTE (1)
Component: POSITION SWITCH	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 338  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>	Operating Time	
Plant I.D. Number: <b>AO-2-302-21B</b>	Temperature (°F)	
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>	Operating Time	
Plant I.D. Number: <b>POS-3-302-21A</b>	Temperature (°F)	
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 339  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>	Operating Time	<1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: <b>POS-3-302-22</b>	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>NAMCO SNAP-LOCK</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
Function/Service: <b>DISCHARGE VOLUME DRAIN VALVE POSITION SWITCH</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>TIP ROOM AROUND STAIRWAY</b>							
Elevation: <b>517'-6"</b>							
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 340  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROD DRIVE HYDRAULIC	Operating Time	<1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: SOLENOID VALVES (TYPICAL OF 177 UNITS)	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: ASCO	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
Function/Service: SEE ATTACHED SHEETS	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 6.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 341  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: CONTROL ROD DRIVE HYDRAULIC	Operating Time	<1 MINUTE
Plant I.D. Number: SO-3-305-120	Temperature (°F)	103
Component: SOLENOID VALVES (TYPICAL OF 177 UNITS)	Pressure (PSIA)	14.7
Manufacturer: ASCO	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: CONTROL ROD DRIVE MANUAL CONTROL	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location ALONG OUTSIDE DRYWELL WALL-EAST WEST SIDE Elevation 517'-6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: CONTROL ROD DRIVE HYDRAULIC	Operating Time	<1 MINUTE
Plant I.D. Number: SO-3-305-121	Temperature (°F)	103
Component: SOLENOID VALVES (TYPICAL OF 177 UNITS)	Pressure (PSIA)	14.7
Manufacturer: ASCO	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: CONTROL ROD DRIVE MANUAL CONTROL	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location ALONG OUTSIDE DRYWELL WALL-EAST&WEST SIDE Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 342  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYDRAULIC</b>  Plant I.D. Number: SO-3-305-122 Component: <b>SOLENOID VALVES (TYPICAL OF 177 UNITS)</b> Manufacturer: ASCO  Model Number:  Purchase Order Number:  Function/Service: <b>CONTROL ROD DRIVE MANUAL CONTROL</b>  Accuracy: Spec: NA Demo: NA Location <b>ALONG OUTSIDE DRYWELL WALL-EAST &amp; WEST SID</b> Elevation <b>517'0"</b>  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	<1 MINUTE
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	<1.0 E04
	Aging	NOT REQD.
	Submergence	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>CONTROL ROD DRIVE HYD</b>  Plant I.D. Number: SO-3-305-123 Component: <b>SOLENOID VALVES (TYPICAL OF 177 UNITS)</b> Manufacturer: ASCO  Model Number:  Purchase Order Number:  Function/Service: <b>CONTROL ROD DRIVE MANUAL CONTROL</b>  Accuracy: Spec: NA Demo: NA Location <b>ALONG OUTSIDE DRYWELL WALL-EAST &amp; WEST SID</b> Elevation <b>517'-6"</b>  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	<1 MINUTE
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	<1.0 E04
	Aging	NOT REQD.
	Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 343  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: MO-3-205-2-4A,B	Temperature (°F)						SEE NOTE (1)
Component: <b>MOTOR OPERATED GATE VALVE</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: <b>LIMITORQUE</b>	Relative Humidity (%)						SEE NOTE (1)
Model Number: <b>SMB-1</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: 3447-141 SPEC K-2205	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION & INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 344  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
<b>System:</b> <b>REACTOR RECIRCULATION</b>	
Plant I.D. Number: MO-3-205-2-4A	
Component: <b>MOTOR OPERATED GATE VALVE</b>	
Manufacturer: <b>LIMITORQUE</b>	
Model Number: <b>SMB-1</b>	
Purchase Order Number: <b>3447-141</b>	
SPEC K-2205	
Function/Service: <b>REACTOR HEAD SPRAY INLET</b>	
Accuracy:	Spec:
Location	Demo:
Elevation	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

EQUIPMENT DESCRIPTION	
<b>System:</b> <b>REACTOR RECIRCULATION</b>	
Plant I.D. Number: MO-3-205-2-4B	
Component: <b>MOTOR OPERATED GATE VALVE</b>	
Manufacturer: <b>LIMITORQUE</b>	
Model Number: <b>SMB-1</b>	
Purchase Order Number: <b>3447-141</b>	
SPEC K-2205	
Function/Service: <b>REACTOR HEAD SPRAY INLET</b>	
Accuracy:	Spec:
Location	Demo:
Elevation	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 345  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	NORMAL 150 LOCA 281		REF. (B)			SEE NOTE (1)
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0		REF. (B)			SEE NOTE (1)
Manufacturer: <b>NAMCO SNAPLOCK</b>	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: <b>SA5A</b>	Chemical Spray	DEMIN WATER		REF. (C)			
Purchase Order Number:	Radiation (Rad)			REF. (D)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR FIGURES 5.2.11 & 5.2.12 C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 346  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>AO-3-220-44</b>	Temperature (°F)	
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	
Manufacturer: NAMCO SNAPLOCK	Relative Humidity (%)	
Model Number: <b>SA5A</b>	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>AO-3-220-45</b>	Temperature (°F)	
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	
Manufacturer: NAMCO SNAPLOCK	Relative Humidity (%)	
Model Number: <b>SA5A</b>	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	
Elevation	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 347  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: AO-3-220-51	Temperature (°F)	NORMAL 150 LOCA 281
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Manufacturer: NAMCO SNAPLOCK	Relative Humidity (%)	100
Model Number: SA5A	Chemical Spray	DEMIN WATER
Purchase Order Number:	Radiation (Rad)	3.3 E05
Function/Service:	Aging	
Accuracy: Spec: Demo: Location DRYWELL AZIMUTH 270	Submergence	NA
Elevation 585'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: AO-3-220-52	Temperature (°F)	NORMAL 150 LOCA 281
Component: <b>POSITION SWITCH</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Manufacturer: NAMCO SNAPLOCK	Relative Humidity (%)	100
Model Number: SA5A	Chemical Spray	DEMIN WATER
Purchase Order Number:	Radiation (Rad)	3.3 E05
Function/Service:	Aging	
Accuracy: Spec: Demo: Location DRYWELL AZIMUTH 270	Submergence	NA
Elevation 585'0"		
Flood Level Elevation: 505'6" Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 348  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: REACTOR RECIRCULATION	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (*F)	NORMAL 150 LOCA 281		REF. (B)			SEE NOTE (1)
Component: SOLENOID VALVE	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0		REF. (B)			SEE NOTE (1)
Manufacturer: ASCO	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: CAT. # WPH8300B61F	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)			REF. (D)			SEE NOTE (1)
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR FIGURES 5.2.10 & 5.2.11 C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 349  
 Revision O  
 Date: 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: AO-3-220-45	Temperature (°F)	
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	
Manufacturer: ASCO	Relative Humidity (%)	
Model Number: CAT. # WPH8300B61F	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>PILOT SOLENOID FOR RECIRCULATION LOOP SAMPLING VALVE</b> AO-3-220-45	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location		
Elevation 585'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: AO-3-220-51	Temperature (°F)	NORMAL 150 LOCA 281
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Manufacturer: ASCO	Relative Humidity (%)	100
Model Number: CAT. # WPH8300B61F	Chemical Spray	DEMIN WATER
Purchase Order Number:	Radiation (Rad)	3.3 EO5
Function/Service: <b>PILOT SOLENOID FOR REACTOR VESSEL HEAD LEAKOFF VALVE</b> AO-3-220-51	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location		
INSIDE DRYWELL Elevation 585'0"		
Flood Level Elevation: Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 351  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (A)			SEE NOTE (1)
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	27.0		REF. (A)			SEE NOTE (1)
Manufacturer: <b>MELETRON</b>	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
Model Number: <b>372-665-49A</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>GE H0763</b>	Radiation (Rad)	7.0 E04		REF. (B)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SPECIAL REPORT NO 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 352  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: PS-3-263-51A Component: <b>PRESSURE SWITCH</b>  Manufacturer: <b>MELETRON</b>  Model Number: 372-665-49A  Purchase Order Number: GE H0763  Function/Service: <b>ABOVE 600PSIG, ENERGIZES SCRAM</b>  Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Operating Time	CONTINUOUS
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	7.0 E04
	Aging	
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: PS-3-263-51B Component: <b>PRESSURE SWITCH</b>  Manufacturer: <b>MELETRON</b>  Model Number: 372-665-49A  Purchase Order Number: GE H0763  Function/Service: <b>ABOVE 600PSIG, ENERGIZES SCRAM RELAYS</b>  Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 48 & M Elevation 545'6"	Operating Time	CONTINUOUS
	Temperature (°F)	242
	Pressure (PSIA)	27.0
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	3.4 E04
	Aging	
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 353  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	242
Pressure (PSIA)	14.7	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	7.0 E04	Radiation (Rad)	3.4 E04
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: REACTOR RECIRCULATION		System: REACTOR RECIRCULATION	
Plant I.D. Number: PS-3-263-52A		Plant I.D. Number: PS-3-263-52B	
Component: PRESSURE SWITCH		Component: PRESSURE SWITCH	
Manufacturer: MELETRON		Manufacturer: MELETRON	
Model Number: 372-665-49A		Model Number: 372-665-49A	
Purchase Order Number: GE H0763		Purchase Order Number: GE H0763	
Function/Service: INITIATES CORE SPRAY AND LPCI ON LOW REACTOR PRESSURE		Function/Service: INITIATES CORE SPRAY AND LPCI ON LOW REACTOR PRESSURE	
Accuracy: Spec: Demo:		Accuracy: Spec: Demo:	
Location RACK 2203-5 COLUMNS 49 & K		Location RACK 2203-6 COLUMNS 48 & M	
Elevation 545'6"		Elevation 545'6"	
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 354  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS		NA			
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (A)			SEE NOTE (1)
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	27.0		REF. (A)			SEE NOTE (1)
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA	NA	NA	NA	NA	NA
Purchase Order Number: <b>M-77-81</b>	Radiation (Rad)	7.0 E04		REF. (B)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	NA
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 355  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	ESAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	7.0 E04	Radiation (Rad)	
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)		Radiation (Rad)	
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 348  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	PARAMETER	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	NORMAL 150 LOCA 281		REF. (B)			SEE NOTE (1)
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0		REF. (B)			SEE NOTE (1)
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
Model Number: <b>CAT. # WPH8300B61F</b>	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)			REF. (D)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR FIGURES 5.2.10 & 5.2.11 C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 349  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	1 MINUTE	
Temperature (°F)	NORMAL 150 LOCA 281	
Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	
Relative Humidity (%)	100	
Chemical Spray	DEMIN WATER	
Radiation (Rad)	3.3 E05	
Aging		
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 350  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	1 MINUTE
Plant I.D. Number: <b>A0-3-220-52</b>	Temperature (°F)	NORMAL 150 LOCA 281
Component: <b>SOLENOID VALVE</b>	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0
Manufacturer: <b>ASCO</b>	Relative Humidity (%)	100
Model Number: <b>CAT. # WPH8300B61F</b>	Chemical Spray	DEMIN WATER
Purchase Order Number:	Radiation (Rad)	3.3 E05
Function/Service: <b>PILOT SOLENOID FOR REACTOR VESSEL HEAD LEAKOFF VALVE</b> <b>A0-3-220-52</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location  <b>INSIDE DRYWELL</b> Elevation <b>585'0"</b>		
Flood Level Elevation: 505'6" Above Flood Level: Yes: X No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	
Plant I.D. Number:	Temperature (°F)	
Component:	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo:	Submergence	
Location		
Elevation		
Flood Level Elevation: Above Flood Level: Yes: X No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 351  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (A)			SEE NOTE (1)
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	27.0		REF. (A)			SEE NOTE (1)
Manufacturer: <b>MELETRON</b>	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
Model Number: <b>372-665-49A</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>GE HO763</b>	Radiation (Rad)	7.0 E04		REF. (B)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SPECIAL REPORT NO 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 352  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-51A</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>MELETRON</b>	Relative Humidity (%)	100
Model Number: <b>372-665-49A</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H0763</b>	Radiation (Rad)	7.0 EO4
Function/Service: <b>ABOVE 600PSIG, ENERGIZES SCRAM</b>	Aging	
Accuracy: Spec: Demo: Location <b>RACK 2203-5 COLUMNS 49 &amp; K</b> Elevation <b>545'6"</b>	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-51B</b>	Temperature (°F)	242
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	27.0
Manufacturer: <b>MELETRON</b>	Relative Humidity (%)	100
Model Number: <b>372-665-49A</b>	Chemical Spray	NA
Purchase Order Number: <b>GE H0763</b>	Radiation (Rad)	3.4 EO4
Function/Service: <b>ABOVE 600PSIG, ENERGIZES SCRAM RELAYS</b>	Aging	
Accuracy: Spec: Demo: Location <b>RACK 2203-6 COLUMNS 48 &amp; M</b> Elevation <b>545'6"</b>	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 353  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	242
Pressure (PSIA)	14.7	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	7.0 EO4	Radiation (Rad)	3.4 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	242	Temperature (°F)	242
Pressure (PSIA)	27.0	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.4 EO4	Radiation (Rad)	3.4 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

C-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 354  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS		NA			
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (A)			SEE NOTE (1)
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	27.0		REF. (A)			SEE NOTE (1)
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA	NA	NA	NA	NA	NA
Purchase Order Number: <b>M-77-81</b>	Radiation (Rad)	7.0 E04		REF. (B)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	NA
Location: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 355  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time	CONTINUOUS		
Temperature (°F)	103		
Pressure (PSIA)	14.7		
Relative Humidity (%)	100		
Chemical Spray	NA		
Radiation (Rad)	7.0 E04		
Aging	NOT REQD.		
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time	CONTINUOUS		
Temperature (°F)	103		
Pressure (PSIA)	14.7		
Relative Humidity (%)	100		
Chemical Spray	NA		
Radiation (Rad)			
Aging	NOT REQD.		
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 356  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	242	Temperature (°F)	242
Pressure (PSIA)	27.0	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.4 E04	Radiation (Rad)	3.4 E04
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	242	Temperature (°F)	242
Pressure (PSIA)	27.0	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.4 E04	Radiation (Rad)	3.4 E04
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 357  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-55A</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA
Purchase Order Number: <b>M-77-81</b>	Radiation (Rad)	7.0 EO4
Function/Service: <b>REACTOR PRESSURE HIGH ALARM, ENERGIZES SCRAM RELAY</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-55B</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA
Purchase Order Number: <b>M-77-81</b>	Radiation (Rad)	7.0 EO4
Function/Service: <b>REACTOR PRESSURE HIGH ALARM ENERGIZES SCRAM RELAY</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 358  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-55C</b>	Temperature (°F)	242
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	27.0
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA
Purchase Order Number: <b>M-77-81</b>	Radiation (Rad)	3.4 EO4
Function/Service: <b>REACTOR PRESSURE HIGH ALARM, ENERGIZES SCRAM RELAY</b>	Aging	
Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 48 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-55D</b>	Temperature (°F)	242
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	27.0
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA
Purchase Order Number: <b>M-77-81</b>	Radiation (Rad)	3.4 EO4
Function/Service: <b>REACTOR PRESSURE HIGH ALARM, ENERGIZES SCRAM RELAY</b>	Aging	
Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 48 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 359  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: <b>SEE ATTACHED SHEETS</b> Component: <b>LEVEL INDICATING SWITCH</b> Manufacturer: <b>YARWAY</b>  Model Number: <b>4418C</b>  Purchase Order Number: <b>GE HO815</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			
	Temperature (°F)	242	212	REF. (A)	REF. (B)		SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100	96	REF. (A)	REF. (B)		SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	7.0 E04		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975. B. REPORT NO DV145C3031- QUALIFICATION DESIGN VERIFICATION FILE, YARWAY 4418C, CE, EC C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 360  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>LIS-3-263-57A</b>	Temperature (°F)	103
Component: <b>LEVEL INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>YARWAY</b>	Relative Humidity (%)	100
Model Number: <b>4418C</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO815</b>	Radiation (Rad)	7.0 E04
Function/Service: <b>REACTOR VESSEL LOW LOW WATER LEVEL ALARM</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>LIS-3-263-57B</b>	Temperature (°F)	103
Component: <b>LEVEL INDICATING SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>YARWAY</b>	Relative Humidity (%)	100
Model Number: <b>4418C</b>	Chemical Spray	NA
Purchase Order Number: <b>GE HO815</b>	Radiation (Rad)	7.0 E04
Function/Service: <b>REACTOR VESSEL LOW LOW WATER LEVEL ALARM</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0058-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 361  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>		Operating Time	CONTINUOUS
Plant I.D. Number: LIS-3-263-58A		Temperature (°F)	242
Component: <b>LEVEL INDICATING SWITCH</b>		Pressure (PSIA)	27.0
Manufacturer: YARWAY		Relative Humidity (%)	100
Model Number: 4418C		Chemical Spray	NA
Purchase Order Number: GE HO815		Radiation (Rad)	3.4 E04
Function/Service: START AND TRIP SIGNALS TO HPCI, LPCI, AND SERVICE WATER PUMPS		Aging	
Accuracy: Spec: Demo:		Submergence	NA
Location RACK 2203-6 COLUMNS 48 & M Elevation 545'6"		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>		Operating Time	CONTINUOUS
Plant I.D. Number: LIS-3-263-58B		Temperature (°F)	242
Component: <b>LEVEL INDICATING SWITCH</b>		Pressure (PSIA)	27.0
Manufacturer: YARWAY		Relative Humidity (%)	100
Model Number: 4418C		Chemical Spray	NA
Purchase Order Number: GE HO815		Radiation (Rad)	3.4 E04
Function/Service: START AND TRIP SIGNALS TO HPCI, LPCI, AND SERVICE WATER PUMPS		Aging	
Accuracy: Spec: Demo:		Submergence	NA
Location RACK 2203-6 COLUMNS 48 & M Elevation 545'6"		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>		Operating Time	CONTINUOUS
Plant I.D. Number: LIS-3-263-58B		Temperature (°F)	242
Component: <b>LEVEL INDICATING SWITCH</b>		Pressure (PSIA)	27.0
Manufacturer: YARWAY		Relative Humidity (%)	100
Model Number: 4418C		Chemical Spray	NA
Purchase Order Number: GE HO815		Radiation (Rad)	3.4 E04
Function/Service: START AND TRIP SIGNALS TO HPCI, LPCI, AND SERVICE WATER PUMPS		Aging	
Accuracy: Spec: Demo:		Submergence	NA
Location RACK 2203-6 COLUMNS 48 & M Elevation 545'6"		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 362  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System: <b>REACTOR RECIRCULATION</b>	ENVIRONMENT
Plant I.D. Number: <b>LIS-3-263-59A</b>	Parameter FSAR
Component: <b>LEVEL INDICATING SWITCH</b>	Operating Time CONTINUOUS
Manufacturer: <b>YARWAY</b>	Temperature (°F) 103
Model Number: <b>4418C</b>	Pressure (PSIA) 14.7
Purchase Order Number: <b>GE HO815</b>	Relative Humidity (%) 100
Function/Service: <b>TRIP MAIN TURBINE AND FEEDWATER PUMPS SWITCHOVER OF LEVEL CONTROL TO/FROM FEEDWATER SYSTEM</b>	Chemical Spray NA
Accuracy: Spec: Demo:	Radiation (Rad) 7.0 E04
Location <b>RACK 2203-5 COLUMNS 49 &amp; K</b>	Aging NOT REQD.
Elevation <b>545'6"</b>	Submergence NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	103
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	7.0 E04
Aging	NOT REQD.
Submergence	NA

EQUIPMENT DESCRIPTION	
System: <b>REACTOR RECIRCULATION</b>	ENVIRONMENT
Plant I.D. Number: <b>LIS-3-263-59B</b>	Parameter FSAR
Component: <b>LEVEL INDICATING SWITCH</b>	Operating Time CONTINUOUS
Manufacturer: <b>YARWAY</b>	Temperature (°F) 242
Model Number: <b>4418C</b>	Pressure (PSIA) 27.0
Purchase Order Number: <b>GE HO815</b>	Relative Humidity (%) 100
Function/Service: <b>TRIP MAIN TURBINE AND FEEDWATER PUMPS, SWITCHOVER OF LEVEL CONTROL TO/FROM FEEDWATER SYSTEM</b>	Chemical Spray NA
Accuracy: Spec: Demo:	Radiation (Rad) 3.4 E04
Location <b>RACK 2203-6 COLUMNS 48 &amp; M</b>	Aging NOT REQD.
Elevation <b>545'6"</b>	Submergence NA
Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-085B-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 363  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	242
Pressure (PSIA)	14.7	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	7.0 EO4	Radiation (Rad)	3.4 EO4
Aging	NOT REQD.	Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	242	Temperature (°F)	27.0
Pressure (PSIA)	27.0	Pressure (PSIA)	NA
Relative Humidity (%)	100	Relative Humidity (%)	NA
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.4 EO4	Radiation (Rad)	
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 364  
 Revision O  
 Date: 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	242
Pressure (PSIA)	14.7	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	7.0 EO4	Radiation (Rad)	3.4 EO4
Aging	NOT REQD.	Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	242	Temperature (°F)	242
Pressure (PSIA)	27.0	Pressure (PSIA)	27.0
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	3.4 EO4	Radiation (Rad)	3.4 EO4
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 365  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)	242		REF. (A)			SEE NOTE (1)
Component: <b>LEVEL TRANSMITTER</b>	Pressure (PSIA)	27.0		REF. (A)			SEE NOTE (1)
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
Model Number: <b>GE/MAC 553</b>	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: <b>SEE ATTACHED SHEETS</b>	Radiation (Rad)	7.0 E04		REF. (B)			SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 366  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: LT-3-646A Component: <b>LEVEL TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: <b>GE/MAC 553</b>  Purchase Order Number: GE H1158 MANUAL GEK 13969-10 Function/Service: <b>REACTOR VESSEL LEVEL INDICATION</b>  Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Operating Time	CONTINUOUS	
	Temperature (°F)	103	
	Pressure (PSIA)	14.7	
	Relative Humidity (%)	100	
	Chemical Spray	NA	
	Radiation (Rad)	7.0 EO4	
	Aging	NOT REQD.	
	Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: LT-3-646B Component: <b>LEVEL TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: <b>GE/MAC 553</b>  Purchase Order Number: GE H1158 MANUAL GEK 13969-10 Function/Service: <b>REACTOR VESSEL LEVEL INDICATION</b>  Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 48 & M Elevation 545'6"	Operating Time	CONTINUOUS	
	Temperature (°F)	242	
	Pressure (PSIA)	27.0	
	Relative Humidity (%)	100	
	Chemical Spray	NA	
	Radiation (Rad)	3.4 EO4	
	Aging		
	Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 367  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	
Temperature (°F)	103	Temperature (°F)	
Pressure (PSIA)	14.7	Pressure (PSIA)	
Relative Humidity (%)	100	Relative Humidity (%)	
Chemical Spray	NA	Chemical Spray	
Radiation (Rad)	7.0 E04	Radiation (Rad)	
Aging	NOT REQD.	Aging	
Submergence	NA	Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System:		Operating Time	
Plant I.D. Number:		Temperature (°F)	
Component:		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
REACTOR VESSEL LEVEL INDICATION		Submergence	
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545' 6"		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 368  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: <b>LITS-3-263-73A&amp;B</b> Component: <b>LEVEL INDICATING TRANSMITTING SWITCH</b> Manufacturer: <b>YARWAY</b>  Model Number: <b>4418CE</b>  Purchase Order Number: <b>GE H1199</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.1 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. FSAR SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 369  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.1 E06	Radiation (Rad)	2.1 E06
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.1 E06	Radiation (Rad)	2.1 E06
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 370  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: <b>PS-3-263-111A,B,C,D</b> Component: <b>PRESSURE SWITCH</b>  Manufacturer: <b>BARKSDALE</b>  Model Number: <b>B2T-M1255-GE</b>  Purchase Order Number: <b>GE 209A4965P1</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.1 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. FSAR SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 371  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-111A</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA
Purchase Order Number: <b>GE 209A4965P1</b>	Radiation (Rad)	2.1 E06
Function/Service: <b>PERMISSIVE FOR LPCI LOOP SELECTION DELAY</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-7 COLUMNS 49 & K Elevation 517'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PS-3-263-111B</b>	Temperature (°F)	103
Component: <b>PRESSURE SWITCH</b>	Pressure (PSIA)	14.7
Manufacturer: <b>BARKSDALE</b>	Relative Humidity (%)	100
Model Number: <b>B2T-M1255-GE</b>	Chemical Spray	NA
Purchase Order Number: <b>GE 209A4965P1</b>	Radiation (Rad)	2.1 E06
Function/Service: <b>PERMISSIVE FOR LPCI LOOP SELECTION DELAY</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-8 COLUMNS 45 & K Elevation 517'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 372  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.1 E06	Radiation (Rad)	2.1 E06
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.1 E06	Radiation (Rad)	2.1 E06
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 373  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: <b>SEE ATTACHED SHEETS</b> Component: <b>PRESSURE TRANSMITTER</b>  Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number: <b>GE/MAC 551</b> <b>CAT # 50-55-1032GAAH1</b> Purchase Order Number: <b>SEE ATTACHED SHEETS</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b> Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			
	Temperature (°F)	242	212	REF. (A)	REF. (B)		SEE NOTE (1)
	Pressure (PSIA)	27.0		REF. (A)			
	Relative Humidity (%)	100	95	REF. (A)	REF. (B)		SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	7.0 E04		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO. 37, REV 1, FEB 1975. B. DV1453006-QUALIFICATION DESIGN VERIFICATION FILE GE/MAC 551 C. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 374  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PT-3-647A</b>	Temperature (°F)	103
Component: <b>PRESSURE TRANSMITTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: GE/MAC 551 CAT # 50-55-1032GAAH1	Chemical Spray	NA
Purchase Order Number: GE H1158	Radiation (Rad)	7.0 EO4
Function/Service: <b>REACTOR VESSEL PRESSURE INDICATION</b>	Aging	NOT REQD.
Accuracy: Spec: Demo: Location RACK 2203-5 COLUMNS 49 & K Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	CONTINUOUS
Plant I.D. Number: <b>PT-3-647B</b>	Temperature (°F)	242
Component: <b>PRESSURE TRANSMITTER</b>	Pressure (PSIA)	27.0
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number: GE/MAC 551 CAT # 50-55-1032GAAH1	Chemical Spray	NA
Purchase Order Number: GE H1158	Radiation (Rad)	3.4 EO4
Function/Service: <b>REACTOR VESSEL PRESSURE INDICATION</b>	Aging	
Accuracy: Spec: Demo: Location RACK 2203-6 COLUMNS 48 & M Elevation 545'6"	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 375  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
<b>System:</b> <b>REACTOR RECIRCULATION</b>	
Plant I.D. Number: <b>PT-3-662</b>	
Component: <b>PRESSURE TRANSMITTER</b>	
Manufacturer: <b>GENERAL ELECTRIC</b>	
Model Number: <b>GE/MAC 551</b>	
CAT # 50-55-1032GAAH1	
Purchase Order Number: <b>GE 120-1991</b>	
Function/Service: <b>REACTOR VESSEL</b>	
<b>PRESSURE INDICATION</b>	
Accuracy:	Spec:
Location	Demo:
RACK 2203-6	
COLUMNS 47 & M	
Elevation	
545' 6"	
Flood Level	
Elevation: NA	
Above Flood Level:	
Yes:	No:

ENVIRONMENT	
Parameter	FSAR
Operating Time	CONTINUOUS
Temperature (°F)	242
Pressure (PSIA)	27.0
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	3.4 EO4
Aging	
Submergence	NA

EQUIPMENT DESCRIPTION	
System:	
Plant I.D. Number:	
Component:	
Manufacturer:	
Model Number:	
Purchase Order Number:	
Function/Service:	
Accuracy:	Spec:
Location	Demo:
Elevation	
Flood Level	
Elevation:	
Above Flood Level:	
Yes:	No:

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 376  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: MO-3-202-4A&B Component: <b>MOTOR OPERATED VALVE</b> Manufacturer:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA		
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT MANUFACTURER, LOCATION & MODEL NUMBER. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 377  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)		Temperature (°F)	
Pressure (PSIA)		Pressure (PSIA)	
Relative Humidity (%)		Relative Humidity (%)	
Chemical Spray		Chemical Spray	
Radiation (Rad)		Radiation (Rad)	
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level			
Elevation: NA			
Above Flood Level:			
Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)		Temperature (°F)	
Pressure (PSIA)		Pressure (PSIA)	
Relative Humidity (%)		Relative Humidity (%)	
Chemical Spray		Chemical Spray	
Radiation (Rad)		Radiation (Rad)	
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level			
Elevation: NA			
Above Flood Level:			
Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 378  
 Revision O  
 Date 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: MO-3-202-5A&B Component: <b>MOTOR OPERATED VALVE</b> Manufacturer:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT MANUFACTURER, LOCATION & MODEL NUMBER. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 379  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)		Temperature (°F)	
Pressure (PSIA)		Pressure (PSIA)	
Relative Humidity (%)		Relative Humidity (%)	
Chemical Spray		Chemical Spray	
Radiation (Rad)		Radiation (Rad)	
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: - No:		Flood Level Elevation: NA Above Flood Level: Yes: - No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time		Operating Time	
Temperature (°F)		Temperature (°F)	
Pressure (PSIA)		Pressure (PSIA)	
Relative Humidity (%)		Relative Humidity (%)	
Chemical Spray		Chemical Spray	
Radiation (Rad)		Radiation (Rad)	
Aging		Aging	
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: - No:		Flood Level Elevation: NA Above Flood Level: Yes: - No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 380  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>  Plant I.D. Number: MO-3-202-6A&B Component: <b>MOTOR OPERATED VALVE</b> Manufacturer:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT MANUFACTURER, LOCATION & MODEL NUMBER. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 381  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
<b>System:</b> <b>REACTOR RECIRCULATION</b>		Operating Time	
Plant I.D. Number: MO-3-202-6A		Temperature (°F)	
Component: <b>MOTOR OPERATED VALVE</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	NA
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
<b>System:</b> <b>REACTOR RECIRCULATION</b>		Operating Time	
Plant I.D. Number: MO-3-202-6B		Temperature (°F)	
Component: <b>MOTOR OPERATED VALVE</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: Demo: Location		Submergence	NA
Elevation		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 382  
 Revision 0  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: MO-3-202-7A&B	Temperature (°F)						SEE NOTE (1)
Component: <b>MOTOR OPERATED VALVE</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. DETERMINE EQUIPMENT MANUFACTURER, LOCATION &amp; MODEL NUMBER. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 383  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: MO-3-202-7A	Temperature (°F)	
Component: <b>MOTOR OPERATED VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: MO-3-202-7B	Temperature (°F)	
Component: <b>MOTOR OPERATED VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 384  
 Revision O  
 Date 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: MO-3-202-9A&B	Temperature (°F)						SEE NOTE (1)
Component: <b>MOTOR OPERATED VALVE</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	SEE NOTE (1)
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT MANUFACTURER, LOCATION & MODEL NUMBER. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 385  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: MO-3-202-9A	Temperature (°F)	
Component: <b>MOTOR OPERATED VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: MO-3-202-9B	Temperature (°F)	
Component: <b>MOTOR OPERATED VALVE</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Demo: Location	Submergence	NA
Elevation		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

Component Sheet No: 386  
Revision O  
Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>DPIS-3-261-34A,B,C,D</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT MANUFACTURER, LOCATION & MODEL NUMBER. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 387  
 Revision 0  
 Date: 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-34A</b>	Temperature (°F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-34B</b>	Temperature (°F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 388  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-34C</b>	Temperature (°F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-34D</b>	Temperature (°F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Elevation		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 389  
 Revision O  
 Date 04-17-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>DPIS-3-261-35A-H</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence	NA	NA	NA	NA	NA	
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level: Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT MANUFACTURER, LOCATION & MODEL NUMBER. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 390  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-35A</b>	Temperature ("F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Elevation		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-35B</b>	Temperature ("F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Elevation		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 391  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:	REACTOR RECIRCULATION	Operating Time	
Plant I.D. Number:	DPIS-3-261-35C	Temperature (°F)	
Component:	DIFFERENTIAL PRESSURE INDICATING SWITCH	Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy:	Spec: Demo:	Submergence	NA
Location			
Elevation			
Flood Level			
Elevation:	NA		
Above Flood Level:			
Yes:	No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:	REACTOR RECIRCULATION	Operating Time	
Plant I.D. Number:	DPIS-3-261-35D	Temperature (°F)	
Component:	DIFFERENTIAL PRESSURE INDICATING SWITCH	Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy:	Spec: Demo:	Submergence	NA
Location			
Elevation			
Flood Level			
Elevation:	NA		
Above Flood Level:			
Yes:	No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 392  
 Revision O  
 Date: 04-17-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-35E</b>	Temperature (°F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>REACTOR RECIRCULATION</b>	Operating Time	
Plant I.D. Number: <b>DPIS-3-261-35F</b>	Temperature (°F)	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	NA
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 393  
 Revision 0  
 Date: 04-17-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time			
Temperature (°F)			
Pressure (PSIA)			
Relative Humidity (%)			
Chemical Spray			
Radiation (Rad)			
Aging			
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR		
Operating Time			
Temperature (°F)			
Pressure (PSIA)			
Relative Humidity (%)			
Chemical Spray			
Radiation (Rad)			
Aging			
Submergence	NA		
Flood Level Elevation: NA Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 394  
 Revision  
 Date - -

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR RECIRCULATION</b>	Operating Time	1 MINUTE		REF. (A)			SEE NOTE (1)
	Temperature (°F)	NORMAL 150 LOCA 281		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (1)
	Radiation (Rad)			REF. (D)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: 505' 6" Above Flood Level: Yes: X No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5. B. FSAR FIGURES 5.2.11 & 5.2.12 C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 395  
 Revision 0  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PROCESS RADIATION MONITORING</b>  Plant I.D. Number: <b>RE-3-1734A-D</b> Component: <b>RADIATION ELEMENT ION CHAMBER</b> Manufacturer: <b>GENERAL ELECTRIC</b>  Model Number:  Purchase Order Number: <b>GE 120-1917 MANUAL GEK-786</b> Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b> Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	10 MINUTES		REF. (A)			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 242		REF. (B)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 27.0		REF. (B)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (B)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.8 EO4		REF. (C)			SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. THESE MONITORS ARE PROVIDED TO DETECT AN ABNORMAL CONDITION WHICH RESULTS IN HIGH STEAM LINE RADIATION THE HIGH RADIATION WOULD BE DETECTED IMMEDIATELY. TEN MINUTES IS CONSERVATIVELY ASSUMED. B. FSAR SECTION 10.11 AND SPECIAL REPORT NO. 37 REV. 1 FEB. 1975	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.
	0858-01

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 396  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. BECHTEL RADIATION STUDY	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 397  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PROCESS RADIATION MONITORING</b>	Operating Time	10 MINUTES
Plant I.D. Number: <b>RE-3-1734A</b>	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>RADIATION ELEMENT ION CHAMBER</b>	Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 120-1917</b>	Radiation (Rad)	1.8 E04
Function/Service: <b>MAIN STEAM LINE A RADIATION MONITORING</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location: <b>STEAM TUNNEL</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PROCESS RADIATION MONITORING</b>	Operating Time	10 MINUTES
Plant I.D. Number: <b>RE-3-1734B</b>	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>RADIATION ELEMENT ION CHAMBER</b>	Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 120-1917</b>	Radiation (Rad)	1.8 E04
Function/Service: <b>MAIN STEAM LINE D RADIATION MONITORING</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location: <b>STEAM TUNNEL</b>	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 398  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PROCESS RADIATION MONITORING</b>	Operating Time	10 MINUTES
Plant I.D. Number: <b>RE-3-1734C</b>	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>RADIATION ELEMENT ION CHAMBER</b>	Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 120-1917</b> <b>MANUAL GEK-786</b>	Radiation (Rad)	1.8 EO4
Function/Service: <b>MAIN STEAM LINE RADIATION MONITORING</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location <b>STEAM TUNNEL</b>		
Elevation <b>529' 6"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PROCESS RADIATION MONITORING</b>	Operating Time	10 MINUTES
Plant I.D. Number: <b>RE-3-1734D</b>	Temperature (°F)	NORMAL 120 HELB 242
Component: <b>RADIATION ELEMENT ION CHAMBER</b>	Pressure (PSIA)	NORMAL 14.7 HELB 27.0
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 120-1917</b> <b>MANUAL GEK-786</b>	Radiation (Rad)	1.8 EO4
Function/Service: <b>MAIN STEAM LINE C RAD</b>	Aging	
Accuracy: Spec: Demo:	Submergence	NA
Location <b>STEAM TUNNEL</b>		
Elevation <b>529' 6"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 399  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>PROCESS RADIATION MONITORING</b>	Operating Time	10 MINUTES	NOT REQD.	REF. (A)	NOT REQD.		
Plant I.D. Number: RE-3-1735A,B	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
Component: <b>RADIATION ELEMENT SENSOR AND CONVERTER</b>	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number: GE-120-1917 MANUAL GEK-802-D	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence	NA	NA	NA	NA	NA	
Elevation: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. THESE MONITORS USED TO DETECT THE RELEASE OF RADIOACTIVE MATERIAL. THIS VENTILATION SYSTEM IS ISOLATED FOLLOWING AN ACCIDENT AND THE STANDBY GAS TREATMENT SYSTEM UTILIZED. EQUIPMENT WOULD THEREFORE ONLY BE REQUIRED TO FUNCTION UNTIL STANDBY GAS TREATMENT SYSTEM START. REFERENCE FSAR FIGURE 8.2.5 FOR START TIME.	

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 400  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 401  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PROCESS RADIATION MONITORING</b>	Operating Time	
Plant I.D. Number: <b>RE-3-1735A</b>	Temperature (°F)	103
Component: <b>RADIATION ELEMENT SENSOR AND CONVERTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 120-1917</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>MANUAL GEK-802-D</b>	Aging	NOT REQD.
Function/Service: <b>REACTOR BLDG VENTILATION RADIATION MONITORING</b>	Submergence	NA
Accuracy: Spec: Demo:		
Location <b>BETWEEN COL. 39 &amp; 40</b>		
<b>BETWEEN COL. J &amp; K</b>		
Elevation <b>570'0"</b>		
Flood Level Elevation: NA		
Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>PROCESS RADIATION MONITORING</b>	Operating Time	
Plant I.D. Number: <b>RE-3-1735B</b>	Temperature (°F)	103
Component: <b>RADIATION ELEMENT SENSOR AND CONVERTER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GENERAL ELECTRIC</b>	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: <b>GE 120-1917</b>	Radiation (Rad)	<1.0 E04
Function/Service: <b>MANUAL GEK-802-D</b>	Aging	NOT REQD.
Function/Service: <b>REACTOR BLDG VENTILATION RADIATION MONITORING</b>	Submergence	NA
Accuracy: Spec: Demo:		
Location <b>VENTILATION ROOM</b>		
<b>REACTOR BUILDING</b>		
Elevation <b>570'0"</b>		
Flood Level Elevation: NA		
Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 402  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR BLDG VENTILATION</b>  Plant I.D. Number: <b>AO-3-5741A.B</b> Component: <b>SOLENOID VALVE</b>  Manufacturer: <b>VERSA</b>  Model Number:  Purchase Order Number:  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 403  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: REACTOR BLDG VENTILATION	Operating Time	1 MINUTE
Plant I.D. Number: AO-3-5741A	Temperature (°F)	103
Component: SOLENOID VALVE	Pressure (PSIA)	14.7
Manufacturer: VERSA	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: AIR SUPPLY CONTROL FOR AO-3-5741-A	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location VENTILATION ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: REACTOR BLDG VENTILATION	Operating Time	1 MINUTE
Plant I.D. Number: AO-3-5741B	Temperature (°F)	103
Component: SOLENOID VALVE	Pressure (PSIA)	14.7
Manufacturer: VERSA	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: AIR SUPPLY CONTROL FOR AO-3-5741-B	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location VENTILATION ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 404  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>REACTOR BLDG VENTILATION</b>  Plant I.D. Number: AO-3-5742A,B Component: <b>SOLENOID VALVE</b>  Manufacturer: VERSA  Model Number: VGS-4422  Purchase Order Number:  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy; Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11. C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 405  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: REACTOR BLDG VENTILATION	Operating Time	1 MINUTE
Plant I.D. Number: AO-3-5742-A	Temperature (°F)	103
Component: SOLENOID VALVE	Pressure (PSIA)	14.7
Manufacturer: VERSA	Relative Humidity (%)	100
Model Number: VGS-4422	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: AIR SUPPLY CONTROL FOR AO-3-5742-A	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location VENTILATION ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: REACTOR BLDG VENTILATION	Operating Time	1 MINUTE
Plant I.D. Number: AO-3-5742-B	Temperature (°F)	103
Component: SOLENOID VALVE	Pressure (PSIA)	14.7
Manufacturer: VERSA	Relative Humidity (%)	100
Model Number: VGS-4422	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: AIR SUPPLY CONTROL FOR AO-3-5742-B	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location VENTILATION ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 406  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM, OFFICE & DRYWELL HVAC  Plant I.D. Number: 2/3-5772-100 Component: ISOLATION DAMPER AND SOLENOID VALVES(2) Manufacturer: JOHNSON SERVICE  Model Number: V6183  Purchase Order Number:  Function/Service: DIESEL GENERATOR ROOM FIRE DAMPER  Accuracy: Spec: NA Demo: NA Location: UNIT 2/3 DG ROOM  Elevation: 527'0"  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	30 DAYS	NOT REQD.	REF. (A)	NOT REQD.		SEE NOTE (1)
	Temperature (°F)	120	NOT REQD.	REF. (B)	NOT REQD.		SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. THIS EQUIPMENT REQUIRED FOR THE DURATION OF A LOSS OF OFFSITE POWER. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS. B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 407  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM, OFFICE, & DRYWELL HVAC	Operating Time	30 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. THIS EQUIPMENT REQUIRED FOR THE DURATION OF A LOSS OF OFFSITE POWER. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS. B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 408  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROOM, OFFICE, &amp; DRYWELL HVAC</b>  Plant I.D. Number: <b>2/3-5772-101</b> Component: <b>ISOLATION DAMPER AND SOLENOID VALVES(2)</b> Manufacturer: <b>JOHNSON SERVICE</b>  Model Number: <b>V6183 32280</b> Purchase Order Number:  Function/Service: <b>DIESEL GENERATOR ROOM FIRE DAMPER</b>  Accuracy: Spec: NA Demo: NA Location: <b>UNIT 2/3 DG ROOM</b>  Elevation: <b>517'6"</b>	Operating Time	30 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. THIS EQUIPMENT REQUIRED FOR THE DURATION OF A LOSS OF OFFSITE POWER. IT IS ASSUMED OFFSITE POWER CAN BE RESTORED WITHIN 30 DAYS. B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 409  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROOM OFFICE DRYWELL HVAC</b>  Plant I.D. Number: 2/3-5731 Component: <b>SUPPLY AIR FAN</b>  Manufacturer: <b>BUFFALO FORGE</b>  Model Number: 250 PCM SHIP# 68K3684 Purchase Order Number: 3447-178 SPEC K-2259 Function/Service: <b>AIR SUPPLY TO COMPUTER ROOM AND CONTROL ROOM</b>  Accuracy: Spec: Demo: Location: <b>ABOVE CONTROL ROOM</b>  Elevation: 551'0"	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (A)	NOT REQD.		
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. BECHTEL RADIATION STUDY	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 410  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROOM, OFFICE DRYWELL HVAC</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (A)	NOT REQD.		
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. BECHTEL RADIATION STUDY	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 411  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM OFFICE DRYWELL HVAC	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04		REF. (A)			
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. BECHTEL RADIATION STUDY	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 412  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM, OFFICE, & DRYWELL HVAC	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 EO4	NOT REQD.	REF. (A)	NOT REQD.		
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. BECHTEL RADIATION STUDY	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 413  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROOM, OFFICE, &amp; DRYWELL HVAC</b>	Operating Time	30 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (C)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. THE DIESEL ROOM FAN WILL BE REQUIRED UNTIL OFFSITE POWER CAN BE RESTORED AFTER A LOSS OF OFFSITE POWER. THIS IS ASSUMED TO BE 30 DAYS. B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 414  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM, OFFICE, & DRYWELL HVAC	Operating Time	CONTINUOUS		NA			
Plant I.D. Number: SEE ATTACHED SHEETS	Temperature (°F)						SEE NOTE (1)
Component: COMPRESSOR	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:							
Purchase Order Number:							
Function/Service: SEE ATTACHED SHEETS	Chemical Spray	NA	NA	NA	NA	NA	
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (A)	NOT REQD.		
Elevation: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. BECHTEL RADIATION STUDY	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 415  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: CONTROL ROOM, OFFICE, DRYWELL HVAC	Operating Time	CONTINUOUS
Plant I.D. Number: 2/3-2A	Temperature (°F)	
Component: COMPRESSOR	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: CONTROL ROOM AIR CONDITIONING	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location ABOVE CONTROL ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: CONTROL ROOM, OFFICE, DRYWELL HVAC	Operating Time	CONTINUOUS
Plant I.D. Number: 2/3-2B	Temperature (°F)	
Component: COMPRESSOR	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: CONTROL ROOM AIR CONDITIONING	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location ABOVE CONTROL ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 416  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM, OFFICE, & DRYWELL HVAC	Operating Time						SEE NOTE (1)
Plant I.D. Number: 213-5772-62	Temperature (°F)						SEE NOTE (1)
Component: DAMPER	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	NA
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: ON MIXING BOX 5731	Submergence	NA	NA	NA	NA	NA	NA
Elevation: 545'0"							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION & ESTABLISH DETERMINE EQUIPMENT LOCATION AND ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 417  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM OFFICE & DRYWELL HVAC	Operating Time						SEE NOTE (1)
Plant I.D. Number: SE-2/3-8941-013	Temperature (°F)						SEE NOTE (1)
Component: SMOKE DETECTOR	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Location: Demo:	Submergence	NA	NA	NA	NA	NA	
Elevation:	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION & ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 418  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: CONTROL ROOM OFFICE & DRYWELL HVAC	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION & ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 419  
 Revision  
 Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>CONTROL ROOM OFFICE &amp; DRYWELL HVAC</b>  Plant I.D. Number: SO-2/3-9441-004 Component: <b>SOLENOID VALVE</b>  Manufacturer:  Model Number:  Purchase Order Number:  Function/Service:  Accuracy: Spec: Location: Demo:  Elevation:  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
	1. DETERMINE EQUIPMENT LOCATION & ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 420  
 Revision 0  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY AC POWER</b>  Plant I.D. Number: 2/3 & 3-5209 Component: <b>STANDBY DIESEL GENERATOR</b> Manufacturer: <b>GENERAL MOTORS</b>  Model Number: <b>A-20-C1</b>  Purchase Order Number: <b>3447-132</b> <b>SPEC K2183</b> Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 EO4	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT NO 37, REV 1, FEB 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 421  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
<b>System:</b> STANDBY AC POWER		<b>ENVIRONMENT</b>
Plant I.D. Number: 3-5209	Parameter	FSAR
Component: STANDBY DIESEL GENERATOR	Operating Time	CONTINUOUS
Manufacturer: GENERAL MOTORS	Temperature (°F)	NORMAL 120 HELB 213
Model Number: A-20-C1	Pressure (PSIA)	NORMAL 14.7 HELB 14.9
Purchase Order Number: 3447-132 SPEC K2183	Relative Humidity (%)	100
Function/Service: PROVIDE AC POWER DURING LOSS OF OFFSITE POWER	Chemical Spray	NA
Accuracy: Spec: NA Demo: NA	Radiation (Rad)	<1.0 EO4
Location 10'0"N OF COL H 8'0"W OF COL 34 Elevation 517'6"	Aging	NOT REQD.
Flood Level Elevation: NA Above Flood Level: Yes: No:	Submergence	NA

ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	NORMAL 120 HELB 213	
Pressure (PSIA)	NORMAL 14.7 HELB 14.9	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0 EO4	
Aging	NOT REQD.	
Submergence	NA	

EQUIPMENT DESCRIPTION		
<b>System:</b> STANDBY AC POWER		<b>ENVIRONMENT</b>
Plant I.D. Number: 2/3-5209	Parameter	FSAR
Component: STANDBY DIESEL GENERATOR	Operating Time	CONTINUOUS
Manufacturer: GENERAL MOTORS	Temperature (°F)	120
Model Number: A-20-C1	Pressure (PSIA)	14.7
Purchase Order Number: 3447-132 SPEC K2183	Relative Humidity (%)	100
Function/Service: PROVIDE AC POWER DURING LOSS OF OFFSITE POWER	Chemical Spray	NA
Accuracy: Spec: NA Demo: NA	Radiation (Rad)	<1.0 EO4
Location 50'0"S OF COL N ON COL 45 Elevation 517'6"	Aging	NOT REQD.
Flood Level Elevation: NA Above Flood Level: Yes: No:	Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 422  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY AC POWER</b>  Plant I.D. Number: SWGR 33-1, SWGR 34-1 Component: <b>4.16 KV SWITCHGEAR</b>  Manufacturer: <b>GENERAL ELECTRIC</b> NPO195A4072 Model Number: <b>MAGNEBLAST BREAKERS</b> TYPE AMH 4.76-250 Purchase Order Number:  Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	1.1 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 423  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT		EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR		Parameter	FSAR
System: <b>STANDBY AC POWER</b>	Operating Time	CONTINUOUS	System: <b>STANDBY AC POWER</b>	Operating Time	CONTINUOUS
Plant I.D. Number: SWGR 33-1	Temperature (°F)	103		Temperature (°F)	103
Component: 4.16 KV SWITCHGEAR	Pressure (PSIA)	14.7		Pressure (PSIA)	14.7
Manufacturer: GENERAL ELECTRIC NPO195A4072	Relative Humidity (%)	100		Relative Humidity (%)	100
Model Number: MAGNEBLAST BREAKERS TYPE AMH 4.76-250	Chemical Spray	NA		Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	5.0 EO5		Radiation (Rad)	1.1 EO6
Function/Service: <b>POWER DISTRIBUTION</b>	Aging	NOT REQD.		Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA		Submergence	NA
Location BETWEEN COL 47 & 48 BETWEEN COL M & N Elevation 545'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:			Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 424  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER  Plant I.D. Number: SWGR 38 & 39 Component: 480 V SWITCHGEAR  Manufacturer: GENERAL ELECTRIC  Model Number: TYPE AKD5  Purchase Order Number:  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.0 E04		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 425  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: SWGR 38	Temperature (°F)	103
Component: 480 V SWITCHGEAR	Pressure (PSIA)	14.7
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100
Model Number: TYPE AKD5	Chemical Spray	NA
Purchase Order Number: REQ NO.291-57145-A	Radiation (Rad)	3.0 E04
Function/Service: POWER DISTRIBUTION	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location: BETWEEN COL 46&47 BETWEEN COL M&N Elevation 570'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: SWGR 39	Temperature (°F)	103
Component: 480 V SWITCHGEAR	Pressure (PSIA)	14.7
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100
Model Number: TYPE AKD5	Chemical Spray	NA
Purchase Order Number: REQ NO.391-2305-8 391-571458A	Radiation (Rad)	<1.0 E04
Function/Service: POWER DISTRIBUTION	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location: BETWEEN COL 46&47 BETWEEN COL M&N Elevation 570'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 426  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER  Plant I.D. Number: SEE ATTACHED SHEETS Component: 480 V MCC  Manufacturer: GENERAL ELECTRIC  Model Number: 7700  Purchase Order Number:  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7		REF. (A)			
	Relative Humidity (%)	100		REF. (A)			
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	2.0 E06		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10, 11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 427  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: MCC 38-1	Temperature (°F)	103
Component: 480 V MCC	Pressure (PSIA)	14.7
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100
Model Number: 7700	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	2.0 E06
Function/Service: POWER DISTRIBUTION	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location BETWEEN COL M&N BETWEEN COL 49&50		
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: MCC 38-2	Temperature (°F)	120
Component: 480 V MCC	Pressure (PSIA)	14.7
Manufacturer: GENERAL ELECTRIC	Relative Humidity (%)	100
Model Number: 7700	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04
Function/Service: POWER DISTRIBUTION	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location BETWEEN COL F&G BETWEEN COL 52&53		
Elevation 538'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 428  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY AC POWER</b>	Operating Time	CONTINUOUS
	Temperature (°F)	120
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	3.6 E05
	Aging	NOT REQD.
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY AC POWER</b>	Operating Time	CONTINUOUS
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	3.6 E05
	Aging	NOT REQD.
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 429  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	2.0 EO6	Radiation (Rad)	<1.0 EO4
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	100
Pressure (PSIA)	14.7	Pressure (PSIA)	NA
Relative Humidity (%)	100	Relative Humidity (%)	NA
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 EO4	Radiation (Rad)	NA
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 430  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY AC POWER</b>  Plant I.D. Number: MCC 39-3 Component: 480 V MCC  Manufacturer: GENERAL ELECTRIC  Model Number: 7700  Purchase Order Number:  Function/Service: <b>POWER DISTRIBUTION</b>  Accuracy: Spec: NA Demo: NA Location BETWEEN COL L & M BETWEEN COL 46 & 47 Elevation 570'0"	Operating Time	CONTINUOUS
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	6.1 E05
	Aging	NOT REQD.
	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY AC POWER</b>  Plant I.D. Number: MCC 39-4 Component: 480 V MCC  Manufacturer: GENERAL ELECTRIC  Model Number: 7700  Purchase Order Number:  Function/Service: <b>POWER DISTRIBUTION</b>  Accuracy: Spec: NA Demo: NA Location BETWEEN COL 44&45 BETWEEN COL L&M Elevation 517'6"  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	CONTINUOUS
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	9.7 E05
	Aging	NOT REQD.
	Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 431  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
System: STANDBY AC POWER		
Plant I.D. Number: MCC 39-7		
Component: 480 V MCC		
Manufacturer: GENERAL ELECTRIC		
Model Number: 7700		
Purchase Order Number:		
Function/Service: POWER DISTRIBUTION		
Accuracy:	Spec:	NA
Demo:		NA
Location BETWEEN COL M&N BETWEEN COL 47&48		
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	103	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	1.5 E06	
Aging	NOT REQD.	
Submergence	NA	

EQUIPMENT DESCRIPTION		
System:		
Plant I.D. Number:		
Component:		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service:		
Accuracy:	Spec:	
Demo:		
Location		
Elevation		
Flood Level Elevation: Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 432  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER  Plant I.D. Number: SEE ATTACHED SHEETS Component: 120/208 V DISTRIBUTION PANEL Manufacturer:	Operating Time						
	Temperature (°F)						
	Pressure (PSIA)						
	Relative Humidity (%)						
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)						
	Aging						
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 433  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	
Plant I.D. Number: DP 28-1	Temperature (°F)	
Component: 120/208 V DISTRIBUTION PANEL	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: POWER DISTRIBUTION	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location IN MCC 28-1 NEAR COL L AND COL 38 Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	
Plant I.D. Number: DP 28-2	Temperature (°F)	
Component: 120/208 V DISTRIBUTION PANEL	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: POWER DISTRIBUTION	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location IN MCC 28-2 NEAR COL F AND COL 35 Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 434  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY AC POWER</b>	Operating Time	
Plant I.D. Number: DP 29-1	Temperature (°F)	
Component: 120/208 V	Pressure (PSIA)	
<b>DISTRIBUTION PANEL</b> Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>POWER DISTRIBUTION</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location MCC 29-1 NEAR COL 43 AND COL K Elevation 517'6"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY AC POWER</b>	Operating Time	
Plant I.D. Number: DP 29-3	Temperature (°F)	
Component: 120/208 V	Pressure (PSIA)	
<b>DISTRIBUTION PANEL</b> Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service: <b>POWER DISTRIBUTION</b>	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location MCC 29-3 NEAR COL L AND COL 41 Elevation 570'0"	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 435  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
Plant I.D. Number: RPS BUS 1&2	Temperature (°F)	213		REF. (A)			SEE NOTE (1)
Component: 120 V REACTOR PROTECTION SYSTEM BUS	Pressure (PSIA)	14.9		REF. (A)			SEE NOTE (1)
Manufacturer:	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
Model Number:	Chemical Spray	NA	NA	NA	NA	NA	NA
Purchase Order Number:	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
Function/Service: SEE ATTACHED SHEETS	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS	Submergence	NA	NA	NA	NA	NA	NA
Elevation: SEE ATTACHED SHEETS	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975 B. BECHTEL RADIATION STUDY	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 436  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:  Plant I.D. Number:  Component: 120 V REACTOR PROTECTION SYSTEM BUS Manufacturer:	Operating Time	
	Temperature (°F)	
	Pressure (PSIA)	
	Relative Humidity (%)	
	Chemical Spray	
	Radiation (Rad)	
	Aging	
	Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:  Plant I.D. Number: RPS BUS 2B Component: 120 V REACTOR PROTECTION SYSTEM BUS Manufacturer:	Operating Time	CONTINUOUS
	Temperature (°F)	213
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	
	Radiation (Rad)	<1.0 EO4
	Aging	
	Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 437  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY AC POWER</b>  Plant I.D. Number: <b>ESSENTIAL SERVICE BUS</b> Component: <b>120/240 V AC</b> <b>ESSENTIAL SERVICE BUS</b> Manufacturer: <b>CUTLER HAMMER UNITROL</b>  Model Number: <b>WESTINGHOUSE BREAKERS</b>  Purchase Order Number:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO. 37, REV 1, FEB 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 438  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY AC POWER</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, FEB 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 439  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
<b>System:</b> <b>STANDBY AC POWER</b>  <b>Plant I.D. Number:</b> <b>ESSENTIAL BUS MMG SET</b> <b>Component:</b> <b>120/240 V AC</b> <b>ESSENTIAL BUS SUPPLY</b> <b>Manufacturer:</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. SPECIAL REPORT NO 37, REV 1, 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 440  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY AC POWER</b>  Plant I.D. Number: <b>SEE ATTACHED SHEETS</b> Component: <b>DIESEL GENERATOR EXCITATION CABINET</b> Manufacturer: <b>VICKERS INC</b>  Model Number: <b>35 D 870-2</b>  Purchase Order Number:  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 147 HELB 14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 441  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	NORMAL 120 HELB 213	Temperature (°F)	103
Pressure (PSIA)	NORMAL 14.7 HELB 14.9	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 E04	Radiation (Rad)	<1.0 E04
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	103	Temperature (°F)	103
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 E04	Radiation (Rad)	<1.0 E04
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 442  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER  Plant I.D. Number: SEE ATTACHED SHEETS Component: DIESEL GENERATOR ENGINE CONTROL PANEL Manufacturer: GENERAL MOTORS  Model Number: S20 E4GW  Purchase Order Number:  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 443  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: NONE	Temperature (°F)	NORMAL 120 HELB 213
Component: DIESEL GENERATOR ENGINE CONTROL PANEL	Pressure (PSIA)	NORMAL 14.7 HELB 14.9
Manufacturer: GENERAL MOTORS	Relative Humidity (%)	100
Model Number: S20 E4GW	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 EO4
Function/Service: DIESEL ENGINE CONTROL	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location DIESEL ROOM 3		
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: NONE	Temperature (°F)	103
Component: DIESEL GENERATOR ENGINE CONTROL PANEL	Pressure (PSIA)	14.7
Manufacturer: GENERAL MOTORS	Relative Humidity (%)	100
Model Number: S20 E4GW	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 EO4
Function/Service: DIESEL ENGINE CONTROL	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location DIESEL ROOM 2/3		
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 444  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER  Plant I.D. Number: SEE ATTACHED SHEETS Component: DIESEL GENERATOR SPEED SENSING PANEL Manufacturer: GENERAL MOTORS  Model Number: S20 E4GW  Purchase Order Number:  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submersion	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 445  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: NONE	Temperature (°F)	NORMAL 120 HELB 213
Component: DIESEL GENERATOR SPEED SENSING PANEL	Pressure (PSIA)	NORMAL 14.7 HELB 14.9
Manufacturer: GENERAL MOTORS	Relative Humidity (%)	100
Model Number: S20 E4GW	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 EO4
Function/Service: DIESEL ENGINE SPEED SENSING	Aging	NOT REOD.
Accuracy: Spec: Demo: Location DIESEL ROOM 3	Submergence	NA
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: NONE	Temperature (°F)	103
Component: DIESEL GENERATOR SPEED SENSING PANEL	Pressure (PSIA)	14.7
Manufacturer: GENERAL MOTORS	Relative Humidity (%)	100
Model Number: S20 E4GW	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 EO4
Function/Service: DIESEL ENGINE SPEED SENSING	Aging	NOT REOD.
Accuracy: Spec: Demo: Location DIESEL ROOM 2/3	Submergence	NA
Elevation 517'6"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 446  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER  Plant I.D. Number: SEE ATTACHED SHEETS Component: DIESEL GENERATOR RELAY AND METER PANEL Manufacturer:  Model Number:  Purchase Order Number:  Function/Service: SEE ATTACHED SHEETS  Accuracy: Spec: Demo: Location: SEE ATTACHED SHEETS  Elevation: SEE ATTACHED SHEETS  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	NORMAL 120 HELB 213		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (A)			SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR PARAGRAPH 10.11 AND SPECIAL REPORT 37, REV 1, FEB, 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. THIS EQUIPMENT MAY BE SUBJECTED TO A HARSH ENVIRONMENT DUE TO A FEEDWATER LINE BREAK. THIS IS UNDER REVIEW BY THE NRC AS PART OF THE PIPE BREAK OUTSIDE CONTAINMENT EVALUATION AND ACTION TAKEN TO RESOLVE THE FEEDWATER PIPE BREAK WILL RESOLVE THE HARSH ENVIRONMENT DUE TO HELB.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 447  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: NONE	Temperature (°F)	NORMAL 120 HELB 213
Component: DIESEL GENERATOR RELAY AND METER PANEL	Pressure (PSIA)	NORMAL 14.7 HELB 15
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: SERIAL NO. 265673	Radiation (Rad)	<1.0 EO4
Function/Service: DG 2 PROTECTIVE RELAY AND LOCAL METERING	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location DIESEL ROOM 3	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: CAB-2223-33	Temperature (°F)	103
Component: DIESEL GENERATOR RELAY AND METER PANEL	Pressure (PSIA)	14.7
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number: SERIAL NO. 265674	Radiation (Rad)	<1.0 EO4
Function/Service: DG 2/3 PROTECTIVE RELAY AND LOCAL METERING	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location DIESEL ROOM 2/3	Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 448  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY AC POWER  Plant I.D. Number: NONE Component: 4KV NON-SEGREGATED PHASE BUS Manufacturer:	Operating Time	CONTINUOUS		NA			
	Temperature (°F)	NORMAL 120 HELB 213		REF. (A)			
	Pressure (PSIA)	NORMAL 14.7 HELB 14.9		REF. (A)			
	Relative Humidity (%)	100		REF. (A)			
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT NO 37, REV 1, FEB 1975 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 449  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: NONE	Temperature (°F)	NORMAL 120 HELB 213
Component: 4KV NON-SEGREGATED PHASE BUS	Pressure (PSIA)	NORMAL 14.7 HELB 14.9
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 EO4
Function/Service: CONNECTS DG 2 TO 4.16 KV SWGR	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location DIESEL ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 517' 6"		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY AC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: NONE	Temperature (°F)	NORMAL 120 HELB 213
Component: 4KV NON-SEGREGATED PHASE BUS	Pressure (PSIA)	NORMAL 14.7 HELB 14.9
Manufacturer:	Relative Humidity (%)	100
Model Number:	Chemical Spray	NA
Purchase Order Number:	Radiation (Rad)	<1.0 EO4
Function/Service: CONNECTS DG 2/3 TO 4.16 KV SWGR	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location DIESEL ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 517' 6"		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 450  
 Revision 0  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: <b>250 V BATT CHGR 3</b> Component: <b>250 V BATTERY CHARGER</b>  Manufacturer: <b>GOULD</b>  Model Number: <b>GRF240T100X</b>  Purchase Order Number: <b>3447-146</b> <b>SPEC K2212</b> Function/Service: <b>CHARGE 250V BATTERY</b> <b>AND PROVIDE DC POWER</b>  Accuracy: Spec: NA Demo: NA Location: BATTERY CHARGER ROOM  Elevation: 549'0"	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB. 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 451  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: STANDBY DC POWER  Plant I.D. Number: 250 V BATT CHRG. 2/3 Component: 250 V BATTERY CHARGER	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT NO. 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 452  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: MCC 3 Component: 250 V DC MOTOR CONTROL CENTER Manufacturer: CUTLER HAMMER UNITROL  Model Number: DIAGRAM 95D9801ED74S BREAKER 45E101G Purchase Order Number: 3447-146 SPEC K2212 Function/Service: <b>DISTRIBUTE DC POWER</b>  Accuracy: Spec: NA Demo: NA Location: BATTERY CHARGER ROOM  Elevation: 549'0"	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT NO 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 453  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: <b>MCC 3 BUS 3A&amp;3B</b> Component: <b>250 V DC REACTOR</b> <b>BUILDING MCC</b> Manufacturer: <b>CUTLER HAMMER</b>  Model Number: <b>UNITROL(NO TAG)</b>  Purchase Order Number: <b>3447-149</b> <b>SPEC K2225</b> Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS	NOT REQD.	NA	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (A)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (A)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.0 E04		REF. (B)			SEE NOTE (1)
	Aging	NOT REQD	NOT	REF. (C)	NOT REQD		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 454  
 Revision 0  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY DC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: MCC 3 BUS 3A	Temperature (°F)	103
Component: 250 V DC REACTOR	Pressure (PSIA)	14.7
BUILDING MCC	Relative Humidity (%)	100
Manufacturer: CUTLER HAMMER	Chemical Spray	NA
Model Number: UNITROL(NO TAG)	Radiation (Rad)	3.0 EO4
Purchase Order Number: 3447-149	Aging	NOT REQD
SPEC K2225	Submergence	NA
Function/Service: DISTRIBUTE DC POWER		
Accuracy: Spec: NA		
Location: BETWEEN COLS 46&47 AND COLS M&N		
Elevation: 570'-0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: STANDBY DC POWER	Operating Time	CONTINUOUS
Plant I.D. Number: MCC 3 BUS 3B	Temperature (°F)	103
Component: 250 V DC REACTOR	Pressure (PSIA)	14.7
BUILDING MCC	Relative Humidity (%)	100
Manufacturer: CUTLER HAMMER	Chemical Spray	NA
Model Number: UNITROL(NO TAG)	Radiation (Rad)	<1.0 EO4
Purchase Order Number: 3447-149	Aging	NOT REQD
SPEC K2225	Submergence	NA
Function/Service: DISTRIBUTES DC POWER		
Accuracy: Spec: NA		
Location: BETWEEN COLS. 46&47 AND COLS.M&N		
Elevation: 570'-0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 455  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: <b>250 V BATTERIES</b> Component: <b>250 V DC BATTERY</b>  Manufacturer: <b>GOULD</b>  Model Number: <b>FPS-25</b>  Purchase Order Number: <b>3447-146</b> <b>SPEC K2212</b> Function/Service: <b>STORE AND SUPPLY DC POWER</b>  Accuracy: Spec: NA Demo: NA Location: <b>BATTERY CHARGER ROOM</b> Elevation: <b>549'0"</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: NA Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1 FEB 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 456  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: <b>125 V BATT CHGR 3&amp;3A</b> Component: <b>125 V BATTERY CHARGER</b>  Manufacturer: <b>GOULD</b>  Model Number: <b>FLOATER CHARGER</b> <b>NO TAG</b> Purchase Order Number: <b>3447-146</b> <b>SPEC K2212</b> Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 EO4	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 457  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY DC POWER</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 125 V BATT CHRG 3	Temperature (°F)	120
Component: <b>125 V BATTERY CHARGER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GOULD</b>	Relative Humidity (%)	100
Model Number: <b>FLOATER CHARGER NO TAG</b>	Chemical Spray	NA
Purchase Order Number: 3447-146 SPEC K2212	Radiation (Rad)	<1.0 E04
Function/Service: <b>CHARGE 125V BATTERY AND PROVIDE DC POWER</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>BATTERY CHARGER ROOM</b>		
Elevation 549'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>STANDBY DC POWER</b>	Operating Time	CONTINUOUS
Plant I.D. Number: 125 V BATT CHGR 3A	Temperature (°F)	120
Component: <b>125 V BATTERY CHARGER</b>	Pressure (PSIA)	14.7
Manufacturer: <b>GOULD</b>	Relative Humidity (%)	100
Model Number: <b>FLOATER CHARGER NO TAG</b>	Chemical Sprey	NA
Purchase Order Number: 3447-146 SPEC K2212	Radiation (Rad)	<1.0 E04
Function/Service: <b>CHARGE 125V BATTERY AND PROVIDE DC POWER</b>	Aging	NOT REQD.
Accuracy: Spec: NA Demo: NA	Submergence	NA
Location <b>BATTERY CHARGER ROOM</b>		
Elevation 549'0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 458  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB. 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 459  
 Revision 0  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: 125 V DCDP MAIN BUS 3 Component: 125 V DC TURB BLDG DISTRIBUTION PANEL Manufacturer: CUTLER HAMMER UNITROL  Model Number: DIAGRAM 95D9801ED745 Purchase Order Number: 3447-149 SPEC K2225 Function/Service: <b>DISTRIBUTE DC POWER</b>  Accuracy: Spec: NA Demo: NA Location: <b>BATTERY CHARGER ROOM</b>  Elevation: 549'0"	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1 FEB. 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 460  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
<b>System:</b> <b>STANDBY DC POWER</b>  <b>Plant I.D. Number:</b> <b>125 V DCDP RES BUS 2</b> <b>Component:</b> <b>125 V DC TURB BLDG</b> <b>DISTRIBUTION PANEL</b> <b>Manufacturer:</b> <b>CUTLER HAMMER UNITROL</b>  <b>Model Number:</b> <b>DIAGRAM</b> <b>94D7801ED745</b> <b>Purchase Order Number:</b> <b>3447-146</b> <b>SPEC K2212</b> <b>Function/Service:</b> <b>DISTRIBUTE DC POWER</b>  <b>Accuracy:</b> Spec: NA <b>Demo:</b> NA <b>Location:</b> BATTERY CHARGER ROOM <b>Elevation:</b>  <b>Flood Level</b> <b>Elevation:</b> NA <b>Above Flood Level:</b> <b>Yes:</b> <b>No:</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB. 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 461  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: 125 V DCDP MAIN BUS 3 Component: 125 V DC REACTOR BLDG DISTRIBUTION PANEL Manufacturer: CUTLER HAMMER UNITROL  Model Number:  Purchase Order Number: 3447-146 SPEC K2212 Function/Service: <b>DISTRIBUTE DC POWER</b>  Accuracy: Spec: Demo: Location: IN MCC MAIN BUS 3B NEAR COL 46 & COL M-N Elevation: 570'-0"	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.0 EO4		REF. (B)			
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 462  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: <b>48/24 V BATT 3A&amp;3B</b> Component: <b>48/24 V BATTERY</b>  Manufacturer: <b>GOULD</b>  Model Number: <b>DPR-9</b>  Purchase Order Number: <b>3447-146</b> <b>SPEC K2212</b> Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37. REV 1 FEB. 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 463  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 E04	Radiation (Rad)	<1.0 E04
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
Operating Time	CONTINUOUS	Operating Time	CONTINUOUS
Temperature (°F)	120	Temperature (°F)	120
Pressure (PSIA)	14.7	Pressure (PSIA)	14.7
Relative Humidity (%)	100	Relative Humidity (%)	100
Chemical Spray	NA	Chemical Spray	NA
Radiation (Rad)	<1.0 E04	Radiation (Rad)	<1.0 E04
Aging	NOT REQD.	Aging	NOT REQD.
Submergence	NA	Submergence	NA
Flood Level Elevation: NA Above Flood Level: Yes: No:		Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-Q858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 464  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: 24 V BATT CHRG 3A&3B Component: 24 V BATTERY CHARGER	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (1)
	Pressure (PSIA)	14.7	NOT REQD.	REF. (A)	NOT REQD.		
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (1)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 EO4	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB. 1975. B. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 465  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	120	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0 E04	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		
ENVIRONMENT		
Parameter	FSAR	
Operating Time	CONTINUOUS	
Temperature (°F)	120	
Pressure (PSIA)	14.7	
Relative Humidity (%)	100	
Chemical Spray	NA	
Radiation (Rad)	<1.0 E04	
Aging	NOT REQD.	
Submergence	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 466  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: STANDBY DC POWER		Operating Time	CONTINUOUS
Plant I.D. Number: 24 V BATT CHRG 3B(+)		Temperature (°F)	120
Component: 24 V BATTERY CHARGER		Pressure (PSIA)	14.7
Manufacturer: GOULD		Relative Humidity (%)	100
Model Number: GRF 24525F30		Chemical Spray	NA
Purchase Order Number: 3447-146 SPEC K2212		Radiation (Rad)	<1.0 E04
Function/Service: CHARGE 48/24 V BATTERY AND PROVIDE DC POWER		Aging	NOT REQD.
Accuracy: Spec: Demo:		Submergence	NA
Location BATTERY CHARGER ROOM		Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 549'0"			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: STANDBY DC POWER		Operating Time	CONTINUOUS
Plant I.D. Number: 24 V BATT CHRG 3B(-)		Temperature (°F)	120
Component: 24 V BATTERY CHARGER		Pressure (PSIA)	14.7
Manufacturer: GOULD		Relative Humidity (%)	100
Model Number: GRF 24525F30		Chemical Spray	NA
Purchase Order Number: 3447-146 SPEC K2212		Radiation (Rad)	<1.0 E04
Function/Service: CHARGE 48/24 V BATTERY AND PROVIDE DC POWER		Aging	NOT REQD.
Accuracy: Spec: Demo:		Submergence	NA
Location BATTERY CHARGER ROOM		Flood Level Elevation: NA Above Flood Level: Yes: No:	
Elevation 549'0"			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 467  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>STANDBY DC POWER</b>  Plant I.D. Number: <b>48/24 V DCDB 3A&amp;B</b> Component: <b>48/24 V DC</b> <b>DISTRIBUTION PANEL</b> Manufacturer: <b>CUTLER HAMMER UNITROL</b>  Model Number: <b>6CF643663</b>  Purchase Order Number: <b>3447-149</b> <b>SPEC K2225</b> Function/Service: <b>SEE ATTACHED SHEETS</b>	Operating Time	CONTINUOUS		NA			SEE NOTE (1)
	Temperature (°F)	120		REF. (A)			SEE NOTE (2)
	Pressure (PSIA)	14.7		REF. (A)			SEE NOTE (2)
	Relative Humidity (%)	100		REF. (A)			SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	<1.0 E04	NOT REQD.	REF. (B)	NOT REQD.		
	Aging	NOT REQD.	NOT REQD.	REF. (C)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR SECTION 10.11 AND SPECIAL REPORT 37, REV 1, FEB. 1975. B. BECHTEL RADIATION STUDY C. REPORT SECTION 4.3.6	2. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 468  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: STANDBY DC POWER	Operating Time		CONTINUOUS
Plant I.D. Number: 48/24 V DCDB 3A	Temperature (°F)		120
Component: 48/24 V DC DISTRIBUTION PANEL	Pressure (PSIA)		14.7
Manufacturer: CUTLER HAMMER UNITROL	Relative Humidity (%)		100
Model Number: 6CF643663	Chemical Spray		NA
Purchase Order Number: 3447-149 SPEC K2225	Radiation (Rad)		<1.0 E04
Function/Service: DISTRIBUTE DC POWER	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location BATTERY CHARGER ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION		ENVIRONMENT	
	Parameter		FSAR
System: STANDBY DC POWER	Operating Time		CONTINUOUS
Plant I.D. Number: 48/24 V DCDB 3B	Temperature (°F)		120
Component: 48/24 V DC DISTRIBUTION PANEL	Pressure (PSIA)		14.7
Manufacturer: CUTLER HAMMER UNITROL	Relative Humidity (%)		100
Model Number: 6CF643663	Chemical Spray		NA
Purchase Order Number: 3447-149 SPEC K2225	Radiation (Rad)		<1.0 E04
Function/Service: DISTRIBUTE DC POWER	Aging		NOT REQD.
Accuracy: Spec: Demo:	Submergence		NA
Location BATTERY CHARGER ROOM	Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 469  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: MO-3-1301-1 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS)</b> DC MOTOR Model Number: <b>TYPE SMB-2-60</b>  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>CONTAINMENT ISOLATION REACTOR TO ISOLATION CONDENSER</b>  Accuracy: Spec: NA Demo: NA Location: <b>INSIDE DRYWELL AZIMUTH 90</b> Elevation: <b>532' 9"</b>	Operating Time	12 DAYS	16 DAYS	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Temperature (°F)	NORMAL 150 LOCA 281	250	REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	39.7	REF. (A)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (1)
	Radiation (Rad)	1.0 EO8	2.0 EO7	REF. (D)	REF. (B)	INDIVIDUAL TEST	SEE NOTE (1)
	Aging		165 F FOR 199.8 HOURS		REF. (B)	INDIVIDUAL TEST	
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: 505' 6" Above Flood Level: Yes: X No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 AND FSAR SECTION 6.2.3.2 B. REPORT NO 600461-B0003, QUALIFICATION TYPE TEST REPORT - LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF ADDITIONAL QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 470  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: <b>MO-3-1301-2</b> Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE</b>  Model Number: <b>SMB-4-200</b>  Purchase Order Number: <b>3447-141</b> <b>SPEC K-2205</b> Function/Service: <b>CONTAINMENT ISOLATION REACTOR TO ISOLATION CONDENSER</b>  Accuracy: Spec: NA Demo: NA Location: <b>OUTSIDE DRYWELL AZIMUTH 90</b> Elevation: <b>532'9"</b>	Operating Time	12 DAYS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	340	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	27.0	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	9.4 E06	1.0 E07	REF. (D)	REF. (B)	INDIVIDUAL TEST	
	Aging		180 C FOR 100 HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
<p>A. FSAR FIGURES 5.2.11 &amp; 5.2.12        B. REPORT NO 600426-B0009, QUALIFICATION TYPE TEST REPORT - LIMITORQUE DC VALVE ACTUATORS. ONLY THE MOTOR WAS THERMALLY AGED. LIMITORQUE CORP USES THESE UNITS AT TEMPERATURES OF 300 F CONTINUOUSLY. THEREFORE AGING WAS CONSIDERED NECESSARY FOR THE MOTOR ONLY.</p>	<p>1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA RESOLVE QUALIFICATION TIME. TEMPERATURE PROFILE DOES NOT MEET THE REQUIREMENTS PER IEEE STANDARDS OR THAT OF THE FSAR. TIME TO REACH TEMPERATURE WAS 1 HOUR AND 55 MINUTES.        2. TEST PROCEDURE REQUIRES SATURATED ATMOSPHERE, BUT HUMIDITY WAS NOT MEASURED DURING TEST.</p>

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 471  
Revision: O  
Date: 04-11-80

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. SPECIAL REPORT NO 37, REV 1, FEB 1975 D. BECHTEL RADIATION STUDY	3. RESOLVE AGING REQUIREMENTS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 472  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: MO-3-1301-3 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (PEERLESS) DC MOTOR</b> Model Number: SMB-1-60  Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>CONTAINMENT ISOLATION ISOLATION CONDENSER RETURN TO REACTOR</b>  Accuracy: Spec: NA Demo: NA Location: <b>OUTSIDE DRYWELL AZIMUTH 180</b> Elevation: 547' 10"	Operating Time	12 DAYS		REF. (A)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (1)
	Temperature (°F)	242	340	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Pressure (PSIA)	27.0	126.7	REF. (C)	REF. (B)	SIMULTANEOUS TEST	
	Relative Humidity (%)	100	100	REF. (C)	REF. (B)	SIMULTANEOUS TEST	SEE NOTE (2)
	Chemical Spray	NA	NA	NA	REF. (D)	NA	
	Radiation (Rad)	6.7 E05	1.0 E07	REF. (D)	REF. (B)	INDIVIDUAL TEST	
	Aging		180 C FOR 100 HOURS		REF. (B)	INDIVIDUAL TEST	SEE NOTE (3)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. REPORT NO 600426-B0009, QUALIFICATION TYPE TEST REPORT - LIMITORQUE DC VALVE ACTUATORS. ONLY THE MOTOR WAS THERMALLY AGED. LIMITORQUE CORP USES THESE UNITS AT TEMPERATURES OF 300 F CONTINUOUSLY. THEREFORE AGING WAS CONSIDERED NECESSARY FOR THE MOTOR ONLY.	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA RESOLVE QUALIFICATION TIME. TEMPERATURE PROFILE DOES NOT MEET THE REQUIREMENTS PER IEEE STANDARDS OR THAT OF THE FSAR. TIME TO REACH TEMPERATURE WAS 1 HOUR AND 55 MINUTES. 2. TEST PROCEDURE REQUIRES SATURATED ATMOSPHERE, BUT HUMIDITY WAS NOT MEASURED DURING TEST.

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket: 50-249

Component Sheet No. 473  
Revision: O  
Date: 04-11-80

EQUIPMENT QUALIFICATION REPORT

DOCUMENTATION REFERENCES (cont.)	NOTES (cont.)
C. SPECIAL REPORT NO 37, REV 1, FEB 1975 D. BECHTEL RADIATION STUDY	3. RESOLVE AGING REQUIREMENTS

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 474  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: MO-3-1301-4 Component: <b>MOTOR OPERATED GATE VALVE</b> Manufacturer: <b>LIMITORQUE (RELIANCE)</b>  Model Number: <b>TYPE SMB SN.79777A</b> Purchase Order Number: 3447-141 SPEC K-2205 Function/Service: <b>CONTAINMENT ISOLATION ISOLATION CONDENSER RETURN TO REACTOR</b>  Accuracy: Spec: NA Demo: NA Location: <b>INSIDE DRYWELL AZIMUTH 180</b> Elevation: <b>538'0"</b>	Operating Time	12 DAYS	16 DAYS	REF. (A)	REF. (B)		
	Temperature (°F)	NORMAL 150 LOCA 281	250	REF. (A)	REF. (B)		SEE NOTE (1)
	Pressure (PSIA)	NORMAL 14.7 LOCA 63.0	39.7	REF. (A)	REF. (B)		SEE NOTE (1)
	Relative Humidity (%)	100		REF. (A)	REF. (B)		
	Chemical Spray	DEMIN WATER		REF. (C)			SEE NOTE (1)
	Radiation (Rad)	1.0 E08	2.0 E07	REF. (D)	REF. (B)		SEE NOTE (1)
	Aging		165 F FOR 199.8 HOURS				SEE NOTE (1)
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: 505' 6" Above Flood Level: Yes: X No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 &5.2.12 AND FSAR SECTION 6.2.3.2 B. REPORT NO 600461-B0003, QUALIFICATION TYPE TEST REPORT - LIMITORQUE VALVE ACTUATORS FOR CLASS IE SERVICE OUTSIDE PRIMARY CONTAINMENT. C. FSAR SECTION 6.2.4.2.B D. BECHTEL RADIATION STUDY	1. INVESTIGATE EXISTENCE OF ADDITIONAL QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 475  
 Revision 0  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: AO-3-1301-17 Component: <b>POSITION SWITCH</b>  Manufacturer: NAMCO SNAP-LOCK Model Number: MARK 11 D1200G Purchase Order Number: 3447-145 SPEC K-2213 Function/Service: <b>POSITION INDICATION FOR VALVE</b> AO-3-1301-17	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	9.0 E04		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 476  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: AO-3-1301-20 Component: <b>POSITION SWITCH</b>  Manufacturer: NAMCO SNAP LOCK Model Number: MARK II D1200G Purchase Order Number: 3447-145 SPEC K-2213 Function/Service: <b>POSITION INDICATION FOR VALVE</b> AO-3-1301-20  Accuracy: Spec: NA Demo: NA Location: <b>ALONG COL N &amp; 49</b>  Elevation: <b>589'0"</b>	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Sprey	NA	NA	NA	NA	NA	
	Radiation (Rad)	9.0 E04		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 477  
 Revision 0  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: AO-3-1301-17 Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: WPHT-8300B61F  Purchase Order Number:  Function/Service: <b>PILOT SOLENOID FOR VALVE AO-3-1301-17</b>  Accuracy: Spec: NA Demo: NA Location: <b>ALONG N &amp; 49</b>  Elevation: <b>589'0"</b>  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	9.0 EO4		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 478  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: AO-3-1301-20 Component: <b>SOLENOID VALVE</b>  Manufacturer: ASCO  Model Number: WPHT-8300B61F  Purchase Order Number:  Function/Service: PILOT SOLENOID FOR VALVE AO-3-1-1301-20	Operating Time	1 MINUTE	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	9.0 E04		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	
Flood Level Elevation: NA Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURE 8.2.5 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 479  
 Revision 0  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: <b>DPIS-3-1349A&amp;B</b> Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b> Manufacturer: <b>BARTON</b>  Model Number: <b>288-4235</b>  Purchase Order Number: <b>GE H0302</b>  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes:      No:	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.2 E05		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)	NOT REQD.		
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 &5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 480  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: <b>DPIS-3-1349A</b> Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b> Manufacturer: <b>BARTON</b>  Model Number: <b>288-4235</b>  Purchase Order Number: <b>GE HO302</b>  Function/Service: <b>MO-3-1301-1,2,3,4 ON HIGH DIFFERENTIAL PRESSURE</b>  Accuracy: Spec: Demo: Location <b>RACK 2203-28</b> <b>COLUMNS 48 &amp; M</b> Elevation <b>517'0"</b>  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	12 DAYS
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	3.2 E05
	Aging	NOT REQD.
	Submergence	NA

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: <b>DPIS-3-1349B</b> Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b> Manufacturer: <b>BARTON</b>  Model Number: <b>288-4235</b>  Purchase Order Number: <b>GE HO302</b>  Function/Service: <b>MO-3-1301-1,2,3,4 ON HIGH DIFFERENTIAL PRESSURE</b>  Accuracy: Spec: Demo: Location <b>RACK 2203-28</b> <b>COLUMNS 48 &amp; M</b> Elevation <b>517'0"</b>  Flood Level Elevation: NA Above Flood Level: Yes: No:	Operating Time	12 DAYS
	Temperature (°F)	103
	Pressure (PSIA)	14.7
	Relative Humidity (%)	100
	Chemical Spray	NA
	Radiation (Rad)	3.2 E05
	Aging	NOT REOD.
	Submergence	NA

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 481  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>ISOLATION CONDENSER</b>  Plant I.D. Number: DPIS-3-1350A&B Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b> Manufacturer: BARTON  Model Number:  Purchase Order Number: GE HO302  Function/Service: <b>SEE ATTACHED SHEETS</b>  Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>  Elevation: <b>SEE ATTACHED SHEETS</b>  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time	12 DAYS	NOT REQD.	REF. (A)	NOT REQD.		
	Temperature (°F)	103	NOT REQD.	REF. (B)	NOT REQD.		
	Pressure (PSIA)	14.7	NOT REQD.	REF. (B)	NOT REQD.		
	Relative Humidity (%)	100	NOT REQD.	REF. (B)	NOT REQD.		
	Chemical Spray	NA	NA	NA	NA	NA	
	Radiation (Rad)	3.2 E05		REF. (C)			SEE NOTE (1)
	Aging	NOT REQD.	NOT REQD.	REF. (D)			
	Submergence	NA	NA	NA	NA	NA	

DOCUMENTATION REFERENCES	NOTES
A. FSAR FIGURES 5.2.11 & 5.2.12 B. FSAR SECTION 10.11 C. BECHTEL RADIATION STUDY D. REPORT SECTION 4.3.6	1. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 482  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	
System: <b>ISOLATION CONDENSER</b>	
Plant I.D. Number: <b>DPIS-3-1350A</b>	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	
Manufacturer: <b>BARTON</b>	
Model Number:	
Purchase Order Number: <b>GE HO302</b>	
Function/Service: <b>MO-3-1301-1,2,3,4 ON HIGH DIFFERENTIAL PRESSURE</b>	
Accuracy: Spec: Demo:	
Location <b>RACK2203-28</b> <b>COLUMNS 48 &amp;M</b> Elevation <b>517'0"</b>	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

ENVIRONMENT	
Parameter	FSAR
Operating Time	12 DAYS
Temperature (°F)	103
Pressure (PSIA)	14.7
Relative Humidity (%)	100
Chemical Spray	NA
Radiation (Rad)	3.2 E05
Aging	NOT REQD.
Submergence	NA

EQUIPMENT DESCRIPTION	
System: <b>ISOLATION CONDENSER</b>	
Plant I.D. Number: <b>DPIS-3-1350B</b>	
Component: <b>DIFFERENTIAL PRESSURE INDICATING SWITCH</b>	
Manufacturer: <b>BARTON</b>	
Model Number:	
Purchase Order Number: <b>GE HO302</b>	
Function/Service: <b>MO-3-1301-1,2,3,4 ON HIGH DIFFERENTIAL PRESSURE</b>	
Accuracy: Spec: Demo:	
Location <b>RACK2203-28</b> <b>COLUMNS 48 &amp;M</b> Elevation <b>517'0"</b>	
Flood Level Elevation: NA Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

Component Sheet No: 483  
Revision  
Date

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>SEE ATTACHED SHEETS</b>	Operating Time						
Plant I.D. Number: <b>SEE ATTACHED SHEETS</b>	Temperature (°F)						
Component:	Pressure (PSIA)						
Manufacturer:	Relative Humidity (%)						
Model Number:	Chemical Spray						
Purchase Order Number:	Radiation (Rad)						
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo: Location: <b>SEE ATTACHED SHEETS</b>	Submergence						
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 484  
 Revision  
 Date: - - -

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:		Operating Time	
		Temperature (°F)	
		Pressure (PSIA)	
		Relative Humidity (%)	
		Chemical Spray	
		Radiation (Rad)	
		Aging	
		Submergence	
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
		Parameter	FSAR
System:		Operating Time	
		Temperature (°F)	
		Pressure (PSIA)	
		Relative Humidity (%)	
		Chemical Spray	
		Radiation (Rad)	
		Aging	
		Submergence	
Flood Level Elevation: Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 485  
 Revision -  
 Date: -

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	
Plant I.D. Number:	Temperature (°F)	
Component:	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	
Plant I.D. Number:	Temperature (°F)	
Component:	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	
Elevation	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 486  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: BUTYL RBR INSU POLYVN CHLORIDE JACKET Manufacturer: GENERAL ELECTRIC CABLE	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 487  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>  Plant I.D. Number: <b>CABLE</b> Component: <b>BUTYL RBR INSU POLYVN CHLORIDE JACKET</b> Manufacturer: <b>SIMPLEX</b>  Model Number:  Purchase Order Number: <b>3447-117</b>  Function/Service:  Accuracy: Spec: Location: Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 488  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: ANHYDREX XX PLASTEX INSU & JACKET Manufacturer: SIMPLEX  Model Number:  Purchase Order Number: SPEC-COM. ED EM-29116 SIMPLEX-XM Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 489  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.      INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 490  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual:		
System: GENERIC	Operating Time						SEE NOTE (1)
Plant I.D. Number: CABLE	Temperature (°F)						SEE NOTE (1)
Component: CROSS LINK POLYETH INSU NEOPRN JACKET	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: GENERAL ELECTRIC CABLE	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number: P.O #205-H0113	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Location: Elevation:	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 491  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 492  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: ANHYDREX XX PLASTEX INSU & JKT Manufacturer: SIMPLEX	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 493  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>  Plant I.D. Number: <b>CABLE</b> Component: <b>ANHYDREX XX</b> <b>PLASTEX INSU</b> Manufacturer: <b>SIMPLEX</b>  Model Number:  Purchase Order Number: <b>SPEC-COM ED-29115</b> <b>SIMPLEX XM-1490A</b> Function/Service:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 494  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: RBR INSU POLYV CHLORIDE JACKET Manufacturer: SIMPLEX  Model Number:  Purchase Order Number: P.O. -#3447-117  Function/Service:   Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 495  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>  Plant I.D. Number: <b>CABLE</b> Component: <b>BUTYL RBR INSU POLYVN CHLORIDE JACKET</b> Manufacturer: <b>GENERAL ELECTRIC CABLE</b> Model Number:  Purchase Order Number: <b>P.O. 205-H0113</b> Function/Service:  Accuracy: Spec: Demo: Location: Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 496  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC	Operating Time						SEE NOTE (1)
Plant I.D. Number: CABLE	Temperature (°F)						SEE NOTE (1)
Component: ANHYDREX XX	Pressure (PSIA)						SEE NOTE (1)
PLASTEX INSU & JKT.	Relative Humidity (%)						SEE NOTE (1)
Manufacturer: SIMPLEX	Chemical Spray						SEE NOTE (1)
Model Number:	Radiation (Rad)						SEE NOTE (1)
Purchase Order Number: SPEC-COM ED-29115	Aging						SEE NOTE (1)
SIMPLEX XM-1490A	Submergence						SEE NOTE (1)
Function/Service:							
Accuracy: Spec: Location: Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 497  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.      INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 498  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC	Operating Time						SEE NOTE (1)
Plant I.D. Number: CABLE	Temperature (°F)						SEE NOTE (1)
Component: SWITCHBOARD-TYPE SIS #SI 57275 VULKENE	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: GENERAL ELECTRIC CABL	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number: P.O. #205-H0113	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Location:	Submergence						SEE NOTE (1)
Elevation:							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 499  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: POLY NYLON INSU SHLD & PLASTEX INSTR Manufacturer: SIMPLEX  Model Number:  Purchase Order Number: SPEC-COM ED-EST 7026-2 SIMPLEX-XM2255 Function/Service:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 500  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: POLY NYLON INSU SHLD & PLASTEX INSTR Manufacturer: SIMPLEX  Model Number:  Purchase Order Number: SPEC-COM ED-EST 7026-2 SIMPLEX-XM2255 Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 501  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: POLY NYLON INSU SHLD & PLASTEX INSTR Manufacturer: SIMPLEX  Model Number:  Purchase Order Number: SPEC-COM ED-EST 7026-2 SIMPLEX-XM2255 Function/Service:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 502  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 503  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>CABLE</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>POLY NYLON INSU SHLD PLASTEX JACKET</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: <b>SIMPLEX</b>	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number: <b>COM ED-B/M3447A EST 70261 SIMPLEX-XM2255</b>	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Location: Elevation: Flood Level Elevation: Above Flood Level: Yes: No:	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 504  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.      INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 505  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC	Operating Time						SEE NOTE (1)
Plant I.D. Number: CABLE	Temperature (°F)						SEE NOTE (1)
Component: 3 TW WITH OVERALL SH COM ED SPEC-EST-70261	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: SIMPLEX	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number: P.O. 3447-117-ITEM#30	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location:	Submergence						SEE NOTE (1)
Elevation:							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 506  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: COM-ED EST-7026-1  Manufacturer: SIMPLEX  Model Number:  Purchase Order Number: P.O. 3447-117 ITEM#24  Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	<p>1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.      INVESTIGATE EXISTENCE OF QUALIFICATION DATA      WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 507  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC	Operating Time						SEE NOTE (1)
Plant I.D. Number: CABLE	Temperature (°F)						SEE NOTE (1)
Component: POLYETH INSU & JKT COAXIAL CABLE	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: RAYCHEM CORP.	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number: P.O. #3447-171 ITEM#1	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location: CONTAINMENT	Submergence						SEE NOTE (1)
Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

Component Sheet No: 508  
Revision O  
Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 509  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC	Operating Time						SEE NOTE (1)
Plant I.D. Number: CABLE	Temperature (°F)						SEE NOTE (1)
Component: COAXIAL-RG59B/U	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: NEWARK ELECTRIC CORP	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number: P.O. #3447-169	Radiation (Rad)						SEE NOTE (1)
ITEM #1	Aging						SEE NOTE (1)
Function/Service:	Submergence						SEE NOTE (1)
Accuracy: Spec: Demo:							
Location: REACTOR CORE AREA							
Elevation:							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS.      INVESTIGATE EXISTENCE OF QUALIFICATION DATA      WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 510  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>CABLE</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>COAXIAL ANTI MICROPHONE</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer:	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Demo: Location:	Submergence						SEE NOTE (1)
Elevation:							SEE NOTE (1)
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 511  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>  Plant I.D. Number: <b>CABLE</b> Component: <b>PE INSU SHLD PE JKT</b>  Manufacturer: <b>BAY ASSOCIATES</b>  Model Number:  Purchase Order Number: <b>P.O. #3447-170-ITEM#2</b>  Function/Service:  Accuracy: Spec: Demo: Location: <b>REACTOR CORE AREA</b>  Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 512  
 Revision O  
 Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERIC</b>	Operating Time						SEE NOTE (1)
Plant I.D. Number: <b>CABLE</b>	Temperature (°F)						SEE NOTE (1)
Component: <b>PE INSU TRIPLE SH</b>	Pressure (PSIA)						SEE NOTE (1)
Manufacturer: <b>BAY ASSOCIATES</b>	Relative Humidity (%)						SEE NOTE (1)
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number: <b>P.O. #3447-170 ITEM #</b>	Radiation (Rad)						SEE NOTE (1)
Function/Service:	Aging						SEE NOTE (1)
Accuracy: Spec: Demo:	Submergence						SEE NOTE (1)
Location: <b>REACTOR CORE</b>							
Elevation:							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No: 513  
Revision O  
Date 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: VINYL INSULATION VINYL JACKET Manufacturer: NEWARK ELECT. CORP.  Model Number:  Purchase Order Number: P.O. #3447-169 ITEM 3  Function/Service:  Accuracy: Spec: Demo: Location:  Elevation:  Flood Level Elevation: Above Flood Level: Yes: No:	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)

DOCUMENTATION REFERENCES	NOTES
	<ol style="list-style-type: none"><li>ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</li></ol>

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

Component Sheet No: 514  
Revision O  
Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERIC  Plant I.D. Number: CABLE Component: MULTI PAIR WITH OVERALL SH CO-CON Manufacturer: GENERAL ELECTRIC CABLE	Operating Time						SEE NOTE (1)
	Temperature (°F)						SEE NOTE (1)
	Pressure (PSIA)						SEE NOTE (1)
	Relative Humidity (%)						SEE NOTE (1)
	Chemical Spray						SEE NOTE (1)
	Radiation (Rad)						SEE NOTE (1)
	Aging						SEE NOTE (1)
	Submergence						SEE NOTE (1)
	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Component Sheet No: 515

Revision O

Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: GENERAL USE ELECTRICAL EQUIPMENT	Operating Time						
Plant I.D. Number: X201B, X202B&D, X203B	Temperature (°F)						
Component: ELECTRICAL PENETRATION	Pressure (PSIA)						
Manufacturer:	Relative Humidity (%)						
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						
Function/Service: SEE ATTACHED SHEETS	Aging						
Accuracy: Spec: Demo:	Submergence						SEE NOTE (1)
Location: SEE ATTACHED SHEETS							
Elevation: SEE ATTACHED SHEETS							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 516  
 Revision O.  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time	
Plant I.D. Number: <b>X2018</b>	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation <b>EL. 532'-6"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time	
Plant I.D. Number: <b>X202B</b>	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation <b>EL. 532'-0"</b>		
Flood Level Elevation: Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 517  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time	
Plant I.D. Number: <b>X202D</b>	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation <b>EL. 532'-0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time	
Plant I.D. Number: <b>X203B</b>	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation <b>EL. 532'-6"</b>		
Flood Level Elevation: Above Flood Level: Yes: No:		

G-0858-03

Component Sheet No: 518

Revision O

Date 04-11-80

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

## EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time						
Plant I.D. Number: X202BB, X202S&W X2000	Temperature (°F)						
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)						
Manufacturer:	Relative Humidity (%)						
Model Number:	Chemical Spray					SEE NOTE (1)	
Purchase Order Number:	Radiation (Rad)						
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo:	Submergence					SEE NOTE (1)	
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 519  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time	
Plant I.D. Number: X202S	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation EL532' -0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time	
Plant I.D. Number: X202W	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation EL532' -6"		
Flood Level Elevation: Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 520  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time	
Plant I.D. Number: X202BB	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation <b>EL534'-0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL PENETRATION</b>	Operating Time	
Plant I.D. Number: X200C	Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location <b>INSIDE DRYWELL</b>		
Elevation <b>EL.532'-6"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

Component Sheet No: 521  
Revision O  
Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time						
Plant I.D. Number: X202L,X X204A,L,M,S	Temperature (°F)						
Component: <b>ELECTRICAL PENETRATIONS</b>	Pressure (PSIA)						
Manufacturer:	Relative Humidity (%)						
Model Number:	Chemical Spray					SEE NOTE (1)	
Purchase Order Number:	Radiation (Rad)						
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo:	Submergence					SEE NOTE (1)	
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	<p>1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</p>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 522  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	
Plant I.D. Number:	Temperature (°F)	
Component: ELECTRICAL PENETRATIONS	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	
Elevation	Flood Level Elevation: NA Above Flood Level: Yes: No:	

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System:	Operating Time	
Plant I.D. Number:	Temperature (°F)	
Component: ELECTRICAL PENETRATIONS	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: Location	Submergence	
Elevation	Flood Level Elevation: Above Flood Level: Yes: No:	

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No. 523  
 Revision O  
 Date: 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>		
Plant I.D. Number: <b>X204A</b>		
Component: <b>ELECTRICAL PENETRATIONS</b>		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service:		
Accuracy:	Spec:	NA
Location	Demo:	NA
<b>INSIDE DRYWELL</b>		
Elevation <b>EL.534'-0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence		

EQUIPMENT DESCRIPTION		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>		
Plant I.D. Number: <b>X204L</b>		
Component: <b>ELECTRICAL PENETRATIONS</b>		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service:		
Accuracy:	Spec:	NA
Location	Demo:	NA
<b>INSIDE DRYWELL</b>		
Elevation <b>EL.533'-6"</b>		
Flood Level Elevation: Above Flood Level: Yes: No:		

ENVIRONMENT		
Parameter	FSAR	
Operating Time		
Temperature (°F)		
Pressure (PSIA)		
Relative Humidity (%)		
Chemical Spray		
Radiation (Rad)		
Aging		
Submergence		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 524  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION			ENVIRONMENT	
	Parameter	FSAR		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time			
Plant I.D. Number: <b>X204M</b>	Temperature (°F)			
Component: <b>ELECTRICAL PENETRATIONS</b>	Pressure (PSIA)			
Manufacturer:	Relative Humidity (%)			
Model Number:	Chemical Spray			
Purchase Order Number:	Radiation (Rad)			
Function/Service:	Aging			
Accuracy: Spec: NA Demo: NA	Submergence			
Location <b>INSIDE DRYWELL</b>				
Elevation <b>EL.533'-6"</b>				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

EQUIPMENT DESCRIPTION			ENVIRONMENT	
	Parameter	FSAR		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time			
Plant I.D. Number: <b>X204S</b>	Temperature (°F)			
Component: <b>ELECTRICAL PENETRATIONS</b>	Pressure (PSIA)			
Manufacturer:	Relative Humidity (%)			
Model Number:	Chemical Spray			
Purchase Order Number:	Radiation (Rad)			
Function/Service:	Aging			
Accuracy: Spec: NA Demo: NA	Submergence			
Location <b>INSIDE DRYWELL</b>				
Elevation <b>EL.533'-6"</b>				
Flood Level Elevation: Above Flood Level: Yes: No:				

G-0858-03

Owner: COMMONWEALTH EDISON  
Facility: DRESDEN  
Unit: 3  
Docket No: 50-249

Component Sheet No: 525  
Revision O  
Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time						
Plant I.D. Number: <b>X204N &amp; Q X205B</b>	Temperature (°F)						
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)						
Manufacturer:	Relative Humidity (%)						
Model Number:	Chemical Spray					SEE NOTE (1)	
Purchase Order Number:	Radiation (Rad)						
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo:	Submergence					SEE NOTE (1)	
Location: <b>SEE ATTACHED SHEETS</b>	Flood Level Elevation: Above Flood Level: Yes: No:						

DOCUMENTATION REFERENCES	NOTES
	<ol style="list-style-type: none"><li>ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.</li></ol>

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 526  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System: GENERAL USE ELECTRICAL EQUIPMENT			Operating Time	
Plant I.D. Number: X204N			Temperature (°F)	
Component: ELECTRICAL PENETRATION			Pressure (PSIA)	
Manufacturer:			Relative Humidity (%)	
Model Number:			Chemical Spray	
Purchase Order Number:			Radiation (Rad)	
Function/Service:			Aging	
Accuracy: Spec: NA Demo: NA			Submergence	
Location INSIDE DRYWELL				
Elevation EL.533'-6"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System: GENERAL USE ELECTRICAL EQUIPMENT			Operating Time	
Plant I.D. Number: X204O			Temperature (°F)	
Component: ELECTRICAL PENETRATION			Pressure (PSIA)	
Manufacturer:			Relative Humidity (%)	
Model Number:			Chemical Spray	
Purchase Order Number:			Radiation (Rad)	
Function/Service:			Aging	
Accuracy: Spec: NA Demo: NA			Submergence	
Location INSIDE DRYWELL				
Elevation EL.533'-6"				
Flood Level Elevation: NA Above Flood Level: Yes: No:				

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 527  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>		Operating Time	
Plant I.D. Number: <b>X205B</b>		Temperature (°F)	
Component: <b>ELECTRICAL PENETRATION</b>		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: NA Demo: NA		Submergence	
Location <b>INSIDE DRYWELL</b>			
Elevation <b>EL.532'-6"</b>			
Flood Level Elevation: NA Above Flood Level: Yes: No:			

EQUIPMENT DESCRIPTION		ENVIRONMENT	
Parameter	FSAR	Parameter	FSAR
System:		Operating Time	
Plant I.D. Number:		Temperature (°F)	
Component:		Pressure (PSIA)	
Manufacturer:		Relative Humidity (%)	
Model Number:		Chemical Spray	
Purchase Order Number:		Radiation (Rad)	
Function/Service:		Aging	
Accuracy: Spec: NA Demo: NA		Submergence	
Location			
Elevation			
Flood Level Elevation: Above Flood Level: Yes: No:			

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

Component Sheet No: 528  
 Revision O  
 Date 04-11-80

### EQUIPMENT QUALIFICATION REPORT

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION REFERENCES		QUALIFICATION METHOD	OUTSTANDING ITEMS
	Parameter	FSAR	Qualification	FSAR	Qual.		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>	Operating Time						
Plant I.D. Number: X202F,N,J X204E,H	Temperature ('F)						
Component: <b>ELECTRICAL PENETRATION</b>	Pressure (PSIA)						
Manufacturer:	Relative Humidity (%)						
Model Number:	Chemical Spray						SEE NOTE (1)
Purchase Order Number:	Radiation (Rad)						
Function/Service: <b>SEE ATTACHED SHEETS</b>	Aging						
Accuracy: Spec: Demo:	Submergence						SEE NOTE (1)
Location: <b>SEE ATTACHED SHEETS</b>							
Elevation: <b>SEE ATTACHED SHEETS</b>							
Flood Level Elevation: Above Flood Level: Yes: No:							

DOCUMENTATION REFERENCES	NOTES
	1. ESTABLISH ENVIRONMENTAL SERVICE CONDITIONS. INVESTIGATE EXISTENCE OF QUALIFICATION DATA WITH MANUFACTURER.

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 529  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System: GENERAL USE ELECTRICAL EQUIPMENT			Operating Time	
Plant I.D. Number: X202F			Temperature (°F)	
Component: ELECTRICAL PENETRATION			Pressure (PSIA)	
Manufacturer:			Relative Humidity (%)	
Model Number:			Chemical Spray	
Purchase Order Number:			Radiation (Rad)	
Function/Service:			Aging	
Accuracy: Spec: NA	Spec: Demo: NA	NA	Submergence	
Location INSIDE DRYWELL				
Elevation EL. 532'-0"				
Flood Level Elevation: NA				
Above Flood Level: Yes: No:				

EQUIPMENT DESCRIPTION			ENVIRONMENT	
			Parameter	FSAR
System: GENERAL USE ELECTRICAL EQUIPMENT			Operating Time	
Plant I.D. Number: X202N			Temperature (°F)	
Component: ELECTRICAL PENETRATION			Pressure (PSIA)	
Manufacturer:			Relative Humidity (%)	
Model Number:			Chemical Spray	
Purchase Order Number:			Radiation (Rad)	
Function/Service:			Aging	
Accuracy: Spec: NA	Spec: Demo: NA	NA	Submergence	
Location INSIDE DRYWELL				
Elevation EL. 532'-0"				
Flood Level Elevation: NA				
Above Flood Level: Yes: No:				

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 530  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: GENERAL USE ELECTRICAL EQUIPMENT	Operating Time	
Plant I.D. Number: X202J	Temperature (°F)	
Component: ELECTRICAL PENETRATION	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location INSIDE DRYWELL		
Elevation EL.532' -0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

EQUIPMENT DESCRIPTION	ENVIRONMENT	
	Parameter	FSAR
System: GENERAL USE ELECTRICAL EQUIPMENT	Operating Time	
Plant I.D. Number: X204E	Temperature (°F)	
Component: ELECTRICAL PENETRATION	Pressure (PSIA)	
Manufacturer:	Relative Humidity (%)	
Model Number:	Chemical Spray	
Purchase Order Number:	Radiation (Rad)	
Function/Service:	Aging	
Accuracy: Spec: NA Demo: NA	Submergence	
Location INSIDE DRYWELL		
Elevation EL.534' -0"		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

G-0858-03

Owner: COMMONWEALTH EDISON  
 Facility: DRESDEN  
 Unit: 3  
 Docket No: 50-249

### EQUIPMENT QUALIFICATION REPORT

Component Sheet No. 531  
 Revision O  
 Date: 04-11-80

EQUIPMENT DESCRIPTION		
System: <b>GENERAL USE ELECTRICAL EQUIPMENT</b>		
Plant I.D. Number: <b>X204H</b>		
Component: <b>ELECTRICAL PENETRATION</b>		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service:		
Accuracy:	Spec:	NA
Demo:	NA	
Location <b>INSIDE DRYWELL</b>		
Elevation <b>EL.534'-0"</b>		
Flood Level Elevation: NA Above Flood Level: Yes: No:		

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

EQUIPMENT DESCRIPTION		
System:		
Plant I.D. Number:		
Component:		
Manufacturer:		
Model Number:		
Purchase Order Number:		
Function/Service:		
Accuracy:	Spec:	NA
Demo:	NA	
Location		
Elevation		
Flood Level Elevation: Above Flood Level: Yes: No:		

ENVIRONMENT	
Parameter	FSAR
Operating Time	
Temperature (°F)	
Pressure (PSIA)	
Relative Humidity (%)	
Chemical Spray	
Radiation (Rad)	
Aging	
Submergence	

G-0858-03



**Bechtel Power Corporation**