

September 18, 1987

Docket Nos. 50-237  
and 50-249

Mr. L. D. Butterfield, Jr.  
Nuclear Licensing Manager  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Butterfield:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT -  
EXEMPTION FROM APPENDIX R TO 10 CFR PART 50 (TAC NOS. 61675, 61676)

Re: Dresden Nuclear Power Station, Unit Nos. 2 and 3

Enclosed is the subject assessment which relates to your submittal dated June 5, 1986, requesting exemptions from the technical requirements of Section III.G.3 of Appendix R to 10 CFR Part 50. The exemption relates to the installation of automatic fire detectors and a fixed suppression system in the drywell expansion gap.

This assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Daniel R. Muller

Daniel R. Muller, Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V, and Special Projects

Enclosure:  
Assessment

cc w/enclosure:  
See next page

DISTRIBUTION:

|              |          |                    |                 |
|--------------|----------|--------------------|-----------------|
| Docket File  | NRC PDR  | Local PDR          | PDIII-2 Reading |
| DCrutchfield | GHolahan | LLuther            | MGrotenhuis     |
| DMuller      | OGC-Beth | EJordan            | JPartlow        |
| ACRS (10)    | GPA/PA   | PDIII-2 Plant File |                 |

(\*See Previous Concurrence)

|            |                 |
|------------|-----------------|
| PDIII-2:LA | PDIII-2:PM      |
| LLuther    | *MGrotenhuis/bj |
| 8/ /87     | 8/ /87          |

PDIII-2  
DMuller  
8/15/87

OGC-Bethesda  
R. Fournier  
8/14/87

|            |                |
|------------|----------------|
| 8709230494 | 870918         |
| PDR        | ADOCK 05000237 |
| F          | PDR            |

September 18, 1987

Docket Nos. 50-237  
and 50-249

Mr. L. D. Butterfield, Jr.  
Nuclear Licensing Manager  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

DISTRIBUTION:  
Docket File  
NRC & Local PDRs  
AD/Holahan  
LLuther  
MGrotenhuis  
OGC-BETHESDA  
EJordan  
JPartlow  
ACRS (10)  
GPA/PA  
PDIII-2 Plant File

Dear Mr. Butterfield:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT  
(TAC NOS. 59853, 59854)

Re: Dresden Nuclear Power Station, Unit Nos. 2 and 3

Enclosed is our Environmental Assessment and Finding of No Significant Impact which relates to your submittal dated August 10, 1984 as supplemented March 1, August 9, and September 18, 1985, and January 9, March 12, March 20 and May 30, 1986, and April 14, 1987 requesting exemptions from the requirements of Section III.G.1 Appendix R to 10 CFR 50.

This Assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

~~Daniel F. Muller~~  
Original signed by  
M. Grotenhuis

Marshall Grotenhuis, Senior Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V, and Special Projects

Enclosure:  
Assessment

cc w/enclosure  
See next page

PD3-2:LA  
LLuther:dj  
9/10/87

PD3-2:PM  
MGrotenhuis  
9/8/87

PD3-2D:  
DMuller  
9/18/87

OGC-Beth  
R. Corner  
9/17/87

Mr. L. D. Butterfield, Jr.  
Commonwealth Edison Company

Dresden Nuclear Power Station  
Units 2 and 3

cc:

Mr. Michael I. Miller  
Isham, Lincoln & Beale  
Three First National Plaza  
Suite 5200  
Chicago, Illinois 60602

Mr. J. Eenigenburg  
Plant Superintendent  
Dresden Nuclear Power Station  
Rural Route #1  
Morris, Illinois 60450

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Dresden Station  
Rural Route #1  
Morris, Illinois 60450

Chairman  
Board of Supervisors of  
Grundy County  
Grundy County Courthouse  
Morris, Illinois 60450

Regional Administrator  
Nuclear Regulatory Commission, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. Michael E. Parker, Chief  
Division of Engineering  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive, 5th Floor  
Springfield, Illinois 62704

Mr. L. D. Butterfield, Jr.  
Commonwealth Edison Company

Dresden Nuclear Power Station  
Units 2 and 3

cc:

Mr. Michael I. Miller  
Isham, Lincoln & Beale  
Three First National Plaza  
Suite 5200  
Chicago, Illinois 60602

Mr. J. Eenigenburg  
Plant Superintendent  
Dresden Nuclear Power Station  
Rural Route #1  
Morris, Illinois 60450

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Dresden Station  
Rural Route #1  
Morris, Illinois 60450

Chairman  
Board of Supervisors of  
Grundy County  
Grundy County Courthouse  
Morris, Illinois 60450

Regional Administrator  
Nuclear Regulatory Commission, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. Michael E. Parker, Chief  
Division of Engineering  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive, 5th Floor  
Springfield, Illinois 62704