

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 050-237
 UNIT NAME DRESDEN UNIT II
 DATE June, 1988
 COMPLETED BY D.C. Maxwell
 TELEPHONE (815)942-2920

REPORT MONTH APRIL, 1988 Corrected

NO.	DATE	TYPE ¹	DURATION (HOURS)	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT #	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
1	88-04-07	F	0:00	A	5	N/A	AD	XCT	2A Reactor Recirculation Pump Motor Generator (M.G.) Set tripped causing a load reduction.
2	88-04-13	S	0:00	H	5	N/A	AD	XCT	Reduced load to enter drywell to repair a 2A reactor recirc pump MG Set current transformer wiring connection.
3	88-04-27	S	0:00	H	5	N/A	SB	CPLG	Reduced load to enter drywell to repair a main steam isolation valve (MSIV) actuating air line.

8806280093 880601
 PDR ADDCK 05000237
 R PDR

1

F: Forced
 S: Scheduled

2

Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & Licensee Examination
 F-Administrative
 G-Operational Error
 H-Other (Explain)

3

Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)
 5-Load Reduction

4

Exhibit G-Instructions for
 Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File
 (NUREG-0161)

5 Exhibit I - Same Source