



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690 - 0767

August 1, 1988

Mr. Thomas E. Murley, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

**Subject: Dresden Station Units 2 and 3
Application for Amendment to Facility
Operating Licenses, DPR-19 and 25,
Appendix A, Technical Specifications
NRC Docket Nos. 50-237 and 50-249**

Dear Mr. Murley:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Section 3.8/4.8 of Appendix A, Technical Specifications to Facility Operating Licenses DPR-19 and DPR-25. The proposed changes involve the addition to Section 3.8/4.8 of provisions which assure the availability and effectiveness of the Control Room Air Filtration System that was installed in response to NUREG-0737, Item III.D.3.4.

Attachment 1 provides the proposed changes to all affected pages of DPR-19 and 25. The changes are described in the Attachment 2 summary and the Attachment 3 significant hazards evaluation.

The proposed changes have been reviewed and approved by both On-Site and Off-Site Review in accordance with Commonwealth Edison Company procedures. We have reviewed the changes in accordance with 10 CFR 50.92(c) and determined that no significant hazards consideration exists, for the reasons described in Attachment 3.

Commonwealth Edison is notifying the State of Illinois of our application for this amendment by transmitting a copy of this letter and its attachment to the designated State Official.


In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is also enclosed.

8808110237 880801
PDR ADOCK 05000237
P PDC

A046
w/check \$150
#0060126

Please direct any questions you may have regarding this matter to this office.

Very truly yours,




J. A. Silady
Nuclear Licensing Administrator

lm

- Attachments 1: Proposed Changes to Appendix A Technical Specifications for Dresden Station Units 2 and 3 Facility Operating Licenses DPR-19 and DPR-25
- 2: Summary of Proposed Changes
- 3: Evaluation of Significant Hazards Consideration

cc: B.L. Siegel - Project Manager, NRR
S.G. DuPont - Senior Resident Inspector, Dresden
M. C. Parker - IDNS

SUBSCRIBED AND SWORN TO
before me this 1st day
of August, 1988



Notary Public