

**Commonwealth Edison**

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920

July 21, 1988

EDE LTR: #88-551

Mr. A. Bert Davis
Regional Administrator
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

PRIORITY ROUTING	
First	Second
RA	RC
DRA	ETC
DRP	SGA
DRS	ML
DRSS	OL
DRMA	OT
	PAO

FILE HAS

Subject: Secondary Containment Leak Rate Test
Dresden Nuclear Power Station
Commonwealth Edison Company
Docket Nos. 50-237 and 50-249

GW

Dear Mr. Davis:

On July 8, 1988, a Secondary Containment Leak Rate Test (SCLRT) was performed on the Unit 2/3 Reactor Building. Although the SCLRT is normally performed prior to refueling outages in accordance with Technical Specification (T.S.) 4.7.C.1.c, this test was performed following observations by Operations personnel while operating the Standby Gas Treatment (SBGT) System that Reactor Building to atmosphere differential pressure indications were less than 0.25 inches of water. Although observing the reactor building differential pressure indications during the SBGT operability surveillance is indicative of secondary containment condition, actual SCLRT results will vary from these indications because the SCLRT procedure utilizes accurate local test instruments. Demonstration of SBGT system capability of maintaining 0.25 inches of water Reactor Building to atmosphere differential pressure under calm wind conditions is required by T.S. 4.7.C.1.c prior to refueling.

The SCLRT was performed in accordance with Dresden Technical Staff Surveillance (DTS) 1600-22. The result was 0.28 inches of water negative pressure in the secondary containment with respect to the atmosphere, which meets the T.S. 4.7.C.1.c criteria. This report is submitted to your attention in accordance with T.S. Table 6.6.1.

Sincerely,

E. D. Eenigenburg
Station Manager
Dresden Nuclear Power Station

EDE:RW:rg

cc: J. Kotowski

J. Brunner

J. Achterberg

A. Anandappa

J. Silady

File/T.S. File (1600)

File/NRC

File/Numerical

1878a

A017

1/0

AUG 9 1988

RETURN ORIGINAL
TO REG 3

8808240045 880721
PDR ADDCK 05000237
PDC