



**Commonwealth Edison**  
One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690 - 0767

March 16, 1989

Dr. Thomas E. Murley, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Dresden Nuclear Power Station Units 2 and 3  
Supplemental Information on Fire Protection  
License Amendment  
NRC Docket Nos. 50-237 and 50-249

References (a): Letter from J.A. Silady to T.E. Murley dated  
February 22, 1989, submitting proposed  
amendment per Generic Letter 88-12.

(b): Letter from J.A. Silady to T.E. Murley dated  
March 1, 1989.

Dear Dr. Murley:

In the Reference (a) submittal, Commonwealth Edison proposed to amend the Dresden Units 2 and 3 Operating Licenses and Technical Specifications concerning Fire Protection, in response to Generic Letter 88-12.

Attachment 5 of the Reference (a) submittal provided the proposed Dresden Administrative Technical Requirements (DATRs) for Fire Protection. In response to a question from the NRR Project Manager for Dresden, CECO intends to supplement the existing DATRs to include all Appendix R safe shutdown (SSD) equipment not already addressed either by existing Technical Specification LCO's, surveillance requirements, and remedial actions or by the existing DATR provisions for opposite unit SSD equipment.

As requested, the addition of these provisions and formal implementation of the DATRs can be accomplished within sixty (60) days of the issuance of the referenced license amendment.

8903280300 890316  
PIR ADOCK 05000237  
PDC

A006  
1/0

Also please note that the Reference (b) letter, concerning resolution of inaccessible area fire protection with opposite unit SSD equipment out of service, contained a typographical error on page 2. The installation of linear thermal detectors will be accomplished during the next Dresden Unit 3 refueling outage rather than the next Unit 2 refueling, as stated.

Please contact this office should further information be required.

Very truly yours,



J. A. Silady  
Nuclear Licensing Administrator

lm

cc: A.B. Davis - Regional Administrator, RIII  
B.L. Siegel - Project Manager, NRR  
S.G. DuPont - Senior Resident Inspector, Dresden  
Office of Nuclear Reactor Safety - IDNS