



**Commonwealth Edison**  
72 West Adams Street, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690 - 0767

June 12, 1989

Dr. Thomas E. Murley, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Dresden Station Units 2 and 3  
Quad Cities Station Units 1 and 2  
Application for Amendment to Facility  
Operating Licenses DPR-19, 25, 29 and 30  
Appendix A, Technical Specifications  
NRC Docket Nos. 50-237/249, 50-254/265

References (a): D.R. Muller to D.L. Farrar letter  
dated June 25, 1987

(b): T. Ross to L.D. Butterfield letter  
dated July 27, 1987

Dr. Murley:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Appendix A, Technical Specifications to Facility Operating Licenses DPR-19, 25, 29 and 30 for the Dresden and Quad Cities Nuclear Power Stations. In reference (a) and (b), the NRC indicated that Draft 7 of Revision 3 to NUREG-0473 identifies inhalation as the most limiting pathway with the child's thyroid as the critical organ for dose calculations. The proposed amendment revises the dose calculation to reflect the critical receptor and pathway to be consistent with NUREG-0473. These changes are listed in Attachment 1 and further described in Attachments 2 and 3.

The proposed changes have been reviewed and approved by both On-site and Off-site review in accordance with Commonwealth Edison Company's procedures. The proposed amendments have been reviewed in accordance with 10 CFR 50.92(c) and it has been determined that no significant hazards consideration exists. This evaluation is documented in Attachment 4.

8906200339 890612  
PDR ADOCK 05000237  
P PDC

2

A009  
/

Commonwealth Edison is notifying the State of Illinois of our application for this amendment by transmitting a copy of this letter and its attachments to the designated State Official. This Technical Specification amendment will be implemented sixty (60) days following the receipt of NRC approval.

Please direct any questions you may have regarding this matter to this office.

Very truly yours,



R. Stols  
Nuclear Licensing Administrator

lb

- Attachments 1: Proposed Changes to Appendix A Technical Specifications for Dresden Units 2 and 3 and Quad Cities Units 1 and 2
- 2: Summary of Changes
  - 3: Description and Bases for Amendment Request
  - 4: Evaluation of No Significant Hazards
  - 5: References

cc: Regional Administrator - Region III  
Office of Nuclear Safety (INDS)  
T.M. Ross - Project Manager, NRR  
B. Siegel - Project Manager, NRR