

Enclosure 1

NEDO-10115  
69 NED 37  
CLASS I  
July 1969

**MECHANICAL PROPERTY SURVEILLANCE OF  
GENERAL ELECTRIC BWR VESSELS**

J. P. Higgins  
F. A. Brandt

Approved:



J. F. Cagle, Manager  
Component Engineering

**ATOMIC POWER EQUIPMENT DEPARTMENT**

**GENERAL  ELECTRIC**

**SAN JOSE, CALIFORNIA**

9004060027 900323  
PDR ADOCK 05000237  
P PIC

TABLE OF CONTENTS

<b>Abstract</b>	1
<b>1. Summary</b>	1
<b>2. Introduction</b>	1
<b>3. Technical Basis</b>	2
<b>4. Operating Philosophy</b>	5
4.1 Neutron Flux	6
4.2 Radiation Effects on A302B/A533B Steel	6
4.3 Radiation Effects in Weld and Weld HAZ Material	6
4.4 Combined Testing	6
<b>5. Program</b>	6
5.1 Implementation	6
5.2 Type of Specimens	7
5.3 Materials	7
5.4 Basket and Capsule Design	7
5.5 Capsule Loading	7
5.6 Specimen Locations	7
5.7 Capsule Dosimeters and Temperature Monitor	8
5.8 Vessel Wall Dosimeters	8
5.9 Typical Program	8
5.10 Specimen Testing and Reports	8
<b>References</b>	9

APPENDIX

<b>A. Drawings</b>	11
<b>B. Preparation of Base Metal Sample Material</b>	35
<b>C. Three-Digit, Twenty-Symbol Marking System (FAB Code)</b>	37
<b>D. Description of Flux Monitors</b>	39
<b>E. Capsule Handling and General Suggestions for Carrying out the Program</b>	41
<b>Distribution</b>	43

**LIST OF ILLUSTRATIONS**

<b>Figure</b>	<b>Title</b>	<b>Page</b>
1	The Effect of Irradiation on Various Heats of A302B Steel . . . . .	3
2	The Effect of Irradiation on Various Heats of A302B/A553B-Class 1 . . . . .	4

**LIST OF TABLES**

<b>Table</b>	<b>Title</b>	<b>Page</b>
1	Calculated Maximum Vessel Wall Fluence Levels For Standard GE Plants . . . . .	2
2	Most Conservative Estimate of Minimum Pressure Test Temperature (°F) for 40-Year Lifetime . . . . .	5
3	Specimens Furnished for Typical Surveillance Program . . . . .	9
C-1	FAB Code - December 1963 . . . . .	38

## ABSTRACT

*The General Electric Company furnishes pressure vessel steel surveillance specimens for each BWR to permit the plant owner to account for radiation-induced changes in mechanical properties of the reactor vessel during service. This report presents several methods for determining the magnitude of these property changes. It also describes the specimens, specimen inventory, capsule design, associated equipment, material selection, and instructions for handling the specimens if they are tested.*

### 1. SUMMARY

General Electric (GE) furnishes a special set of specimens with each Boiling Water Reactor (BWR) which may be used to monitor the effect of fast neutron fluence on the mechanical properties of the reactor vessel steel. At the fast neutron fluence levels for the 40-year lifetime of current BWR's these changes are minimal. This report suggests a variety of ways in which these potential radiation-induced changes may be accounted for in the operation of BWR power plants.

Tensile test and Charpy V-notch test bars representing the reactor-pressure-vessel base metal, weld metal and weld-heat-affected-zone (HAZ) metal, and neutron flux dosimeters are installed in the vessel. Sufficient samples are provided to measure changes to vessel mechanical properties throughout the vessel life if they are removed and tested periodically by the owner. These specimens are placed in the reactor for insurance and for economic reasons. They may be used to give *absolute measurement* of any change in mechanical properties, if required, or they may be used to demonstrate that the pressure vessel material is less sensitive to radiation effects than material of this type as defined by a conservative published curve.

Exposure levels in the BWR cause no change in tensile properties for A302B/A533B steel which would affect plant operation. The nil-ductility transition temperature (NDT) of this steel is increased by exposure to neutron fluences greater than  $10^{17}$  nvt. A large body of experimental data has been gathered to document the extent of this change. Calculations for predicting neutron fluence at the vessel wall are being verified by experimental techniques, and it will soon be possible to relate electrical power output of the plant to neutron fluence at the wall with absolute confidence.

When the neutron fluence is known, it can be related to published curves of shift in transition temperature versus fluence to provide a conservative measure of the minimum temperature where the reactor vessel material will remain ductile. The plant owner thus has a variety of choices to account for mechanical property changes. These include measuring or calculating the maximum vessel-wall fast neutron fluence and either testing irradiated specimens or using published data to relate neutron fluence to radiation-induced property change.

### 2. INTRODUCTION

Pressure vessel steels in nuclear power plants are exposed to an environment of neutron flux and temperature which may produce a measurable effect on the mechanical and physical properties of vessel material. From the viewpoint of the plant operator, changes in the nil-ductility transition temperature of the pressure vessel are of interest. The temperature where ferritic steels may break in a brittle rather than a ductile mode is raised by exposure to a neutron fluence greater than  $10^{17}$  nvt ( $> 1$  MeV). Therefore, some adjustment of the minimum vessel pressurization temperature may be required to accommodate shifts in the NDT. The tensile yield strength is increased and ductility is

decreased by exposures above  $10^{18}$  nvt ( $> 1$  MeV). No action on the part of the plant operator is necessary to accommodate changes in the vessel steel tensile properties. General Electric recommends the minimum vessel pressurization temperature be at least 60°F above the NDT to assure ductile behavior of the vessel material.

The predicted maximum vessel wall fluence for the current BWR product line is presented in Table 1. Note that these numbers are calculated conservatively since they assume the plant operates at 100 percent power, 100 percent of the time during a 40-year plant life. Sound practice

requires that any radiation-induced changes in the NDT temperature, although small at these fluence levels, be accounted for in plant operation. General Electric furnishes

special groups of test specimens for each BWR and provides the owner with several options to determine the extent of pertinent radiation-induced mechanical property changes.

Table 1  
CALCULATED MAXIMUM VESSEL WALL FLUENCE  
LEVELS FOR STANDARD GE PLANTS

Vessel Inner Diameter	Number of Fuel Elements	Thermal Power Rating (MW)	Maximum Wall Neutron Flux (nv > 1 MeV)	40-Year Neutron Fluence <sup>1</sup> (nv > 1 MeV)
183	368	1590	$1.1 \times 10^9$	$1.4 \times 10^{18}$
218	548	2380	$5.5 \times 10^8$	$7.0 \times 10^{17}$
218	560	2440	$6.8 \times 10^8$	$8.6 \times 10^{17}$
251	764	3440	$3.0 \times 10^8$	$3.8 \times 10^{17}$
269	880	4240	$1.4 \times 10^8$	$1.7 \times 10^{17}$

Note 1. Calculation assumes 100% power, 100% of the time during plant life.

### 3. TECHNICAL BASIS

Considerable data are available relating neutron fluence to change in NDT for ferritic materials. For A302B/A533B - Class I steels, these data are usually based on the 30 ft-lb Charpy V-notch energy transition temperature which has been correlated<sup>1</sup> with the dropweight specimen NDT for this steel. Figure 1 shows results from earlier work performed by Carpenter, et al., on the effect of neutron radiation on various heats of A302B/A533B - Class I steel exposed to reactor operating conditions.<sup>2</sup> Note the curves and equations for radiation-sensitive heats (upper and lower curves respectively). Figure 2 presents a comparison of the basic Carpenter<sup>2</sup> reference data shown in Figure 1 against results of several GE-BWR surveillance programs. In addition, Figure 2 includes the curves and equations for the upper limit for the original Carpenter data

(upper curve labeled *worst-case*) as well as the upper limit for GE-BWR operating experience. The upper *worst-case* curve represents the most conservative, technically justified estimate of the radiation sensitivity of A302B/A533B - Class I steel. The lower curve reflects the upper limit for GE 550°F BWR operating experience. Note that the GE data include radiation effects on A302B/A533B - Class I weld and weld HAZ material as well as base metal.

Tabulated results of how the minimum pressure test temperature may be adjusted, provided the fluence for a given period of time is known, are given in Table 2. These results are based on *worst-case* performance on material with an initial NDT of 40°F and include the 60°F margin above NDT required by the GE Technical Specifications.




Figure 1. The Effect of Irradiation on Various Heats of A302B Steel "Sensitive" and "Insensitive" Irradiation Behaviors are Demonstrated by the Upper and Lower Curves, Respectively. (By permission of the American Nuclear Society, Sept 8, 1964)

GENERAL ELECTRIC  
SURVEILLANCE PROGRAM TEST RESULTS  
PLOTTED FOR COMPARISON WITH REFERENCE DATA (2)

- ◇ DNPS - BASE METAL
- ◆ DNPS - WELD METAL
- ◊ DNPS - HAZ
- BIG ROCK - BASE METAL
- BIG ROCK - WELD METAL
- ⊙ BIG ROCK - HAZ
- ◇ HUMBOLDT - BASE METAL
- ◆ HUMBOLDT - WELD METAL
- ◊ HUMBOLDT - HAZ




Figure 2. The Effect of Irradiation on Various Heats of A302B/A533B-Class 1.

Table 2  
**MOST CONSERVATIVE ESTIMATE\* OF MINIMUM  
 PRESSURE TEST TEMPERATURE (°F)  
 FOR 40-YEAR LIFETIME**

Years of Operation	Projected Neutron Fluence (nvt > 1 MeV)						
	$5 \times 10^{16}$	$1 \times 10^{17}$	$2 \times 10^{17}$	$5 \times 10^{17}$	$1 \times 10^{18}$	$2 \times 10^{18}$	$5 \times 10^{18}$
0	100	100	100	100	100	100	100
5	100	100	100	108	115	128	165
10	100	100	100	115	128	155	200
15	100	100	106	122	142	174	220
20	100	100	112	130	155	190	242
25	100	103	115	136	165	200	251
30	100	106	118	142	174	210	262
35	100	109	121	148	182	220	277
40	100	112	125	155	190	230	295

\* Based on maximum initial 40°F NDT plus required 60°F margin and worst-case radiation sensitivity curve for A302B/A533B - Class I:  $(\Delta T T)^{\circ F} = 1228 - 1475 \log (\phi t) + 44.5 [\log (\phi t)]^2$

#### 4. OPERATING PHILOSOPHY

Surveillance programs for early nuclear power plants were development oriented since, at the time of their construction, there were little data available on the effect of neutron radiation on pressure vessel steels. As results from these early surveillance programs and other General Electric environmental exposure development programs have become available, sufficient data have been generated for A302B/A533B steel to develop empirical equations adequate to predict the effect of various nuclear environments.

This increased information, coupled with a design change in the BWR which has reduced the neutron fluence at the vessel wall, has lessened the necessity for testing surveillance specimens to monitor mechanical property changes. It is now possible to relate the calculated or measured neutron fluence at the vessel wall to mechanical property changes by using published data. For the present generation of BWR plants, GE provides a standard series of surveillance specimens plus a special flux monitor capsule.

The owner now has multiple options to determine any radiation-induced changes in mechanical properties. These options are presented in the succeeding sections.

In this regard, special attention should be called to the fact that changes in the NDT need be considered only if the owner, for whatever reason, chooses to pressurize the reactor vessel prior to power operation. The mode of operation of a BWR does not depend on pressurization by external means. The 1000 psi - 550°F operating conditions are dictated solely by the physical characteristics of the BWR coolant. This pressure-temperature relationship results in no appreciable stress on the reactor vessel until the water coolant temperature is in excess of 400°F (well above any temperature where potential shifts in the NDT become a factor for consideration). Further, there is no normal operating mode which would require that a BWR be pressurized at temperatures below where boiling would occur. Under these circumstances, surveillance of radiation-induced mechanical property changes become academic.



## NEUTRON FLUX

The fast neutron flux at the vessel wall may be determined by either of the following techniques.

4.1.1 The neutron flux may be determined by analyzing dosimeter wire. This need be done only once, preferably after 1 year of operation or the first scheduled plant shut-down. Since there is a direct linear relationship between thermal power generation and neutron flux, the fluence at the vessel can be accurately calculated at any given time.

4.1.2 An alternate approach would be to compute the flux at the vessel wall based on nuclear considerations. This can be done currently with a slight risk of gross error. This risk will be eliminated within 5 years by experimental work. The neutron fluence in BWR plants is so low that even gross errors will cause no operating risk.

## 4.2 RADIATION EFFECTS ON A302B/A533B STEEL

The owner may account for radiation effects on A302B/A533B vessel steel by utilizing any of the four methods outlined below.

The upper limit for GE-BWR data relating change in 30 ft-lb transition temperature to fluence as shown in Figure 2 may be used. There is some risk that a particular heat of steel may be more sensitive than the curve indicates, although the data include sufficient points to make this risk very low. The low BWR neutron fluence reduces the risk even more.

4.2.2 A more conservative approach is to use the upper boundary for all data developed for this steel (worst-case) including BWR, PWR, and test reactor experimental data (Figure 2). This method may prove to be costly in terms of extra time and expense for preheating the reactor vessel prior to hydrotest.

4.2.3 A third approach is to test one set of impact specimens irradiated in the reactor to establish the radiation sensitivity of the material. This option should be considered only if the cost of preheating the vessel to the higher temperature dictated by a conservative curve per 4.2.1 or 4.2.2

exceeds the cost of testing specimens. It incurs a secondary risk that the test may demonstrate that the material is as sensitive as the conservative curve.

4.2.4 Finally, the owner may choose to test all the impact specimens over the life of the plant. There is little engineering and no economic incentive to do this since so much data for A302B/A533B steel are already available.

## 4.3 RADIATION EFFECTS IN WELD AND WELD HAZ MATERIAL

The owner may account for radiation effects in weld and weld HAZ of A302B/A533B material by any of the four following methods.

4.3.1 The upper limit for GE-BWR data (Figure 2) may be used. At present, this involves some uncertainty since limited data are available for these materials. The risk is low because of the low neutron fluence of the BWR.

4.3.2 A more conservative approach is to use the *worst-case* curve for base material. This includes results from a wide variety of heats and radiation temperatures ranging from 450 to 575°F. By analogy, the weld and weld HAZ metal can be expected to behave no worse than the worst of these. Use of this curve may be costly for reasons given in 4.2.2 above.

4.3.3 A third option is to test one set of impact specimens for economic reasons per the rationale developed in 4.2.3.

4.3.4 A final choice is to test all impact specimens over the life of the plant to develop additional data with the objective of developing a more reliable empirical curve.

## 4.4 COMBINED TESTING

If the owner decides to test irradiated specimens and exercises options 4.2.3, 4.2.4, 4.3.3, or 4.3.4, he should consider combining forces with other nuclear power reactor owners to establish either one-point or three-point curves by irradiating the steels from each reactor vessel in a single experiment, in one reactor and having all post-irradiation tests performed at the same laboratory at one time.

## 5. PROGRAM

### IMPLEMENTATION

The surveillance specimens must accurately represent the pressure vessel to be monitored. Accurate measurement or calculation of the maximum neutron flux at the vessel

wall is required. Good equipment design is required to assure accurate specimen positions and protection for long periods, and yet allow inexpensive fabrication and post-irradiation handling.

General Electric provides tensile and Charpy V-notch mechanical test specimens from the reactor vessel base metal, weld HAZ metal, and weld metal from a joint made on the reactor steel which simulates a welded joint in the reactor vessel. Neutron dosimeter wire is included with each group of specimens. Specimens are placed near the reactor vessel wall where the exposure is similar to that of the vessel wall.

## 5.2 TYPE OF SPECIMENS

Small tensile specimens (see Drawing 921D276\*) are provided and may be used to measure the effect of neutron irradiation on the yield strength, and ductility of the pressure vessel materials.

Standard Charpy V-notch specimens (see Drawing 921D277) are provided and may be used to measure the effect of neutron irradiation on the fracture energy transition temperature of the pressure vessel materials.

## 5.3 MATERIALS

Charpy V-notch and tensile specimens are made from the base metal used to fabricate the vessel (see Appendix B). The specimens are made from flat slabs cut parallel to and one-quarter plate thickness from both of the plate surfaces, and are machined with their longitudinal axis parallel to the plate rolling direction. The notches of the Charpy specimens are cut perpendicular to the plate surface.

A test weld representing a vessel welded joint is fabricated from vessel base material. Charpy and tensile specimens representing the weld HAZ and the weld metal are fabricated from the test weld material.

The weld Charpy specimens are made transverse to the weld direction; thus, only the central section of the specimen is necessarily composed of weld-deposited metal. Specimens are taken throughout the weld section to a distance of 3/4 inch from the weld root. Their long axes are parallel to the plate surface and normal to the weld length. The Charpy notch is made perpendicular to the plate surface.

The gage lengths of the weld tensile specimens are made entirely of weld metal by taking the specimens parallel to the weld length and parallel to the plate surface.

The weld HAZ tensile specimens are made transverse to the weld length and parallel to the plate surface. The center of the specimen is located at the joint between the base metal and weld deposit

The weld HAZ Charpy specimens are made transverse to the weld length and parallel to the plate surface. The axis

of the notch is perpendicular to the plate surface, and the notch radius is located at the intersection of the base metal and weld deposit.

All specimens are marked with FAB Code (see Appendix C) on one end.

## 5.4 BASKET AND CAPSULE DESIGN

The tensile and impact specimens are placed in capsules which are held in capsule baskets. These baskets are in turn fastened to a holder (Drawing 117C3910) and suspended from a bracket on the reactor vessel wall inside diameter. The capsule basket (Drawing 117C3911) is binary coded according to the reactor number and sequence. The identification number system for various GE reactors is contained in Drawing 129B3578.

The basket confines the capsules to a small area, which ensures that the neutron fluence for each capsule will be similar. It reduces the amount of reactor handling at removal time because only one transfer is required. It also reduces the number of vessel brackets required in the reactor structure to hold the specimens. The basket can serve as a container for storage or shipping if the specimens are to be tested in a hot laboratory.

The irradiation capsules are designed to hold the specimens in a dry helium atmosphere in a small space to reduce neutron flux variation among the samples. The tensile capsule is a thin-wall tube. An aluminum filler piece is used to ensure good heat flow between the specimen gage length and the capsule wall (Drawing 117C3912). The impact capsule is a rectangular box (Drawing 117C3913) with thin walls. Reactor water pressure assures good contact between the capsule wall and the specimens. Under these conditions, gamma heat produced in the specimen flows out of the capsule with a minimum gradient, and the specimen temperature is close to the water temperature.

## 5.5 CAPSULE LOADING

Two tensile specimens are placed in each tensile capsule. These capsules are FAB-coded on one end. Drawing 117C3912 shows a typical tensile specimen capsule loading. Twelve impact specimens, an iron, a nickel, and a copper dosimeter wire are placed in each impact capsule. The impact capsules are binary-coded sequentially as shown in Drawing 117C3913.

## 5.6 SPECIMEN LOCATIONS

The specimens are positioned at three locations in the reactor vessel adjacent to the inner vessel wall at positions radially adjacent to the core mid-plane where the neutron flux will be highest. Typical locations are shown in Drawing 921D435. These specimens are exposed to a neutron flux with a rate and spectrum similar to that of the vessel wall.

\* All drawings are shown in Appendix A.

### 5.7 CAPSULE DOSIMETERS AND TEMPERATURE MONITOR

Each impact capsule contains iron, nickel, and copper wire dosimeters. These dosimeters can be used to determine the neutron fluence by performing radiochemical analyses for the particular nuclear reaction of interest as outlined in Appendix D. These radiochemical measuring techniques require great care to attain valid results.

Because the boiling water reactor is a constant-temperature device, no special temperature monitoring devices are required.

### 5.8 VESSEL WALL DOSIMETERS

The specimen capsules and their flux monitors are always a finite distance from the reactor pressure vessel wall. If one is to calculate the neutron fluence at the pressure vessel wall using data from the capsule flux monitors, he must know the exact location of the capsule monitor with respect to the wall and the flux gradient between the capsule monitor and the wall. Since the flux gradient is very steep, small errors in determining the position or the amount of the gradient can cause gross errors in calculating the wall fluence. This error will always be conservative but it can be an economic problem since it may lead to excessive preheating costs. General Electric provides a precise measurement of the distance between the capsules and the wall. In addition, one capsule basket has special iron and copper dosimeter wire contained in a capsule holder (Drawing 158B7636) located as close as practical to the

wall. These dosimeters (Drawing 158B7636) can be removed independently of the surveillance samples. General Electric recommends that for plants where the owner decides to measure one of these monitors that it be removed during the first refueling outage since the iron dosimeter wire is most accurate for a period of about 1 year.

### 5.9 TYPICAL PROGRAM

Capsules are installed in the reactor prior to startup. Capsule removal schedules may vary, depending on the type of information needed, which, in turn, depends on the integrated neutron flux at the vessel wall. A list of specimens included in a typical surveillance program is presented in Table 3.

Details of all specimens with their locations in the capsules, all capsules with their locations in the baskets, and all baskets with their locations in the reactor, are shown on drawings in Appendix A.

### 5.10 SPECIMEN TESTING AND REPORTS

The specimens must be tested under special conditions, using remote handling and shielding. Such tests are made most conveniently in a radioactive materials laboratory. Careful supervision of all tests is required to assure accurate results and to avoid wastage of the limited number of specimens. Suggestions for capsule handling and testing are given in Appendix E. Reports should be requested for each batch of specimens removed and tested.

**Table 3**  
**SPECIMENS FURNISHED FOR**  
**TYPICAL SURVEILLANCE PROGRAM**

Reactor Group Number	Type Specimen	Number of Specimens		
		Base	Weld	HAZ
Unirradiated Base-Line Specimens				
	C(a)	12	12	12
	T(b)	3	3	3
In-Reactor Specimens				
1	C	12	12	12
	T	2	2	2
2	C	8	8	8
	T	2	2	2
3	C	8	8	8
	T	2	2	2
Out of Reactor Spares				
	C	12	12	12
	T	3	3	3
Total Specimens				
	C	52	52	52
	T	12	12	12

(a) C = standard Charpy V-notch impact specimen

(b) T = 1/4 inch gage diameter tensile specimen

### REFERENCES

1. Pellini, W. S., and Puzak, P. P., *Practical Considerations in Applying Laboratory Fracture Test Criteria to the Fracture-Safe Design of Pressure Vessels*, Journal of Engineering for Power, Trans. ASME, Vol. 86 - Series A - No. 4, 1964, pp. 429-443.
2. Carpenter, G. F., Knopf, N. R., and Byron, E. S., *Anomalous Embrittling Effects Observed During Irradiation Studies on Pressure Vessel Steels*, Nucl. Sci. Eng., 19, 18-38 (1964).
3. *Recommended Practice for Surveillance Tests on Structural Materials in Nuclear Reactors (E185)*, Book of ASTM Standards, Part 31 (1964).

**APPENDIX A**

**DRAWINGS**

The following drawings are contained in this appendix.

<b>129B3578</b>	<b>Surveillance Program Number Identification of GE Reactors</b>
<b>921D435</b>	<b>Surveillance Program</b>
<b>921D277</b>	<b>Charpy Impact Specimen</b>
<b>921D276</b>	<b>Tensile Test Specimen</b>
<b>117C3910</b>	<b>Specimen Holder Surveillance Program</b>
<b>117C3911</b>	<b>Capsule Basket</b>
<b>117C3912</b>	<b>Tensile Specimen Capsule</b>
<b>117C3913</b>	<b>Impact Specimen Capsule</b>
<b>158B7636</b>	<b>Capsule Holder</b>
<b>158B7635</b>	<b>Neutron Dosimeter</b>

GENERAL ELECTRIC

ON SHEET  
UNLESS OTHERWISE SPECIFIED USE THE FOLLOWING—

APPLIED PRACTICES	SURFACES	TOLERANCE ON MACHINED DIMENSIONS	REV. NO. <b>225</b>
	✓	± — ± — ± — ± —	TITLE
			<b>129B357B</b>
			CONT. ON SHEET 2 SH. NO. 1

TITLE  
**SURVEILLANCE PROGRAM NUMBER IDENTIFICATION OF G.E. REACTORS**

CONT. ON SHEET  
SH. NO.

REACTOR NO.	PLANT NAME	SURVEILLANCE PROGRAM DWG.	BINARY CODE
1	VBWR (G.E.)		0 0 0
2	DRESDEN UNIT #1 (COMMONWEALTH EDISON)	197E793SH12	0 0 0
3	GARIGLIANO POWER STA. (SENN)	117B1400	0 0 0
4	JPDR (JAERI)		0 0 0
5	BIG ROCK POINT N.S. (CONSUMERS POWER)	104B1343SH3	0 0 0
6	HUMBOLDT BAY UNIT 3 (PG&E)	104B1099SH3	0 0 0
7	VESR (G.E.)	104R667SH3	0 0 0
8	DODEWAARD POWER STA. (SEP-GKN)		0 0 0
9	TARAPUR (GOV'T OF INDIA)	129B3807	0 0 0
10	KRB (RWE-BAYERNWERK)	129B3806	0 0 0
11	NINE MILE POINT N.S. (NIAGARA MOHAWK)	129B3891	0 0 0
12	OYSTER CREEK UNIT #1 (JERSEY CENTRAL)	129B3892	0 0 0
13	DRESDEN UNIT #2 (COMMONWEALTH EDISON)	921D401	0 0 0
14	SANTA MARIA DE GARONA (NUCLEONOR)	ZB-1969-13	0 0 0
15	MILLSTONE (CONN. LIGHT AND POWER, HARTFORD ELECTRIC LIGHT, WESTERN MASS. ELECTRIC CO.)	921D406	0 0 0
16	PILGRIM (BOSTON EDISON)	921D507	0 0 0
17	TSURUGA (JAPC)	921D225	0 0 0
18	DRESDEN UNIT #3 (COMMONWEALTH EDISON)	921D401	0 0 0
19	MONTICELLO (NORTHERN STATES POWER)	921D435	0 0 0
20	QUAD CITIES #1 (COMMONWEALTH EDISON)	886D477	0 0 0
21	QUAD CITIES #2 (COMMONWEALTH EDISON)	886D477	0 0 0
22	FUKUSHIMA 1 (TEPCO)	921D457	0 0 0
23	BROWNS FERRY 1 (TVA)	921D456	0 0 0
24	VERMONT YANKEE (CENTRAL VT. PUBLIC SERV & GREEN MT. PWR CORP)	921D514	0 0 0
25	PEACH BOTTOM 2 (PHIL. ELECTRIC)	921D496	0 0 0
26	BROWN FERRY 2 (TVA)	921D456	0 0 0
27	PEACH BOTTOM 3 (PHIL. ELECTRIC)	921D496	0 0 0
28	J. FITZPATRICK (PWR. AUTHORITY ST. OF N.Y.)	921D465	0 0 0
29	LILCO (LONG ISLAND LIGHTING CO.)		0 0 0
30	COOPER STATION (CONSUMERS PUBLIC PWR.)	921D709	0 0 0
31	BROWNS FERRY 3 (TVA)	921D456	0 0 0
32	BELL STATION (N.Y. STATE G & E)		0 0 0

NOTES:  
1. THE HOLE PATTERN IS A BINARY NUMBER MADE BY ADDING THE VALUES OF THE HOLES AS INDICATED BELOW.

1 2 4 8  
0 0 0 0 ← CODING REF. HOLES  
(THIS METHOD USED FOR REACTORS 1 THRU 7)

1 2 4 8 16  
0 0 0 0 0 ← CODING REF. HOLES  
(THIS METHOD USED FOR REACTORS 8 THRU 31)

1 2 4 8 16 32  
0 0 0 0 0 0 ← CODING REF. HOLES  
(THIS METHOD USED FOR REACTORS 32 THRU 63)

REVISIONS	PRINTS TO
4 <i>10/13/69</i> H.H.T. 3 <i>10/13/69</i> H.H.T.	GP <sup>2</sup>
ADDED SHEET 2. ADDED DWG. N. TO REACTORS NO. 16, 22 THRU 27 & 31, 11.6.11	RV <sup>2</sup>
5 <i>10/13/69</i> H.H.T. NE-22438 <i>10-13-69</i>	SC <sup>2</sup>

MADE BY: **P. LOVIER, OCT. 4, 1965**  
 APPROVED: **M.S.H. 10-5-65**  
 LOCATION: **SAN JOSE**  
 TITLE: **129B357B**  
 CONT. ON SHEET 2 SH. NO. 1

CHK'D BY: *W. Swann*  
 10-13-68  
 WCS 1-27-69

GENERAL ELECTRIC

ON HS 13345 WD INCO	ON SHIPPED	UNLESS OTHERWISE SPECIFIED USE THE FOLLOWING:—	REV NO <b>05</b>	TITLE <b>SURVEILLANCE PROGRAM NUMBER IDENTIFICATION OF G.E. REACTORS</b>
		APPLIED PRACTICES	SURFACES ✓	TOLERANCES ON MACHINED DIMENSIONS
		+ —	FRACTIONS + —	DECIMALS + —
		—	—	ANGLES + —
		CONT ON SHEET <b>F</b>		SH NO. <b>2</b>

REACTOR NO.	PLANT NAME	SURVEILLANCE PROGRAM DWG.	BINARY CODE
33	FUKUSHIMA II (TEPCO)	921D471	0 0000
34	AKM (BERNISCHE KRAFT WERK)	ZB-1969-16	0 0000


REVISIONS	PRINTS TO
	GP <sup>2</sup>
	RV <sup>2</sup>
	SC <sup>2</sup>

FOR REVISIONS SEE SHEET 1.

MADE BY <i>W. S. Swan</i> Jan 21 '69	APPROVALS R J <i>Swan</i>	APED SAN JOSE	OFF OR DUP	129B3578
FIELD H. H. <i>Swan</i> Feb 13 '69	2-11-69	LOCATION	CONT ON SHEET	SH NO. 2

CHK'D BY: W. S. Swan 1-27-69

R



GENERAL ELECTRIC

92/D-35

SURVEILLANCE PROGRAM

MISCELLANEOUS

PL 13518D

FCR-710E963(2-100)

DATE	BY	CHKD
11/11/51	SAW	SAW

92/D-35


SAW


11/11/51

17/18









UNLESS OTHERWISE SPECIFIED USE THE FOLLOWING—		TITLE AS SHOWN		GENERAL ELECTRIC		117C3910	
APPLIED PRACTICES	SURFACES	FINISHES	STRAIGHTENING	DRILLING	REWORK	SPECIMEN HOLDER	
145A5481	✓	✓	✓	✓	✓	FIRST MADE FOR SURVEILLANCE PROGRAM	
						PL ISSUED	
						FCF-61-93-9210435	

REVISIONS	DATE	BY	CHKD
1	11/10/54	W. K. ...	SC
2	11/10/54	W. K. ...	SC
3	11/10/54	W. K. ...	SC

APPROVED	DATE	117C3910
W. K. ...	11/10/54	
CHKD BY	DATE	
W. K. ...	11/10/54	

117C3910

GENERAL ELECTRIC


117C39/1

UNLESS OTHERWISE SPECIFIED USE THE FOLLOWING --

APPLIED PRACTICES	SURFACES	FINISHES	WELDING	THREADS	COATING
145A5481	✓				

TITLE  
**CAPSULE BASKET**  
FIRST MADE FOR SURVEILLANCE PROGRAM  
PL ISSUED

FCF: G1-G3-117C39/0



GROUP	HOLE PATTERN	FIG.
1	● ○ ○ ○	1
2	○ ● ○ ○	2
3	○ ○ ○ ●	3



- NOTES:
- THE HOLE PATTERN IS A BINARY NUMBER MADE BY ADDING THE VALUES OF THE HOLES AS INDICATED BELOW:  

1	2	4	8
●	●	●	●
○	○	○	○

 CODING REFERENCE HOLES
  - THE HOLE PATTERN IS A BINARY NUMBER MADE BY ADDING THE VALUES OF THE HOLES AS INDICATED BELOW:  

1	2	4	8
○	○	○	○
○	○	○	○

 CODING REFERENCE HOLES
  - ARRANGEMENT OF CAPSULES P4 TO P13 WITHIN CONTAINER IS OPTIONAL
  - INSTALL HANDLE P3 FIRMLY AGAINST STACK OF CAPSULES & SPACERS TO TAKE UP ALL END PLAY OF PARTS, AND WELD.





REVISED	ISSUED	DATE	BY	FOR
1	1	11-11-60	W.S.	SC 1
				AP-1

APED SAN JOSE 117C39/1

CHK'D BY 10-3-60

117C39/1





APPLIED SURFACES		SURFACES		APPLIED SURFACES		SURFACES		APPLIED SURFACES		SURFACES	
145A.5481	✓										

GENERAL ELECTRIC 117C3913

IMPACT SPECIMEN CARPULE

FIRST MADE FOR SURVEILLANCE PROGRAM PL ISSUED

FCF: 61-65-117C3911  
66-610-117C4370

- NOTES:
- THE HOLE PATTERN IS A BINARY NUMBER MADE BY ADDING THE VALUES OF THE HOLES AS INDICATED BELOW:  
 . 1 2 4 8 16  
 . . . . . - CODING REFERENCE HOLES
  - EXHAUST AIR TO REDUCE CAPSULE INTERNAL PRESSURE TO ONE (1) TORR. BACKFILL WITH WELDING GRADE HELIUM AT ATMOSPHERIC PRESSURE AND SEAL WELD HOLE.
  - MASS SPECTROMETER LEAK TEST COMPLETED ASSEMBLY. ALLOWABLE LEAKAGE 1x10<sup>-6</sup> CC/MIN.

GROUP	HOLE PATTERN				
1	●				
2		●			
3	●	●			
4			●		
5	●	●			
6	●	●	●		
7	●	●	●		
8				●	
9	●			●	
10	●	●	●	●	

REVISIONS	DATE	BY	CHKD
1	11/18/68	EMF	SC
NE-22234			

117C3913


APPROVED: [Signature] DATE: 11/18/68

SAV JOSE

117C3913

CHD 41: 10-5-68

117C3913



REVISIONS	PRINTS TO
1	SC <sup>2</sup>
NE 21155 (MKS 6-19-67)	EM-2
	GP <sup>2</sup>

MADE BY: <i>APED</i> DATE: <i>02-22-68</i>	APPROVED: <i>APED</i>	LOCATION: <i>SAN JOSE</i>	REV NO: <i>01</i>
ISSUED: <i>14/68</i>	DATE: <i>14/68</i>	LOCATION: <i>SAN JOSE</i>	REV NO: <i>01</i>

CHK'D BY: *W. Sauer 10-30-68* R

GENERAL ELECTRIC


UNLESS OTHERWISE SPECIFIED USE THE FOLLOWING:—			REV NO. 0
APPLIED PRACTICES 209A4270.	SURFACES ✓	TOLERANCES ON MACHINED DIMENSIONS FRACTIONS DECIMALS ANGLES + — + — + —	158B7635 CONT ON SHEET SHE NO

TITLE *ASM*  
**NEUTRON DOSIMETER**  
 FIRST MADE FOR *SEARVEILLANCE PROGRAM*  
 PL ISSUED

FCF:G1-886D345

NOTES:

- BEFORE ASSEMBLING P2 EXHAUST AIR TO REDUCE CAPSULE INTERNAL PRESSURE TO ONE (1) TORR. BACKFILL WITH WELDING GRADE HELIUM AT ATMOSPHERIC PRESSURE AND SEAL WELD HOLE.
- MASS SPECTROMETER LEAK TEST COMPLETED ASSEMBLY ALLOWABLE LEAKAGE  $10^{-6}$  CC/MIN.
- WELDING PER 209A4290



METAL STAMP WITH  
 12 ± .01 HIGH CHARACTERS  
 158B7635 G1-SER. NO.

SER. NO. FURN. BY MANUF.

REVISIONS	PRINTS TO
	RV <sup>2</sup>
	EM-2
	PR-1
	GP <sup>2</sup>

MADE BY R. J. ...	DATE Oct 22, 1968	APPROVED BY APED	DIV OR LOCATION SAN JOSE	158B7635
BY H. H. ...	DATE Nov 26, 68	DATE 11/1/68	LOCATION SAN JOSE	

CHAD BY: *W. Swann*  
 10.30.68 R



## APPENDIX B

### PREPARATION OF BASE METAL SAMPLE MATERIAL

#### B.1 STEEL PRODUCTION

The pressure vessel steel normally is melted in an electric furnace and aluminum-treated in the ladle. Each ingot is hot-rolled into one large plate. The plates are air cooled after being rolled, and are then shipped to the fabricator for additional heat treatment and fabrication.

#### B.2 VESSEL FABRICATION HISTORY

Most BWR pressure vessels are constructed of SA-533 Grade B, Class 1 steel plate, 6 to 8 inches thick. The vessel shell plates are furnished to the vessel fabricator in the hot-rolled condition. The plates are austenitized, followed

by liquid quenching, tempering, and furnace cooling. They are cold-formed into half shells. Stub ends of the plates are removed after this operation and are set aside for the surveillance material. The half shells are welded together to form the vessel shell rings. Several rings are welded together to form the vessel. Postweld heat treatments are performed after each circumferential weld is completed.

#### B.3 SPECIMEN PREPARATION

Mechanical test specimens are prepared from the vessel plate in accordance with the GE specification for the pressure vessel surveillance program.

## APPENDIX C

## THREE-DIGIT, TWENTY-SYMBOL MARKING SYSTEM (FAB CODE)

Specimens for a reactor pressure vessel materials surveillance program are being installed in each GE power reactor. Several types of steels and several thousand specimens are to be handled. All the specimens look alike, and a positive means for identification is required. The following items are monitored by the marking system:

1. Reactor
2. Type of Material
  - Interior Base
  - Exterior Base
  - Weld
  - Heat-Affected Zone (HAZ)

3. Location (within limits) on Stock Plate
4. Individual Serial Numbers

These specimens must be handled remotely after irradiation, and the largest possible marking is required. After considering all the factors, a modification of a system developed by the U.S. Steel Corporation Applied Research Laboratory was adopted for surveillance specimen marking. This system (FAB Code) uses three digits and twenty symbols, and can accommodate 8000 specimens. The sequence is illustrated in Table C-1. Note that "look alike" symbols are avoided as much as possible.

**Table C-1**  
**FAB CODE - DECEMBER 1963**

Arabic Number Series	FAB Code Series	Three-Digit FAB Code Series																			
		*11	*21	*31	*41	*51	*61	*71	*A1	*B1	*C1	*D1	*E1	*J1	*K1	*L1	*M1	*P1	*T1	*U1	*Y1
1	1	*11	*21	*31	*41	*51	*61	*71	*A1	*B1	*C1	*D1	*E1	*J1	*K1	*L1	*M1	*P1	*T1	*U1	*Y1
2	2	*12	*22	.	.	.	.	.	*A2	.	*C2	.	.	.	.	.	*M2	.	.	.	*Y2
3	3	*13	*23	*33	.	*53	.	.	*A3	.	.	.	.	.	*J3	.	*P3	.	.	.	*Y3
4	4	*14	*24	.	*44	.	.	*74	*A4	.	.	*D4	.	.	*K4	.	.	.	*T4	.	*Y4
5	5	*15	*25	*35	.	.	.	.	*A5	.	.	.	.	*J5	.	.	.	.	.	*U5	*Y5
6	6	*16	*26	.	.	.	*66	.	*A6	.	.	.	*E6	.	.	.	.	.	.	.	*Y6
7	7	*17	*27	*37	.	.	.	.	*A7	.	.	.	.	.	.	.	.	.	.	.	*Y7
8	A	*1A	*2A	.	*4A	.	.	*7A	*AA	.	.	.	.	.	.	.	*MA	.	.	.	*YA
9	B	*1B	*2B	*3B	.	*5B	.	*7B	*AB	.	*CB	.	.	.	*LB	.	*PB	.	.	.	*YB
10	C	*1C	*2C	.	.	.	.	.	*AC	.	.	.	.	.	*KC	.	.	.	*TC	.	*YC
11	D	*1D	*2D	*3D	.	.	.	.	*AD	*BD	.	.	.	.	*JD	.	.	.	.	*UD	*YD
12	E	*1E	*2E	.	.	.	.	.	*AE	.	.	.	*EE	.	.	.	.	.	.	.	*YE
13	J	*1J	*2J	*3J	*4J	.	.	.	*AJ	.	.	.	.	.	.	.	.	.	.	.	*YJ
14	K	*1K	*2K	.	.	.	.	.	*AK	.	.	.	.	.	.	.	.	.	.	.	*YK
15	L	*1L	*2L	*3L	.	*5L	.	.	*AL	.	.	.	.	.	.	.	.	.	.	.	*YL
16	M	*1M	*2M	.	*4M	.	.	.	*AM	*BM	.	.	.	.	.	.	.	.	.	.	*YM
17	P	*1P	*2P	*3P	.	.	*6P	.	*AP	.	.	.	.	.	.	.	.	.	.	.	*YP
18	T	*1T	*2T	*3T	.	.	.	.	*AT	.	.	*DT	.	.	.	.	.	.	.	.	*YT
19	U	*1U	*2U	*3U	.	.	.	*7U	*AU	.	.	.	.	.	.	.	.	.	.	.	*YU
20	Y	*1Y	*2Y	*3Y	*4Y	*5Y	*6Y	*7Y	*AY	*BY	*CY	*DY	*EY	*JY	*KY	*LY	*MY	*PY	*TY	*UY	*YY
Cumulative Total		20	40	60	80	100	120	140	160	180	200	220	240	260	280	300	320	340	360	380	400

- NOTES: 1. \*denotes first digit of marking code and is furnished in instructions. It will be a FAB Code letter or number such as 2, 4, 7, A, D, J or Y.
2. . denotes number in sequence left out to reduce labor in making table.
3. For ease of marking, it is suggested that a set of stencils be set up in the order shown in column headed "FAB Code Series."

NECO-10115


## APPENDIX D

## DESCRIPTION OF FLUX MONITORS

**D.1 NICKEL WIRE**

Commercially-pure English nickel containing 0.0729 percent cobalt is used.

The nuclear reactions of interest are:

**D.2 IRON WIRE**

Commercially-pure iron thermocouple wire, 24-gage, is used.

The nuclear reaction of interest is:  $\text{Fe}^{54} (n,p) \text{Mn}^{54}$

**D.3 COPPER WIRE**

Very high purity (99.999 percent) copper wire is used.

The nuclear reaction of interest is:  $\text{Cu}^{63} (n,\alpha) \text{Co}^{60}$

**D.4 REFERENCE**

Hogg, C. H., and Weber, L. D., *Fast Neutron Dosimetry at the MTR-ETR Site*, ASTM STP No. 341, 133 (1963).

*General Analysis of Radio Isotopes*, ASTM E181-62 (1968).

*Fast-Neutron Flux By Radioactivation of Iron, Measuring*, ASTM E263-65T.

*Fast-Neutron Flux By Radioactivation of Nickel, Measuring*, ASTM E264-65T.

## APPENDIX E

CAPSULE HANDLING AND GENERAL SUGGESTIONS  
FOR CARRYING OUT THE PROGRAM

## E.1 GENERAL INSTRUCTIONS

## E.1.1 Binary Code

Capsules and baskets in the surveillance program are binary-coded. The use of the binary code is illustrated in GE drawing 129B3578, and in Appendix A of this report.

## E.1.2 FAB Code

The FAB Code is described in Appendix C of this report.

## E.2 CAPSULE REMOVAL FROM REACTOR

Every effort is made to design the capsules and locate them to assure reasonable ease of removal. The respective drawings of capsule and pressure vessel should be reviewed and a removal plan should be made prior to the operation.

## E.3 SHIPPING

If individual capsules are removed from the baskets, they should be placed in a cask liner prior to inserting them in a shipping cask, since it is very difficult to retrieve small objects from the bottom of a cask at the hot laboratory. It may be necessary to get a license to ship byproduct materials prior to shipping the capsules. The receiver may need a license to receive such materials. The receiver should have a set of drawings of all items shipped.

## E.4 CAPSULE OPERATIONS AT HOT LABORATORY

## E.4.1 Gamma Scan

Each capsule should be gamma-scanned to obtain a measure of the neutron exposure variations within each capsule and among the several capsules.

## E.4.2 Impact Specimen Capsule

This capsule has a 1/4-inch-thick stainless steel spacer at the bottom; if possible, the capsule should be parted in this area. The flux monitors are loose on the seam side of the can, and are identified by their length. The specimens should slide out. If they do not and the capsule requires slitting down one side, this should be done on the weld-seam side because the numbered ends of the specimens are opposite to this side.

## E.4.3 Tensile Specimen Capsule

This capsule may be opened at either end by cutting the weld. Some skill may be required to get the specimen out because the fillets at the ends of the gage length tend to wedge the aluminum spacers. When the specimens stick as they are being loaded into the capsules, forcing techniques are not successful because forcing increases the wedging action. Back-and-forth, gentle rapping should break the specimens loose, and then they slide easily out or in. There are no flux monitors in these capsules.

## E.5 EXAMINATION OF SPECIMENS PRIOR TO TESTING

The specimen numbers in each capsule and their orientation are described in the schedule drawing.

E.6 SUGGESTIONS FOR MECHANICAL TESTING (See ASTM Specification E185)<sup>3</sup>

The following data should be obtained by testing the Charpy specimens:

1. Energy Transition curve at temperatures which completely bracket the brittle ductile transition range, and which define the lower and upper shelf energies.
2. Fracture transition curve determined by examination of the fractured surfaces, using ASTM Specification A370 as a guide.
3. Photograph of each pair of fracture surfaces at a minimum 1X magnification.
4. Hardness data on representative specimens near the notch on the notch surface prior to impact test.

There are sufficient specimens to develop a transition curve if care is taken during testing and if curves previously developed are used as a guide. No duplicate tests should be made before the full extent of the curve is determined. The specimen notch location is referenced to the unmarked end. If an end reference stop is used to align the specimens in this machine, the unmarked end of the specimen must be used with it.

The following data should be obtained by testing the tensile specimens:

1. 0.2 percent yield strength.
2. Ultimate tensile strength.

Complete autographic load-elongation curve, preferably obtained with extensometer on specimen gage length.

4. Uniform elongation from curve.
5. Total elongation from curve.
6. Reduction of area from broken specimen.
7. Photograph of each pair of fractured surfaces at a minimum 1X magnification.
8. Photograph of the length of the broken specimen, with a precision ruler adjacent to the gage length to provide a judgment of the type of necking.

Testing parameters should also be reported, such as type and make of machine, loading rate, strain rate, and temperature. If possible, the tensile tests should be made at 550°F. Each tensile specimen should be checked for gage marks prior to testing because some specimens may lack them. Gage marks should be applied to specimens which have none, with a commercial gage marker.

#### E.7 CONTROL SPECIMENS

A group of specimens from each type of material is available to determine the initial condition of the material

prior to temperature cycling or irradiation. These should be tested with the first group of irradiated specimens. The tests should be made on the same machine used for the irradiated specimens.

#### E.8 METALLOGRAPHY

If funds permit, metallographic specimens should be made of representative samples—especially at the longer time intervals.

#### E.9 DOSIMETRY (See Appendix D)

Each impact capsule contains an iron, a nickel, and a copper wire. It is recommended that these wires be analyzed by radiochemical means to obtain a measure of the integrated neutron flux exposure of the specimens. It should not be necessary to analyze all the flux wires of all capsules. Wires from selected capsules can be analyzed, and the remainder can be retained as spares, as required.

**DISTRIBUTION**

<b>Name</b>	<b>M/C</b>	<b>Name</b>	<b>M/C</b>
R. H. Beers . . . . .	377	I. R. Kobsa . . . . .	743
R. J. Benche . . . . .	712	B. F. McClintic (11) . . . . .	384
F. A. Brandt (5) . . . . .	744	E. O'Conner . . . . .	743
D. G. Bridenbaugh . . . . .	132	J. F. O'Mara (5) . . . . .	377
F. J. Cage . . . . .	713	G. R. Schmidt . . . . .	743
L. J. Chockie . . . . .	377	L. A. Steinert . . . . .	712
W. Fiock . . . . .	377		
G. M. Gordon . . . . .	VNC-103	NED Library (5) . . . . .	328
G. R. Hanson . . . . .	743	VNC Library (2) . . . . .	VNC-102
J. P. Higgins (5) . . . . .	744	SVL Library . . . . .	SVL

ATOMIC POWER EQUIPMENT DEPARTMENT  
**GENERAL  ELECTRIC**  
 SAN JOSE, CALIFORNIA

**TECHNICAL INFORMATION SERIES**  
 TITLE PAGE

<b>AUTHOR</b> J. P. Higgins F. A. Brandt	<b>SUBJECT</b> GE BWR Vessels	<b>NO.</b> 69NED37	
		<b>DATE</b> July 1969	
<b>TITLE</b> Mechanical Property Surveillance of General Electric BWR Vessels		<b>GE CLASS</b> I	
		<b>GOVT. CLASS</b> None	
REPRODUCIBLE COPY FILED AT TECHNICAL PUBLICATIONS UNIT, APED, SAN JOSE, CALIFORNIA		<b>NO. PAGES</b> 33	
<b>SUMMARY</b>  <p>The General Electric Company furnishes pressure vessel steel surveillance specimens for each BWR to permit the plant owner to account for radiation induced changes in mechanical properties of the reactor vessel during service. This report presents several methods for determining the magnitude of these property changes. It also describes the specimens, specimen inventory, capsule design, associated equipment, material selection, and instructions for handling the specimens if they are tested.</p>			

By cutting out this rectangle and folding on the center line, the above information can be fitted into a standard card file.

For list of contents - drawings, photos, etc. and for distribution see next page (FN-610-2)

JOB NUMBER 6017

INFORMATION PREPARED FOR APED

TESTS MADE BY J. P. Higgins, F. A. Brandt

COUNTERSIGNED J. F. Cage SECTION Design Engineering

BUILDING AND ROOM NO. K-215 LOCATION San Jose, Calif.