

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

Central files

JUL 18 1975

Commonwealth Edison Company
ATTN: Mr. Byron Lee, Jr.
Vice President
P. O. Box 767
Chicago, Illinois 60690

Docket No. 50-10
Docket No. 50-237
Docket No. 50-249

Gentlemen:

This letter is in response to Mr. Abel's letter to our office dated July 2, 1975, relating to our inspection of the Dresden Nuclear Station on May 12, 1975.

With respect to your comments on Section 4, Paragraph e.(1), the inspection of these penetrations was performed on a sampling basis, and therefore the words "a large number" are considered appropriate.

With respect to your comments on Section 4, Paragraph e.(2), we clarify this paragraph to state: paper, rags, and wood were found in cable trays at various locations in the auxiliary electric room.

We expect that you have completed your inspection of electrical penetrations and that you have implemented corrective actions if required.

Should you have any additional questions concerning these matters, we will be glad to discuss them with you.

Sincerely yours,

Gaston Fiorelli, Chief
Reactor Operations Branch

bcc w/ltr dtd 7/2/75:
PDR
Local PDR
NSIC
TIC
Anthony Roisman, Esq.



u



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

July 2, 1975

Mr. Gaston Fiorelli, Chief
Office of Inspection and
Enforcement - Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Dresden Station Units 1, 2 and 3
NRC Inspection Reports 50-10/ 75-09,
50-237/75-14 and 50-249/75-12

Dear Mr. Fiorelli:

In reference to the subject reports, we offer the following clarifications of a few points.

In Section 4, Visual Examination, Paragraph e(1), "a large number" could be more definitively stated as "4 or 5". In the same paragraph, Item (2), "at various locations in the plant" could be more clearly stated as "one location in the auxiliary electrical equipment room". We believe these minor corrections may eliminate some possible misinterpretation of these items.

We have also reviewed the subject inspection reports and have identified no proprietary information.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'J. S. Abel', written over a horizontal line.

J. S. Abel
Nuclear Licensing Administrator
Boiling Water Reactors

JUL 7 1975