



Telegram

1975 APR 16 PH 4:08  
00115

VEB203(1607)(2-034913E106)PD 04/16/75 1605

ICS IPMBNGZ CSP

AC \_\_\_\_\_ BOOK NO. \_\_\_\_\_ OPR. NO. \_\_\_\_\_  
TELEPHONE NBR. 312-858-2666  
TELEPHONED TO P.H.J. [Signature]  
DATE BLD. 4/17 TIME 10:50  
ATTEMPTS TO DELIVER: \_\_\_\_\_

8159424449 IDBN MORRIS IL 107 04-16 0405P EST

PMS JAMES G KEPPLER, REGIONAL DIRECTOR DIRECTORATE  
OPERATIONS REGION 3, WUX  
U.S. NUCLEAR REGULATORY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN IL 60137

50-237

SUBJECT: DPR-19, DRESDEN NUCLEAR POWER STATION, UNIT 2.

THIS WILL CONFIRM A CONVERSATION WITH P JOHNSON OF YOUR OFFICE AT  
1500 HOURS THIS DATE CONCERNING IODINE REMOVAL EFFICIENCY OF THE  
2/3A STAND-BY GAS TREATMENT SYSTEM CHARCOAL FILTERS TO BE 98.2  
PERCENT WHICH IS LESS THAN THE 99.0 PERCENT EFFICIENCY REQUIRED BY  
THE TECHNICAL SPECIFICATIONS. BOTH UNITS 2 AND 3 WERE IN COLD SHUT  
DOWN AND SECONDARY CONTAINMENT WAS NOT REQUIRED AT THE TIME THE "A"  
TRAIN WAS FOUND INOPERABLE. THE "B" SYSTEM TRAIN WAS TESTED

SF-1201 (R5-69) SATISFACTORILY AT THIS TIME. THIS NOTIFICATION WILL BE FOLLOWED BY A

10 DAY REPORT

B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON COMPANY RR #1 MORRIS ILLINOIS 60450  
NNNN

AC \_\_\_\_\_ BOOK NO. \_\_\_\_\_ OPR. NO. \_\_\_\_\_  
TELEPHONE NBR. \_\_\_\_\_  
TELEPHONED TO \_\_\_\_\_ BY \_\_\_\_\_  
DATE BLD. \_\_\_\_\_ TIME \_\_\_\_\_  
ATTEMPTS TO DELIVER: \_\_\_\_\_

APR 21 1975

SF-1201 (R5-69)



Telegram

VEA171(1617)(2-036407E107)PD 04/17/75 1617

1975 APR 17 PM 4: 18

ICS IPMBNGZ CSP

8159424449 TDBN MORRIS IL 91 04-17 0417P EST

PMS JAMES G KEPPLER, REGIONAL DIRECTOR, DIRECTORATE OF REGULATORY OPERATIONS REGION III, WUX

U.S. NUCLEAR REGULATORY COMMISSION 799 ROOSEVELT RD  
GLEN ELLYN IL 60137

SUBJECT: DPR-25, DRESDEN NUCLEAR POWER STATION, UNIT 3.

3-0-249

00066

THIS WILL CONFIRM A CONVERSATION WITH MR. P. JOHNSON OF YOUR OFFICE AT 1445 HOURS THIS DATE CONCERNING MAIN STEAM-LINE "D" DRYWELL PENETRATION X105D. FAILURE TO PASS CONTAINMENT LOCAL LEAK RATE TESTS. FAILURE APPEARS TO BE DUE TO BROKEN TESTLINE WHICH PENETRATES BELLOWS-TYPE PENETRATION BETWEEN PRIMARY AND SECONDARY BELLOWS. PRIMARY CONTAINMENT INTEGRITY WAS NOT REQUIRED AT TIME OF DISCOVERY. FURTHER INFORMATION WILL FOLLOW IN A TEN DAY REPORT.

SF-1201 (R5-69)

B B STEPHENSON SUPT. DRESDEN NUCLEAR POWER STATION COMMONWEALTH EDISON CO RURAL ROUTE 1 MORRIS IL 60450  
NNNN

US Atomic Energy

AC \_\_\_\_\_ BOOK NO. \_\_\_\_\_ OPR. NO. \_\_\_\_\_  
TELEPHONE NBR. 312 858 2660  
TELEPHONED TO BY 97  
DATE DLD. 4-18 TIME 9:46A  
ATTEMPTS TO DELIVER: \_\_\_\_\_

APR 21 1975

SF-1201 (R5-69)