




Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690

September 19, 1975

Regulatory

File Copy



Mr. Dennis L. Ziemann, Chief
 Operating Reactors - Branch 2
 Division of Reactor Licensing
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

**Subject: Dresden Station Units 2 and 3
 Quad-Cities Station Units 1 and 2
 ECCS Valve Failure Analysis
 NRC Docket Nos. 50-237, 50-249,
 50-254, and 50-265**


Dear Mr. Ziemann:

The ECCS single valve failure analysis Table 1, submitted June 23, 1975, has been revised to provide a more comprehensive listing and to more accurately describe the valves.

Please replace Table 1 with those enclosed in this letter. This revised table has received Onsite and Offsite Review.

Enclosed are one (1) signed original and 59 copies for your information.

Very truly yours,



[Signature]
 G. A. Abrell
 Nuclear Licensing Administrator
 Boiling Water Reactors

Enclosure

TABLE 1
DRESDEN 2 & 3

ECCS SINGLE VALVE FAILURE ANALYSIS

<u>SYSTEM</u>	<u>TOTAL NO. OF VALVES AT STA.</u>	<u>VALVES*</u>	<u>POSITION FOR NORMAL PLANT OPERATION</u>		<u>CONSEQUENCES OF VALVE FAILURE ASSUMED TOGETHER WITH DESIGN BASIS LOCA</u>
			<u>CLOSED</u>	<u>OPEN</u>	
Core Spray	(4)	Suction e.g. M27 (MO-2-1402-3A)		X	Negate use of one core spray loop
	(8)	Injection e.g. M27 (MO-2-1402-24B & 25B)	X	X	Negate use of one core spray loop
	(4)	Test Return e.g. M27 (MO-2-1402-4B)	X		Negate use of one core spray loop
	(4)	Minimum Flow e.g. M27 (MO-2-1402-38A & 38B)		X	Partial flow loss in one loop
High Pressure Coolant Injection	(2)	Condensate Suction e.g. M51 (MO-2-2301-6)		X	Utilize Suppression Pool Water
	(4)	Suppression Pool Suction Valve e.g. M51 (MO-2-2301-35 & 36)	X		Utilize Condensate Storage Tank Water
	(4)	Injection e.g. M51 (MO-2-2301-8&9)	X	X	Negates HPCI
	(6)	Turbine Inlet e.g. M51 (MO-2-2301-3,4, & 5)	X	X	Negates HPCI
	(4)	Test Return e.g. M51 (MO-2-2301-10&15)	X		No consequences (negates HPCI if both valves fail open)
	(2)	Minimum Flow e.g. M51 (MO-2-2301-14)	X		Partial loss of flow

* Numerical designation following valves titles refer to P&ID sheets and an example of a particular valve.

TABLE 1
DRESDEN 2 & 3

ECCS SINGLE VALVE FAILURE ANALYSIS

SYSTEM	TOTAL NO. OF VALVES AT. STA.	VALVES*	POSITION FOR NORMAL PLANT OPERATION		CONSEQUENCES OF VALVE FAILURE ASSUMED TOGETHER WITH DESIGN BASIS LOCA
			CLOSED	OPEN	
Low Pressure Coolant Injection	(8)	Injection e.g. M29 (MO-2-1501-21B & 22B)	X	X	Negate use of LPCI
	(4)	Minimum Flow e.g. M29 (MO-2-1501-13A & 13B)	X		Partial flow loss in one loop due to flow to Suppression Pool
	(8)	Test Return e.g. M29 (MO-2-1501-38B & 20B)	X		No consequences (negates loop if both valves fail open)
	(4)	Cross Tie e.g. M29 (MO-2-1501-32B & 32A)		X	Negate one LPCI loop (two pumps per loop)
	(4)	HX Bypass e.g. M29 (MO-2-1501-11B & 11A)		X	Reduce flow due to HX pressure drop
	(8)	Pump Suction e.g. M29 (MO-2-1501-5A, B, C, D)		X	Negate one out of four pumps
	Automatic Depressurization System (Design is changing; safety/relief valves will be installed)	(10)	Relief Valve e.g. M12 (MO-2-203-3A)	X	

* Numerical designation following valves titles refer to P&ID sheets and an example of a particular valve.

TABLE 1

QUAD-CITIES 1 & 2ECCS SINGLE VALVE FAILURE ANALYSIS

SYSTEM	TOTAL NO. OF VALVES AT STA.	VALVES *	POSITION FOR NORMAL PLANT OPERATION		CONSEQUENCES OF VALVE FAILURE ASSUMED TOGETHER WITH DESIGN BASIS LOCA
			CLOSED	OPEN	
Core Spray	(4)	Suction e.g. M36 (MO-1-1402-3B)		X	Negate use of one core spray
	(8)	Injection e.g. M36 (MO-1-1402-24B & 25B)	X	X	Negate use of one core spray
	(4)	Test Return e.g. M36 (MO-1-1402-4B)	X		Negate use of one core spray loop
	(4)	Minimum Flow e.g. M36 (MO-1-1402-38A & 38B)		X	Partial flow loss in one loop
High Pressure Coolant In- jection	(2)	Condensate Suction e.g. M46 (MO-1-2301-6)		X	Utilize Suppression Pool Water
	(4)	Suppression Pool Suction Valve e.g. M46 (MO-1-2301-35 & 36)	X		Utilize Condensate Storage Tank Water
	(4)	Injection e.g. M46 (MO-1-2301-8&9)	X	X	Negates HPCI
	(6)	Turbine Inlet e.g. M46 (MO-1-2301-3,4,5)	X	X	Negates HPCI
	(4)	Test Return e.g. M46 (MO-1-2301-10&15)	X		No consequences (negates HPCI if both valves fail open)
	(2)	Minimum Flow e.g. M46 (MO-1-2301-14)	X		Partial loss of flow

* Numerical designation following valves titles refer to P&ID sheets and an example of a particular valve.

TABLE 1
QUAD-CITIES 1 & 2

ECCS SINGLE VALVE FAILURE ANALYSIS

SYSTEM	TOTAL NO. OF VALVES AT. STA.	VALVES*	POSITION FOR NORMAL PLANT OPERATION		CONSEQUENCES OF VALVE FAILURE ASSUMED TOGETHER WITH DESIGN BASIS LOCA
			CLOSED	OPEN	
Low Pressure Coolant Injection (Mode of the RHRS)	(8)	Injection e.g. M39 (MO-1-1001-28B & 29B)	X	X	Negate use of LPCI
	(4)	Minimum Flow e.g. M39 (MO-1-1001-18A)	X		Partial flow loss in one loop due to flow to Suppression Pool
	(8)	Test Return e.g. M39 (MO-1-1001-34A & 36A)	X		No consequence (negates loop if both valves fail open)
	(4)	Cross Tie e.g. M39 (MO-1-1001-19B)		X	Negate one LPCI loop (two pumps per loop)
	(4)	HX Bypass e.g. M39 (MO-1-1001-16B)		X	Reduce flow due to HX pressure drop
	(8)	Pump Suction e.g. M37 (MO-1-1001-7A,B C, D)		X	Negate one out of four pumps
	Automatic Depressuriza- tion System (Design is changing; safety/ relief valves will be installed)	(10)	Relief Valve e.g. M13 (1-203-3A)	X	

* Numerical designation following valves titles refer to P&ID sheets and an example of a particular valve.