

Docket No. 50-10, 50-237,
50-249 and 50-254

APR 24 1975

~~copy of encl.~~
copy of encl.
filed w/ Docket
50-10

DISTRIBUTION

NRC PDR
Local PDR
Docket
KRGoller
ORB #2 Reading
TJCarter
OELD
OI&E (3)
DLZiemann
PWO' Connor
RDSilver
RWReid
RMDiggs
JRBuchanan

TBAbernathy
SVarga
ACRS (14)

Commonwealth Edison Company
ATTN: Mr. J. S. Abel
Nuclear Licensing Administrator -
Boiling Water Reactors
P. O. Box 767
Chicago, Illinois 60690

Gentlemen:

Our review of recent submittals regarding the reevaluation of emergency core cooling system (ECCS) performance in accordance with 10 CFR 50.46 indicates that certain additional information was required in order for us to complete our evaluation. This letter is to inform you of one part of the evaluations that have been submitted that has required additional information.

In performing the evaluation of single failures of ECCS equipment required by Appendix K to 10 CFR 50, Section I.D.1., the effects of a single failure or operator error that causes any manually-controlled, electrically-operated valve to move to a position that could adversely affect the ECCS must be considered. Therefore, please review your submittals regarding ECCS; and if this consideration has not been specifically reported in the past, your upcoming submittal must address this consideration. Include any proposed plant modifications and changes to the Technical Specifications that might be required to protect against any loss of safety function caused by this type of failure. A copy of Branch Technical Position EICSB 18 from the U.S. Nuclear Regulatory Commission's Standard Review Plan is attached to provide you with guidance.

This request for generic information was approved by GAO under a blanket clearance number E-180225 (R0072); this clearance expires July 31, 1977.

Sincerely,

Original signed by
Dennis L. Ziemann

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Reactor Licensing

Enclosure:
Branch Technical Position EICSB 18

cc w/enclosure: See next page

ECCS
(2)

DB

OFFICE >	RL:ORB #2	RL:ORB #2	RL:ORB #2	RL:ORB #2	
SURNAME >	PWO' Connor:tc	RDSilver:tc	RWReid:tc	DLZiemann	
DATE >	4/23/75	4/23/75	4/24/75	4/24/75	

APR 24 1975

cc w/enclosures:

Mr. Charles Whitmore
President and Chairman
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

John W. Rowe, Esquire
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza
Chicago, Illinois 60670

Anthony Z. Roisman, Esquire
Berlin, Roisman and Kessler
1712 N Street, N. W.
Washington, D. C. 20036

Moline Public Library
504 - 17th Street
Moline, Illinois 61265

Morris Public Library
604 Liberty Street
Morris, Illinois 60451