

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | | 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | F I L I S I L I S I T I | 2 | 0 1 0 1 - 1 0 1 0 1 0 1 0 1 - 1 0 1 0 | 3 | 4 1 1 1 1 1 1 1 | 4 | | | 5

CON'T
01 | REPORT SOURCE | L | 6 | 0 1 5 1 0 1 0 1 0 1 3 1 3 1 5 | 7 | 0 1 9 1 3 1 0 1 7 1 8 | 8 | 1 1 0 1 1 1 3 1 7 1 8 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

012 | During power operation, the Digital Data Processing System (DDPS) mal-
013 | functioned. This resulted in loss of CEA backup position indication and
014 | the incore flux detector system used to monitor flux distribution. Action
015 | required by Specifications 3.1.3.3 and 4.2.1.3 was initiated and power
016 | was reduced. The DDPS was repaired and returned to service in 70 minutes.
017 | This is the fourth occurrence involving loss of the DDPS due to the cause
018 | described below. (See 335-78-2, -78-9 and -78-26)

019 | SYSTEM CODE | I I E | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | G | 13 | COMPONENT CODE | I I N I S I T R I U | 14 | COMP. SUBCODE | Y | 15 | VALVE SUBCODE | Z | 16 |
17 | LER/RO REPORT NUMBER | 7 1 8 | 21 | SEQUENTIAL REPORT NO. | 0 3 1 9 | 24 | OCCURRENCE CODE | 0 1 3 | 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32 |
ACTION TAKEN | D | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | B | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 1 0 1 0 1 2 | 27 | ATTACHMENT SUBMITTED | N | 23 | NPRO-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | F I 1 2 1 0 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

110 | The cause of the DDPS malfunction was a momentary memory failure. The
111 | DDPS was repaired and placed back into service in 70 minutes. Such
112 | momentary failures are not uncommon in small computer systems.

114 | FACILITY STATUS | E | 23 | % POWER | 1 1 0 1 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Observation | 32

115 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

117 | PERSONNEL EXPOSURES NUMBER | 0 1 0 1 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

118 | PERSONNEL INJURIES NUMBER | 0 1 0 1 0 | 40 | DESCRIPTION | NA | 41

119 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43

120 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45

NAME OF PREPARER M. A. Schoppman PHONE: 305/552-3802

7810230169

