

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:7904060130 DOC. DATE: 79/03/30 NOTARIZED: NO DOCKET #
 FACIL:50-335 ST. LUCIE PLANT, UNIT 1, FLORIDA POWER & LIGHT CO. 05000335
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R. E. FLORIDA POWER & LIGHT CO.
 RECIP. NAME RECIPIENT AFFILIATION
 STELLO, V. DIVISION OF OPERATING REACTORS

SUBJECT: NOTIFICATION THAT STEAM GENERATORS WILL NOT BE CHEMICALLY
 CLEANED DURING UPCOMING CYCLE 3 FUEL OUTAGE. TEST RESULTS TO
 DATE DO NOT JUSTIFY EXPENSE OF CHEMICAL CLEANING.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 3 ENCL 0 SIZE: 11
 TITLE: GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LIC

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
ACTION:	05 BC ORB 4	7	7			
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	12 I&E	2	2	14 TA/EDO	1	1
	15 CORE PERF BR	1	1	16 AD SYS/PROJ	1	1
	17 ENGR BR	1	1	18 REAC SFTY BR	1	1
	19 PLANT SYS BR	1	1	20 EEB	1	1
	21 EFLT TRT SYS	1	1	22 BRINKMAN	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	23 ACRS	16	16			

APR 9 1979


MA 4

60

TOTAL NUMBER OF COPIES REQUIRED: LTR 38 ENCL 30



10. P 452



March 30, 1979
L-79-76

Office of Nuclear Reactor Regulation
Attention: Mr. Victor Stello, Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Stello:

Re: St. Lucie Unit 1
Docket No. 50-335
Cleaning of Steam Generators

The purpose of this letter is to inform you that, based on the results of developmental testing performed to date, Florida Power & Light Company does not plan to chemically clean the St. Lucie Unit 1 steam generators during the upcoming Cycle 3 refueling outage. Further testing is required to support the feasibility and justify the expense of chemical cleaning. We will keep you informed of our position on chemical cleaning at St. Lucie, however, our plans for continuing the developmental work are undetermined at this time.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/cph

cc: Mr. James P. O'Reilly, Region II
Harold F. Reis, Esquire

Handwritten: Aool
5/3/79

7904060130

