



May 25, 1979
L-79-141

19 MAY 29 A 9:01

USNRC REGION II
ATLANTA, GEORGIA

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-335
IE Bulletin 79-06, 79-06B

In response #4 of our letter L-79-79 dated April 24, 1979 we stated that prior to mode 1 operation, instructions will be issued to further ensure that an operator is designated to promptly initiate and verify auxiliary feedwater flow to the steam generator(s), if needed, during transient and accident situations. We would like to clarify our response to state that this action would be the primary duty of the designated operator during such transients and accidents, and at such time he would have no concurrent duties.

Very truly yours,

Robert E. Uhrig
Vice President

REU:TCG:cf

cc: Harold Reis, Esquire

7907100094

AO 2

790194 60

OFFICIAL COPY