

USNRC REGION II
ATLANTA, GEORGIA

79 JUL 3 A 9:14

P.O. BOX 529100, MIAMI, FL 33152



FLORIDA POWER & LIGHT COMPANY

June 28, 1979
L-79-174

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-335
IE Bulletin 78-04

As a result of our work on IE Bulletin 79-01, we have determined that NAMCO D2400X switches are used at St. Lucie Unit 1, however, they are not installed on safety related equipment inside containment for any purpose other than valve position indication.

This information is submitted to update our March 29, 1978 response to IE Bulletin 78-04.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/cph

cc: Harold F. Reis, Esquire

7908270302

A0 2

60

790260
OFFICIAL COPY
PEOPLE SERVING PEOPLE

