

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7910020377 DUC. DATE: 79/09/25 NOTARIZED: NO BUCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co 05000250
~~50-251 Univ. of New Mexico Research Reactor 05000252~~
 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 AUTH. NAME AUTHUR AFFILIATION
 HRRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Office of Nuclear Reactor Regulation

SUBJECT: Responds to 790821 & 29 ltrs re request to commit to five-man fire brigade. Three-man brigade considered sufficient. Proposed regulation will be commented on after publication in FR. Addl comments on encl to ltrs will follow.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 3 ENCL 0 SIZE: 1
 TITLE: Fire Protection Information (After Issuance of Op. Lic.)

NOTES: -----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	05 BC ORB #1, ORB #4	1	1			
INTERNAL:	01 REG FILE	1	1	02 WRC PDR	1	1
	09 I&C	2	2	11 TA/EDU	1	1
	12 AUXIL SYS BR	2	2	14 PLANT SYS BR	5	5
	19 WAMBACH	1	1	20 MURAKAKA, R	1	1
	06LD	1	0			
EXTERNAL:	03 LPDR	1	1	04 MSIC	1	1
	22 ACKS	10	10			

OCT 3 1979

MA
4

TOTAL NUMBER OF COPIES REQUIRED: LTR 38 ENCL 0 60



September 25, 1979
L-79-270

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut
Acting Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point and St. Lucie Plants
Docket Nos. 50-250, 50-251, and 50-335
Fire Brigade Size

We have reviewed your letters of August 21 and August 28, 1979 for Turkey Point Units 3 & 4 and St. Lucie Unit 1, respectively. These letters informed us that the NRC staff was preparing a proposed change to 10 CFR 50 to incorporate a minimum fire brigade shift size into the Commission's regulations, and requested that we commit to a five man fire brigade.

The Turkey Point and St. Lucie Technical Specifications presently require a three man fire brigade. As noted in our earlier correspondence on this subject, we consider a three man fire brigade adequate to respond to potential fires at our Turkey Point and St. Lucie nuclear plants.

At this time, rather than propose revised Technical Specifications for our plants, we would prefer to review the proposed NRC regulation after it is published in the Federal Register, and then submit comments for further consideration by the Commission. We have also reviewed the enclosures to your letters, and we are preparing additional comments to be forwarded under separate cover letter.

Yours truly,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU:GDW:cf

cc: Mr. J. P. O'Reilly, Region II
Robert Lowenstein, Esquire

Handwritten: A006
3/10

7910020377