



January 11, 1980
L-80-15

Central File
50-335

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-335
IE Bulletin 79-28

The subject Bulletin has been reviewed, and we have determined that no NAMCO Model EA 180 Limit Switches are in stock or installed in safety related systems at St. Lucie Unit 1.

We plan to install environmentally qualified EA 180 switches to satisfy a commitment made in response to IE Bulletin 79-01, however, these switches have not been received to date. According to quality assurance surveillance documentation, the switches that will be supplied to St. Lucie Unit 1 will be free of the condition described in the Bulletin.

Very truly yours,

for *Robert E. Uhrig*
Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/MAS/cph

cc: Harold Reis, Esquire

AOE
8028
BD
OFFICIAL COPY

8002040.147