

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-335FLORIDA POWER AND LIGHT COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE


The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 34 to Facility Operating License No. DPR-67 issued to Florida Power and Light Company (the licensee), which revised Technical Specifications (TS) for operation of St. Lucie Plant, Unit No. 1 (the facility), located in St. Lucie County, Florida. The amendment is effective as of its date of issuance.

This amendment deletes the fuel enrichment limit from TS 5.3.1 (Reactor Core/Fuel Assemblies) and adds a fuel enrichment limit to TS 5.6.1 (Fuel Storage/Criticality). This places the enrichment limit in the appropriate part of the TS.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.


5002110 206




For further details with respect to this action, see (1) the application for amendment dated October 4, 1979, as supplemented December 12, 1979, (2) Amendment No. 34 to License No. DPR-67, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Indian River Junior College Library, 3209 Virginia Avenue, Ft. Pierce, Florida. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 23rd day of January, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 23, 1980

Docket No. 50-335

Dr. Robert E. Uhrig
Vice President
Florida Power & Light Company
Advanced Systems & Technology
P. O. Box 529100
Miami, Florida 33152

Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. 34 to Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit No. 1. The amendment consists of a change to the Technical Specifications (TS) in response to your application dated October 4, 1979, as supplemented by letter dated December 12, 1979. We have revised your proposed change as discussed with and agreed to by your staff.

This amendment deletes the fuel enrichment limit from TS 5.3.1 and adds a fuel enrichment limit to TS 5.6.1.

As discussed with your staff, our authorization of this proposed TS does not indicate any decision by the NRC with respect to whether the next refueling (Cycle 4) or subsequent refuelings involve any unreviewed safety questions. A licensee must make this determination with respect to 10 CFR 50.59. We note that your proposed fuel management scheme in your December 12, 1979 submittal may require augmented surveillance. This matter will be discussed with your staff.

Copies of the Safety Evaluation and Notice of Issuance are also enclosed.

Sincerely,

A handwritten signature in cursive script that reads "Robert W. Reid".


Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

Enclosures:

1. Amendment No. 34
2. Safety Evaluation
3. Notice

cc w/enclosures:

See next page



Omaha Public Power District

cc w/enclosure(s):

Margaret R. A. Paradis
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, NW.
Washington, D. C. 20036

Mr. Emmett Rogert
Chairman, Washington County
Board of Supervisors
Blair, Nebraska 68023


Omaha Public Power District
ATTN: Mr. William Dermeyer
Plant Manager
Fort Calhoun Plant
1623 Harney Street
Omaha, Nebraska 68102

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Region VII
ATTN: EIS COORDINATOR
1735 Baltimore Street
Kansas City, Missouri 64108

Mr. Frank Gibson
W. Dale Clark Library
215 South 15th Street
Omaha, Nebraska 68102

cc w/enclosures & incoming dtd:
10/4 & 12/12/79
Director, Nebraska Department of
Environmental Control
Post Office Box 94877, State House Station
Lincoln, Nebraska 68509





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER & LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 34
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power & Light Company (the licensee) dated October 4, 1979, as supplemented December 12, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-67 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 34, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION




Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 23, 1980

FIGURE 5.1-2

LOW POPULATION ZONE



DESIGN FEATURES

5.2.1.2 SHIELD BUILDING

- a. Minimum annular space = 4 feet.
- b. Annulus nominal volume = 543,000 cubic feet.
- c. Nominal outside height (measured from top of foundation base to the top of the dome) = 230.5 feet.
- d. Nominal inside diameter = 148 feet.
- e. Cylinder wall minimum thickness = 3 feet.
- f. Dome minimum thickness = 2.5 feet.
- g. Dome inside radius = 112 feet.

DESIGN PRESSURE AND TEMPERATURE

5.2.2 The containment vessel is designed and shall be maintained for a maximum internal pressure of 44 psig and a temperature of 264°F.

PENETRATIONS

5.2.3 Penetrations through the containment structure are designed and shall be maintained in accordance with the original design provisions contained in Sections 3.8.2.1.10 and 6.2.4 of the FSAR with allowance for normal degradation pursuant to the applicable Surveillance Requirements.

5.3 REACTOR CORE

FUEL ASSEMBLIES

5.3.1 The reactor core shall contain 217 fuel assemblies with each fuel assembly containing a maximum of 176 fuel rods clad with Zircoloy-4. Each fuel rod shall have a nominal active fuel length of 136.7 inches and contain a maximum total weight of 2250 grams uranium. The initial core loading shall have a maximum enrichment of 2.83 weight percent U-235. Reload fuel shall be similar in physical design to the initial core loading.

DESIGN FEATURES

CONTROL ELEMENT ASSEMBLIES

5.3.2 The reactor core shall contain 73 full length and no part length control element assemblies. The control element assemblies shall be designed and maintained in accordance with the original design provisions contained in Section 4.2.3.2 of the FSAR with allowance for normal degradation pursuant to the applicable Surveillance Requirements.

5.4 REACTOR COOLANT SYSTEM

DESIGN PRESSURE AND TEMPERATURE

5.4.1 The reactor coolant system is designed and shall be maintained:

- a. In accordance with the code requirements specified in Section 5.2 of the FSAR with allowance for normal degradation pursuant to the applicable Surveillance Requirements,
- b. For a pressure of 2485 psig, and
- c. For a temperature of 650°F, except for the pressurizer which is 700°F.

VOLUME

5.4.2 The total water and steam volume of the reactor coolant system is 11,100 \pm 180 cubic feet at a nominal T_{avg} of 567°F.

5.5 EMERGENCY CORE COOLING SYSTEMS

5.5.1 The emergency core cooling systems are designed and shall be maintained in accordance with the original design provisions contained in Section 6.3 of the FSAR with allowance for normal degradation pursuant to the applicable Surveillance Requirements.

5.6 FUEL STORAGE

CRITICALITY

5.6.1 The new fuel storage racks are designed and shall be maintained with a center-to-center distance of not less than 21 inches between fuel assemblies placed in the storage racks. The spent fuel storage racks are designed and shall be maintained with a center-to-center distance of not

DESIGN FEATURES

CRITICALITY (Continued)

less than 12.53 inches between fuel assemblies placed in the storage racks. These spacings ensure a K_{eff} equivalent to ≤ 0.95 with the storage pool filled with unborated water. The K_{eff} of ≤ 0.95 includes the conservative assumptions as described in Section 9.1 of the FSAR. In addition, fuel in the storage pool shall have a U-235 loading of ≤ 41.45 grams of U-235 per axial centimeter of fuel assembly (\leq an enrichment of 3.7 weight percent U-235).

DRAINAGE

5.6.2 The fuel pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 56 feet.

CAPACITY

5.6.3 The spent fuel pool is designed and shall be maintained with a storage capacity limited to no more than 728 fuel assemblies.

5.7 SEISMIC CLASSIFICATION

5.7.1 Those structures, systems and components identified as seismic Class I in Section 3.2.1 of the FSAR shall be designed and maintained to the original design provisions contained in Section 3.7 of the FSAR with allowance for normal degradation pursuant to the applicable Surveillance Requirements.

5.8 METEOROLOGICAL TOWER LOCATION

5.8.1 The meteorological tower location shall be as shown on Figure 5.1-1.

5.9 COMPONENT CYCLE OR TRANSIENT LIMITS

5.9.1 The components identified in Table 5.9-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.9-1.