

RESRAD GROUNDWATER EXPOSURE FACTORS FOR INITIAL SUITE RADIONUCLIDES (mrem/y per pCi/L)
 Screening Values for Eliminating Low Dose Radionuclides and Determining Radionuclide Mixture for Final Compliance Assessments

Radionuclide	MAX DOSE (mrem/y) (mrem/y)	GW Concentration (t=0, pCi/L)	GW Exposure Factor mrem/yr per pCi/L
Ag-108m	2.498E-01	3.676E+01	6.80E-03
Am-241	1.123E+01	5.643E+00	1.99E+00
Am-243	1.121E+01	5.643E+00	1.99E+00
C-14	2.706E+00	7.120E+02	3.80E-03
Cm-243	1.526E+00	1.122E+00	1.36E+00
Cm-244	1.221E+00	1.122E+00	1.09E+00
Co-60	1.122E-01	4.480E+00	2.50E-02
Cs-134	1.935E+00	2.212E+01	8.75E-02
Cs-137	1.536E+00	2.212E+01	6.94E-02
Eu-152	3.798E-02	1.050E+01	3.62E-03
Eu-154	5.517E-02	1.050E+01	5.25E-03
Eu-155	8.562E-03	1.050E+01	8.15E-04
Fe-55	1.480E-04	3.500E-01	4.23E-04
H-3	2.169E-01	4.891E+03	4.43E-05
Nb-94	8.656E-02	2.212E+01	3.91E-03
Ni-59	5.746E-03	1.608E+01	3.57E-04
Ni-63	1.573E-02	1.608E+01	9.78E-04
Np-237	2.026E+03	8.302E+02	2.44E+00
Pm-147	5.569E-03	1.050E+01	5.30E-04
Pu-238	1.003E+01	5.740E+00	1.75E+00
Pu-239	1.114E+01	5.741E+00	1.94E+00
Pu-240	1.114E+01	5.741E+00	1.94E+00
Pu-241	3.571E-01	5.740E+00	6.22E-02
Sb-125	1.894E+00	5.812E+01	3.26E-02
Sr-90	4.362E+01	3.993E+02	1.09E-01
Tc-99	5.142E+00	4.891E+03	1.05E-03

BASEMENT FILL MODEL GROUNDWATER EXPOSURE FACTORS (mrem/y per pCi/L)

Radionuclide	Maximum Dose (mrem/y)			GW Concentration (pCi/L)	GW Exposure Factor (mrem/y per pCi/L)
	Drinking Water	Plant/Meat/Milk	Total		
Co-60	5.40E-02	5.82E-02	1.12E-01	4.48E+00	2.50E-02
Cs-134	6.58E-01	1.28E+00	1.94E+00	2.21E+01	8.75E-02
Cs-137	5.23E-01	1.01E+00	1.54E+00	2.21E+01	6.94E-02
Eu-152	3.17E-02	6.30E-03	3.80E-02	1.05E+01	3.62E-03
Eu-154	4.61E-02	9.14E-03	5.52E-02	1.05E+01	5.26E-03
H-3	1.38E-01	7.88E-02	2.17E-01	4.89E+03	4.43E-05
Ni-63	4.42E-03	1.13E-02	1.57E-02	1.61E+01	9.78E-04
Sr-90	2.87E+01	1.49E+01	4.36E+01	3.99E+02	1.09E-01

CALCULATION OF GROUNDWATER AND FILL CONCENTRATION FACTORS FROM DUST-MS RESULTS

Reference:

ZionSolutions TSD 14-009, Revision 1 Brookhaven National Laboratory (BNL) Report "Evaluation of Maximum Radionuclide Groundwater Concentrations for Basement Fill Model"

DUST-MS Assumed Basement Inventory:

	DUST-MS Inventory (pCi)
Auxiliary	6503
Containment	2759
Turbine	14679
Spent Fuel Pool/Transfer Canals	780
Crib House/Forebay	6940
Waste Water Treatment Facility	1124

Calculations:

Input to Calculation

Conversion Factor 1.00E-09 mCi/pCi

Auxiliary Basement

	DUST-MS Results		GW Conc Factor	Fill Conc Factor	
	pCi/L	pCi/g	pCi/L per mCi	pCi/g per mCi	
Co-60	2.60E-08	5.80E-09	4.00E-03	8.92E-04	6.76E-07
Cs-134	6.89E-07	3.10E-08	1.06E-01	4.77E-03	
Cs-137	2.47E-06	1.11E-07	3.80E-01	1.71E-02	
Eu-152	1.07E-07	1.03E-08	1.65E-02	1.58E-03	
Eu-154	8.38E-08	7.96E-09	1.29E-02	1.22E-03	
H-3	9.10E-04	0.00E+00	1.40E+02	0.00E+00	
Ni-63	1.90E-06	1.18E-07	2.92E-01	1.81E-02	
Sr-90	1.96E-05	4.51E-08	3.01E+00	6.94E-03	

Containment

	DUST RESULTS		GW Conc Factor	Fill Conc Factor
	pCi/L	pCi/g	pCi/L per mCi	pCi/g per mCi
Co-60	1.26E-06	2.81E-07	4.57E-01	1.02E-01
Cs-134	6.23E-06	2.80E-07	2.26E+00	1.01E-01
Cs-137	6.23E-06	2.80E-07	2.26E+00	1.01E-01
Eu-152	2.95E-06	2.81E-07	1.07E+00	1.02E-01
Eu-154	2.95E-06	2.81E-07	1.07E+00	1.02E-01
H-3	1.69E-03	0.00E+00	6.13E+02	0.00E+00
Ni-63	4.53E-06	2.81E-07	1.64E+00	1.02E-01
Sr-90	1.14E-04	2.62E-07	4.13E+01	9.50E-02

Spent Fuel Pool/Transfer Tunnels

	DUST RESULTS		GW Conc Factor	Fill Conc Factor
	pCi/L	pCi/g	pCi/L per mCi	pCi/g per mCi
Co-60	4.25E-07	9.48E-08	5.45E-01	1.22E-01
Cs-134	1.13E-05	5.09E-07	1.45E+01	6.53E-01
Cs-137	4.07E-05	1.83E-06	5.22E+01	2.35E+00
Eu-152	1.75E-06	1.68E-07	2.24E+00	2.15E-01
Eu-154	1.37E-06	1.30E-07	1.76E+00	1.67E-01
H-3	1.49E-02	0.00E+00	1.91E+04	0.00E+00
Ni-63	3.13E-05	1.94E-06	4.01E+01	2.49E+00
Sr-90	3.21E-04	7.38E-07	4.12E+02	9.46E-01

Turbine

	DUST RESULTS		GW Conc Factor pCi/L per mCi	Fill Conc Factor	
	pCi/L	pCi/g		pCi/g per mCi	
Co-60	1.68E-06	3.74E-07		1.14E-01	2.55E-02
Cs-134	8.29E-06	3.73E-07		5.65E-01	2.54E-02
Cs-137	8.29E-06	3.73E-07		5.65E-01	2.54E-02
Eu-152	3.93E-06	3.74E-07		2.68E-01	2.55E-02
Eu-154	3.93E-06	3.74E-07		2.68E-01	2.55E-02
H-3	2.25E-03	0.00E+00		1.53E+02	0.00E+00
Ni-63	6.02E-06	3.73E-07		4.10E-01	2.54E-02
Sr-90	1.52E-04	3.49E-07		1.04E+01	2.38E-02

Crib House/Forebay

	DUST RESULTS		GW Conc Factor pCi/L per mCi	Fill Conc Factor	
	pCi/L	pCi/g		pCi/g per mCi	
Co-60	6.78E-07	1.51E-07		9.77E-02	2.18E-02
Cs-134	3.35E-06	1.51E-07		4.83E-01	2.18E-02
Cs-137	3.35E-06	1.51E-07		4.83E-01	2.18E-02
Eu-152	1.59E-06	1.51E-07		2.29E-01	2.18E-02
Eu-154	1.59E-06	1.51E-07		2.29E-01	2.18E-02
H-3	9.08E-04	0.00E+00		1.31E+02	0.00E+00
Ni-63	2.44E-06	1.51E-07		3.52E-01	2.18E-02
Sr-90	6.14E-05	1.41E-07		8.85E+00	2.03E-02

Waste Water Treatment Facility

	DUST RESULTS		GW Conc Factor pCi/L per mCi	Fill Conc Factor	
	pCi/L	pCi/g		pCi/g per mCi	
Co-60	2.34E-05	5.22E-06		2.08E+01	4.64E+00
Cs-134	1.16E-04	5.20E-06		1.03E+02	4.63E+00
Cs-137	1.16E-04	5.20E-06		1.03E+02	4.63E+00
Eu-152	5.43E-05	5.21E-06		4.83E+01	4.64E+00
Eu-154	5.48E-05	5.21E-06		4.88E+01	4.64E+00
H-3	3.13E-02	0.00E+00		2.78E+04	0.00E+00
Ni-63	8.40E-05	5.21E-06		7.47E+01	4.64E+00
Sr-90	2.12E-03	4.87E-06		1.89E+03	4.33E+00

BFM Groundwater Dose Factors (Not adjusted for insignificant contributor dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canals	Turbine	Crib House/Forebay ¹	WWTF
	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)
Co-60	1.00E-04	1.14E-02	0.00E+00	2.87E-03	2.85E-03	5.21E-01
Cs-134	9.27E-03	1.98E-01	0.00E+00	4.94E-02	4.91E-02	9.03E+00
Cs-137	2.64E-02	1.57E-01	0.00E+00	3.92E-02	3.90E-02	7.17E+00
Eu-152	5.96E-05	3.87E-03	0.00E+00	9.69E-04	9.64E-04	1.75E-01
Eu-154	6.77E-05	5.62E-03	0.00E+00	1.41E-03	1.40E-03	2.56E-01
H-3	6.21E-03	2.72E-02	0.00E+00	6.80E-03	6.75E-03	1.23E+00
Ni-63	2.86E-04	1.61E-03	0.00E+00	4.01E-04	4.00E-04	7.31E-02
Sr-90	3.29E-01	4.51E+00	0.00E+00	1.13E+00	1.12E+00	2.06E+02

BFM Drilling Spoils Dose Factors (Reference: TSD 14-021, Table 5) (Not adjusted for insignificant contributor dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canals	Turbine	Crib House/Forebay ¹	WWTF
	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)
Co-60	1.07E-02	2.97E-02	1.58E-01	9.58E-03	2.07E-02	2.26E-01
Cs-134	6.29E-03	1.72E-02	9.41E-02	5.54E-03	1.19E-02	1.31E-01
Cs-137	3.22E-03	7.27E-03	4.83E-02	2.35E-03	5.05E-03	5.57E-02
Eu-152	5.02E-03	1.38E-02	7.46E-02	4.45E-03	9.58E-03	1.05E-01
Eu-154	5.57E-03	1.46E-02	8.25E-02	4.73E-03	1.02E-02	1.12E-01
H-3	0.00E+00	0.00E+00	1.45E-09	0.00E+00	0.00E+00	0.00E+00
Ni-63	3.23E-08	5.61E-08	3.78E-07	1.86E-08	4.81E-08	4.16E-07
Sr-90	6.26E-05	1.39E-04	7.60E-04	4.61E-05	1.16E-04	1.04E-03

Note 1: The Crib House/Forebay Groundwater and Drilling Spoils Dose Factors was adjusted higher to account for a revision that lowered the void volume. The demolition plan for the Crib House was revised to leave the interior walls as opposed to removing all interior walls per the original demolition plan. This resulted in a decrease in the Crib House saturated zone fill mass in the Basement Fill Model with a corresponding increase in the pCi/g and pCi/L values calculated in TSD 14-009. The BFM and DS dose factors are both directly proportional to the pCi/g and pCi/L concentrations which are inversely proportional to the ratio of the Revised Volume to the Original Volume for the Crib House/Forebay combined. The revised Crib House/Forebay volume and the ratio of the Revised/Original volume is provided in TSD 14-014, Revision 1 (Table 38)

Ratio of Revised/Original Crib House/Forebay Volume = 8.60E-01

Soil DCGLs for ROC with Without insignificant Contributor Adjustment

Radionuclide	Surface Soil DCGL without Adjustment for Insignificant Contributors	Subsurface Soil DCGL without Adjustment for Insignificant Contributors
	(pCi/g)	(pCi/g)
Co-60	4.734E+00	3.825E+00
Cs-134	7.524E+00	4.930E+00
Cs-137	1.576E+01	8.606E+00
Ni-63	3.969E+03	8.478E+02
Sr-90	1.343E+01	1.840E+00

Soil DCGLs for ROC with Insignificant Contributor Adjustment

Radionuclide	Surface Soil DCGL	Subsurface Soil DCGL
	(pCi/g)	(pCi/g)
Co-60	4.261	3.443
Cs-134	6.772	4.437
Cs-137	14.184	7.745
Ni-63	3572.100	763.020
Sr-90	12.087	1.656

Insignificant radionuclide dose fraction	10.000%
Adjustment Fraction	0.900

Table 17 – Industrial Use Concentrations “DCGLs” and Adjusted DCGLs

Soil DCGL Insignificant Contributor Dose Fraction Applied to Industrial Use DCGL

Soil Insignificant radionuclide dose fraction	0.171%
Soil Adjustment Fraction	0.998

Radionuclide	Industrial Use DCGL		Adjusted Industrial Use DCGL	
	(pCi/g)		(pCi/g)	
Co-60	12.36		12.34	
Cs-134	23.37		23.33	
Cs-137	55.86		55.76	
Eu-152	27.48		27.43	
Eu-154	25.47		25.43	
H-3	1819.00		1815.89	
Ni-63	9.50E+06		9.48E+06	
Sr-90	14.09		14.07	

Soil DCGLs Using Minimum Site-Specific Soil Kd Values

Radionuclide	Kd	Surface Soil DCGL without	Subsurface Soil DCGL without
		Adjustment for Insignificant Contributors	Adjustment for Insignificant Contributors
		(pCi/g)	(pCi/g)
Co-60	1161	4.734	3.825
Cs-134	615	7.524	4.930
Cs-137	615	15.76	8.606
Ni-63	62	3995	848.6
Sr-90	2.3	14.36	1.860

Soil DCGLs Using Maximum Site-Specific Soil Kd Values

Radionuclide	Kd	Surface Soil DCGL without	Subsurface Soil DCGL without
		Adjustment for Insignificant Contributors	Adjustment for Insignificant Contributors
		(pCi/g)	(pCi/g)
Co-60	1161	4.734	3.825
Cs-134	635	7.523	4.930
Cs-137	635	15.76	8.606
Ni-63	331	3969	847.8
Sr-90	3.4	13.43	1.840

Ratio of DCGLs (Maximum Kd DCGL/Minimum Kd DCGL)

Radionuclide	Surface Soil Ratio	Subsurface Soil Ratio
Co-60	1.00	1.00
Cs-134	1.00	1.00
Cs-137	1.00	1.00
Ni-63	0.99	1.00
Sr-90	0.94	0.99

Dose Assessment Clean Concrete Fill at Detection Limit

Inputs to Calculation

Turbine Clean Concrete Fill Surface Area and Volume (Reference: 6/29/16 email from Don Roth)

	U1 SURFACE AREA (SQ. FT.)	U2 SURFACE AREA (SQ. FT.)
EL 592 SLABS	61,164	61,164
EL 609 & 617 SLABS	52,848	52,848
EL 630 SLABS	14,654	14,654
EL 642 SLABS	83,420	83,420
EL 592 BEAMS	3,800	3,800
TURBINE FOUNDATION	59,981	59,981
PERIMETER WALLS	1,728	1,728
MASONRY WALLS	56,570	56,570
TOTALS	334,165	334,165

Volume of Clean Turbine Concrete to be Used as Fill	
Volume	21,525 cubic yard
Volume	1.65E+04 m3

Containment Clean Concrete Fill Surface Area and Volume (Drawing B-210, Reactor Building Containment Structural Arrangement Zion Station Unit No. 1&2 Commonwealth Edison Co. Chicago Illinois)

Containment Dimensions (cylinder)		
Diameter Exterior	147.00 ft	
Diameter Interior	140.00 ft	
Cylinder Height	171.50 ft	
Thickness	3.50 ft	
Containment Dimensions (Roof)		
Dome Radius Exterior	20.17 ft	
Dome Radius Interior	17.50 ft	
Thickness	2.67 ft	
Conversion Factor	929.03 cm2/ft2	
Conversion Factor	28316.80 cm3/ft3	
Containment Cylinder Surface Area and Volume		
Area of Outer Surface	7.92E+04 ft2	7.36E+07 cm2
Area of Inner Surface	7.54E+04 ft2	7.01E+07 cm2
Volume of Concrete Fil	2.71E+05 ft3	7.66E+09 cm3
Containment Roof Surface Area and Volume		
Area of Outer Surface	2.56E+03 ft2	2.37E+06 cm2
Area of Inner Surface	1.92E+03 ft2	1.79E+06 cm2
Volume of Concrete Fil	5.96E+03 ft3	1.69E+08 cm3
Containment Total Volume (one unit)		7.83E+03 m3

Total Clean Concrete Fill Volume - Containment plus Turbine	3.21E+04 m3
--	--------------------

Conversion Factors and Assumptions

Conversion Factor	0.0929 m2/ft2
Conversion Factor	1.0000E+06 cm3 per m3
Conversion Factor	1.000E+04 cm2 per m2
concrete density	2.35 g/cm3
Non-detect Maximum	5000 dpm/100 cm2
Conversion factor	2.2 dpm/pCi
Conversion Factor	1.00E-09 mCi/pCi
conversion Factor	7.65E-01 m3/yd3
Conversion Factor	7.65E+05 cm3/yd3

Calculation

Total Inventory Gamma in Turbine Clean Concrete Debris at MDC	1.41E+01 mCi
Total Inventory Gamma in Containment Clean Concrete Debris at MDC	6.72E+00 mCi

Inventory per m3 of fill

Turbine	8.57E-04 mCi/m3
Containment	4.29E-04 mCi/m3

Basement	Fill Volume (m3) ¹	gamma inventory (mCi)
Unit 1 Containment Bu	1.21E+04	1.04E+01
Unit 2 Containment Bu	1.21E+04	1.04E+01
Auxiliary Building	3.76E+04	3.22E+01
Turbine Building	4.26E+04	3.65E+01
Crib House and Foreba	3.92E+04	3.36E+01
WWTF	1.01E+03	8.66E-01
Spent Fuel Pool and Tr:	1.04E+03	8.92E-01

Note 1: Fill volumes from TSD 14-021 Revision 1, Table 23

Insignificant Contributor (IC) Dose Adjustment Factor:

	Assigned IC Dose Percentage	IC Dose Adjustment Factor
Auxiliary	5.00%	1.05
Containment	10.00%	1.11
Basements other than Auxiliary and Containment	5.00%	1.05

Basement Dose Factors (adjusted for insignificant dose contribution)

	Auxiliary (mrem/y per mCi)	Containment (mrem/y per mCi)	Spent Fuel Pool/ Transfer Canals ¹ (mrem/y per mCi)	Turbine (mrem/y per mCi)	Crib House/ Forebay (mrem/y per mCi)	WWTF (mrem/y per mCi)
Co-60	1.14E-02	4.44E-02	4.44E-02	1.30E-02	2.46E-02	7.60E-01
Cs-134	1.59E-02	2.17E-01	2.17E-01	5.52E-02	6.16E-02	9.17E+00
Cs-137	2.98E-02	1.65E-01	1.65E-01	4.17E-02	4.43E-02	7.22E+00
Eu-152	5.35E-03	1.92E-02	1.92E-02	5.65E-03	1.10E-02	2.86E-01
Eu-154	5.93E-03	2.19E-02	2.19E-02	6.38E-03	1.21E-02	3.74E-01
H-3	6.21E-03	2.72E-02	2.72E-02	6.80E-03	6.75E-03	1.23E+00
Ni-63	2.86E-04	1.61E-03	1.61E-03	4.01E-04	4.00E-04	7.31E-02
Sr-90	3.29E-01	4.51E+00	4.51E+00	1.13E+00	1.12E+00	2.06E+02

Note 1: SFP/Transfer Canal Dose Factors set equal to Containment to account for groundwater pathway

Maximum Basement Activity

	mCi	mCi	mCi	mCi	mCi	mCi
Co-60	2.20E+03	5.63E+02	5.63E+02	1.93E+03	1.01E+03	3.29E+01
Cs-134	1.57E+03	1.15E+02	1.15E+02	4.53E+02	4.06E+02	2.73E+00
Cs-137	8.40E+02	1.52E+02	1.52E+02	6.00E+02	5.64E+02	3.46E+00
Eu-152	4.68E+03	1.30E+03	1.30E+03	4.43E+03	2.26E+03	8.76E+01
Eu-154	4.22E+03	1.14E+03	1.14E+03	3.92E+03	2.06E+03	6.69E+01
H-3	4.03E+03	9.20E+02	9.20E+02	3.68E+03	3.71E+03	2.02E+01
Ni-63	8.75E+04	1.56E+04	1.56E+04	6.23E+04	6.25E+04	3.42E+02
Sr-90	7.59E+01	5.54E+00	5.54E+00	2.21E+01	2.22E+01	1.21E-01

ROC Mixture for Containment (Reference: TSD 14-019, Revision 1 Table 20)

	Percent Activity	Ratio to Cs-137
Co-60	4.675%	6.92E-02
Cs-134	0.008%	1.21E-04
Cs-137	67.582%	1.00E+00
Eu-152	0.436%	6.45E-03
Eu-154	0.058%	8.57E-04
H-3	0.074%	1.10E-03
Ni-63	26.275%	3.89E-01
Sr-90	0.027%	4.05E-04
ROC Total Percent Acti	99.136%	
Insignificant Contribut	0.864%	
Total	100.000%	

ROC Mixture for Auxiliary Basement (Reference: TSD 14-019, Revision 1 Table 20)

	Percent Activity	Ratio to Cs-137
Co-60	0.908%	1.22E-02
Cs-134	0.010%	1.38E-04
Cs-137	74.597%	1.00E+00
Ni-63	23.480%	3.15E-01
Sr-90	0.051%	6.83E-04
ROC Total	99.046%	
Percent Activity		
Insignificant Con	0.954%	
Total	100.00%	

Clean Concrete Hypothetical Dose Containment ROC Mixture

	Auxiliary	Containment	Spent Fuel Pool/ Transfer Canals	Turbine	Crib House/ Forebay	WWTF
	mrem/yr	mrem/yr	mrem/yr	mrem/yr	mrem/yr	mrem/yr
Co-60	2.54E-02	3.19E-02	2.74E-03	3.27E-02	5.73E-02	4.55E-02
Cs-134	6.18E-05	2.71E-04	2.33E-05	2.43E-04	2.50E-04	9.57E-04
Cs-137	9.60E-01	1.71E+00	1.47E-01	1.52E+00	1.49E+00	6.26E+00
Eu-152	1.11E-03	1.28E-03	1.10E-04	1.33E-03	2.40E-03	1.60E-03
Eu-154	1.64E-04	1.95E-04	1.67E-05	2.00E-04	3.49E-04	2.77E-04
H-3	2.19E-04	3.09E-04	2.65E-05	2.72E-04	2.48E-04	1.17E-03
Ni-63	3.58E-03	6.48E-03	5.57E-04	5.70E-03	5.23E-03	2.46E-02
Sr-90	4.30E-03	1.90E-02	1.63E-03	1.67E-02	1.53E-02	7.22E-02
Total	9.94E-01	1.77E+00	1.52E-01	1.58E+00	1.57E+00	6.40E+00

Clean Concrete Hypothetical Dose Auxiliary ROC Mixture

	Auxiliary	Containment	Spent Fuel Pool/ Transfer Canals	Turbine	Crib House/ Forebay	WWTF
	mrem/yr	mrem/yr	mrem/yr	mrem/yr	mrem/yr	mrem/yr
Co-60	4.47E-03	5.61E-03	4.82E-04	5.76E-03	1.01E-02	8.00E-03
Cs-134	7.08E-05	3.11E-04	2.67E-05	2.79E-04	2.86E-04	1.10E-03
Cs-137	9.60E-01	1.71E+00	1.47E-01	1.52E+00	1.49E+00	6.26E+00
Ni-63	2.90E-03	5.25E-03	4.51E-04	4.61E-03	4.23E-03	1.99E-02
Sr-90	7.25E-03	3.20E-02	2.75E-03	2.82E-02	2.58E-02	1.22E-01
Total	9.74E-01	1.75E+00	1.51E-01	1.56E+00	1.53E+00	6.41E+00

Calculation of Basement Surface DCGLs (pCi/m²)

Inputs to Calculation

Conversion Factor	1.00E+09 pCi/mCi
Dose Limit	25 mrem/yr
Conversion Factor	0.0929 m ² /ft ²
Conversion Factor	0.0283 m ³ /ft ³

BFM Groundwater Dose Factors (Not adjusted for insignificant contributor dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/Forebay	WWTF
	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)
Co-60	1.00E-04	1.14E-02	0.00E+00	2.87E-03	2.85E-03	5.21E-01
Cs-134	9.27E-03	1.98E-01	0.00E+00	4.94E-02	4.91E-02	9.03E+00
Cs-137	2.64E-02	1.57E-01	0.00E+00	3.92E-02	3.90E-02	7.17E+00
Eu-152	5.96E-05	3.87E-03	0.00E+00	9.69E-04	9.64E-04	1.75E-01
Eu-154	6.77E-05	5.62E-03	0.00E+00	1.41E-03	1.40E-03	2.56E-01
H-3	6.21E-03	2.72E-02	0.00E+00	6.80E-03	6.75E-03	1.23E+00
Ni-63	2.86E-04	1.61E-03	0.00E+00	4.01E-04	4.00E-04	7.31E-02
Sr-90	3.29E-01	4.51E+00	0.00E+00	1.13E+00	1.12E+00	2.06E+02

BFM Drilling Spoils Dose Factors (Not adjusted for insignificant contributor dose)

	Auxiliary ¹	Containment ¹	Spent Fuel Pool/Transfer Canal	Turbine ¹	Crib House/Forebay ¹	WWTF ¹
	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)
Co-60	1.07E-02	2.97E-02	1.58E-01	9.58E-03	2.07E-02	2.26E-01
Cs-134	6.29E-03	1.72E-02	9.41E-02	5.54E-03	1.19E-02	1.31E-01
Cs-137	3.22E-03	7.27E-03	4.83E-02	2.35E-03	5.05E-03	5.57E-02
Eu-152	5.02E-03	1.38E-02	7.46E-02	4.45E-03	9.58E-03	1.05E-01
Eu-154	5.57E-03	1.46E-02	8.25E-02	4.73E-03	1.02E-02	1.12E-01
H-3	1.45E-09	1.45E-09	1.45E-09	1.45E-09	1.45E-09	1.45E-09
Ni-63	3.23E-08	5.61E-08	3.78E-07	1.86E-08	4.81E-08	4.16E-07
Sr-90	6.26E-05	1.39E-04	7.60E-04	4.61E-05	1.16E-04	1.04E-03

Note 1: BFM DFs for H-3 were reported as zero in TSD 14-019, Table 11. A non-zero value is required for the DCGL calculation. The lowest non-zero DF reported for all nuclides was H-3 in the SFP which was conservatively applied as the H-3 DF for all Basements.

Basement Surface Areas

Survey Unit	Wall and Floor Surface Area m ²
Auxiliary Building 542	
Floor and All Walls	6503
Containment Basement	2759
SFP/Transfer Canal ³	723
Turbine Building	
Basement	14864
Crib House/Forebay ^{1,2}	13842
WWTF	1124

Reference: TSD 14-014, Table 64

Note 1: Crib House/Forebay Volume listed in TSD 14-009, Revision 1 adjusted lower by factor of 0.86 due to revision of decommissioning approach entailing leaving walls
(Reference: TSD 14-014 Revision 1, Table 38)

Correction factor of 1/0.86 already applied to BFM Dose Factors in "ROC BFM Dose Factors" Tab

Note 2: Revised Crib House Forebay Surface Area due to leaving interior walls

Reference: TSD 14-014 Revision 1, Table 64

Note 3: Revised SFP/Transfer Tunnel Surface Area in TSD 14-014, Revision 1

Reference: TSD 14-014 Revision 1, Table 64

	Surface Area ft ²	Surface Area m ²
Circ Water Discharge Tunnel ¹ (2)	52400	4868
Circ Discharge Piping ³	11570	1075
Circ Water Intake Pipe ² (2)	47491	4412
Buttress Pits/Tendon Tunnels ⁴	20626	1916

Note 1: Reference TSD 14-014, Table 64. Area includes Unit 1 and Unit 2 Discharge Tunnels

Note 2: TSD 14-016 Table 46. Area includes Unit 1 and Unit 2 Intake Pipes

Note 3: TSD 14-016, Table 50

Note 4: TSD 14-014, Revision 2, Tables 60 & 63, and TSD 13-005 Rev 1 Table 15

Summation Surface Area Used for Basement DCGL Calculation

Basement	Structure Areas Included in DCGL Calculation	Total SA (m ²)
Containment	Containment + SFP/Transfer Canal	3482
Auxiliary	Auxiliary + SFP/Transfer Canal	7226
Turbine	Turbine + Circulating Water Discharge Tunnels (2) + Circulating Water Intake Pipe (2) + Circ Discharge Pipe + Buttress Pits/Tendon Tunnels	27135
Crib House/Forebay	Crib House/Forebay + Circulating Water Intake Pipe (2)	18254
SFP/Transfer Canal	SFP/Transfer Canal	723

BFM Groundwater DCGLs (Not Adjusted for Insignificant Contributor Dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/Forebay	WWTF
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	3.46E+10	6.28E+08	NA	3.21E+08	4.81E+08	4.27E+07
Cs-134	3.73E+08	3.63E+07	NA	1.86E+07	2.79E+07	2.46E+06
Cs-137	1.31E+08	4.58E+07	NA	2.35E+07	3.51E+07	3.10E+06
Eu-152	5.81E+10	1.85E+09	NA	9.51E+08	1.42E+09	1.27E+08
Eu-154	5.11E+10	1.28E+09	NA	6.55E+08	9.78E+08	8.68E+07
H-3	5.58E+08	2.64E+08	NA	1.36E+08	2.03E+08	1.80E+07
Ni-63	1.21E+10	4.47E+09	NA	2.30E+09	3.42E+09	3.04E+08
Sr-90	1.05E+07	1.59E+06	NA	8.14E+05	1.22E+06	1.08E+05

BFM Drilling Spoils DCGLs (Not Adjusted for Insignificant Contributor Dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/Forebay	WWTF
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	3.23E+08	2.42E+08	2.19E+08	9.61E+07	6.61E+07	9.83E+07
Cs-134	5.50E+08	4.18E+08	3.67E+08	1.66E+08	1.15E+08	1.69E+08
Cs-137	1.07E+09	9.88E+08	7.16E+08	3.93E+08	2.71E+08	4.00E+08
Eu-152	6.89E+08	5.21E+08	4.64E+08	2.07E+08	1.43E+08	2.12E+08
Eu-154	6.22E+08	4.90E+08	4.19E+08	1.95E+08	1.34E+08	1.99E+08
H-3	2.38E+15	4.94E+15	2.38E+16	6.34E+14	9.42E+14	1.53E+16
Ni-63	1.07E+14	1.28E+14	9.15E+13	4.96E+13	2.85E+13	5.34E+13
Sr-90	5.53E+10	5.15E+10	4.55E+10	2.00E+10	1.18E+10	2.14E+10

Basement DCGL_B (Not Adjusted for Insignificant Contributor Dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal ¹	Turbine	Crib House/Forebay	WWTF
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	3.20E+08	1.75E+08	1.75E+08	7.40E+07	5.81E+07	2.97E+07
Cs-134	2.22E+08	3.34E+07	3.34E+07	1.68E+07	2.24E+07	2.43E+06
Cs-137	1.17E+08	4.38E+07	4.38E+07	2.22E+07	3.11E+07	3.08E+06
Eu-152	6.81E+08	4.07E+08	4.07E+08	1.70E+08	1.30E+08	7.94E+07
Eu-154	6.14E+08	3.54E+08	3.54E+08	1.50E+08	1.18E+08	6.04E+07
H-3	5.58E+08	2.64E+08	2.64E+08	1.36E+08	2.03E+08	1.80E+07
Ni-63	1.21E+10	4.47E+09	4.47E+09	2.30E+09	3.42E+09	3.04E+08
Sr-90	1.05E+07	1.59E+06	1.59E+06	8.14E+05	1.22E+06	1.08E+05

Note 1: DCGL_B for SFP/Transfer Canal equal to the lower of the Auxiliary or Containment DCGL which was Containment for all ROC

Insignificant Contributor Dose Adjustment Factor

	Assigned IC Dose Percentage	IC Dose Adjustment Factor
Auxiliary	5.00%	0.95
Containment	10.00%	0.90
Basements other than Auxiliary and Containment	5.00%	0.95

Adjusted BFM Groundwater DCGLs (Adjusted for Insignificant Contributor Dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/ Forebay	WWTF
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	3.28E+10	5.65E+08	NA	3.05E+08	4.57E+08	4.05E+07
Cs-134	3.55E+08	3.27E+07	NA	1.77E+07	2.65E+07	2.34E+06
Cs-137	1.25E+08	4.12E+07	NA	2.23E+07	3.34E+07	2.95E+06
Eu-152	5.52E+10	1.67E+09	NA	9.03E+08	1.35E+09	1.21E+08
Eu-154	4.85E+10	1.15E+09	NA	6.22E+08	9.29E+08	8.24E+07
H-3	5.30E+08	2.38E+08	NA	1.29E+08	1.93E+08	1.71E+07
Ni-63	1.15E+10	4.02E+09	NA	2.18E+09	3.25E+09	2.89E+08
Sr-90	9.98E+06	1.43E+06	NA	7.74E+05	1.16E+06	1.03E+05

Adjusted BFM Drilling Spoils DCGLs (Adjusted for Insignificant Contributor Dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/ Forebay	WWTF
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	3.07E+08	2.18E+08	2.08E+08	9.13E+07	6.28E+07	9.34E+07
Cs-134	5.23E+08	3.77E+08	3.49E+08	1.58E+08	1.09E+08	1.61E+08
Cs-137	1.02E+09	8.89E+08	6.80E+08	3.73E+08	2.58E+08	3.80E+08
Eu-152	6.54E+08	4.69E+08	4.41E+08	1.97E+08	1.36E+08	2.01E+08
Eu-154	5.91E+08	4.41E+08	3.98E+08	1.85E+08	1.28E+08	1.89E+08
H-3	2.26E+15	4.45E+15	2.26E+16	6.02E+14	8.95E+14	1.45E+16
Ni-63	1.02E+14	1.15E+14	8.69E+13	4.71E+13	2.70E+13	5.08E+13
Sr-90	5.25E+10	4.63E+10	4.32E+10	1.90E+10	1.12E+10	2.03E+10

Adjusted Basement DCGL_g (Adjusted for Insignificant Contributor Dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal ¹	Turbine	Crib House/ Forebay	WWTF
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	3.04E+08	1.57E+08	1.57E+08	7.03E+07	5.52E+07	2.83E+07
Cs-134	2.11E+08	3.01E+07	3.01E+07	1.59E+07	2.13E+07	2.31E+06
Cs-137	1.11E+08	3.94E+07	3.94E+07	2.11E+07	2.96E+07	2.93E+06
Eu-152	6.47E+08	3.66E+08	3.66E+08	1.62E+08	1.23E+08	7.55E+07
Eu-154	5.83E+08	3.19E+08	3.19E+08	1.43E+08	1.12E+08	5.74E+07
H-3	5.30E+08	2.38E+08	2.38E+08	1.29E+08	1.93E+08	1.71E+07
Ni-63	1.15E+10	4.02E+09	4.02E+09	2.18E+09	3.25E+09	2.89E+08
Sr-90	9.98E+06	1.43E+06	1.43E+06	7.74E+05	1.16E+06	1.03E+05

Note 1: DCGL for SFP/Transfer Canal equal to the lower of the Auxiliary or Containment DCGL which was Containment for all ROC.

Calculation of Embedded Pipe DCGL

Inputs to Calculation

Conversion Factor	1.00E+09 pCi/mCi
Dose Limit	25 mrem/yr
Conversion Factor	0.0929 m ² /ft ²

Insignificant Contributor Dose Adjustment Factor

	Assigned IC Dose Percentage	IC Dose Adjustment Factor
Auxiliary	0.05	0.95
Containment	0.10	0.90
Basements other than Auxiliary and Containment	0.05	0.95

Auxiliary Basement Embedded Pipe (Floor Drains) (adjusted for insignificant contributor dose)

Inputs to Calculation

Auxiliary Floor Drain Surface Area	299.41 m ²
------------------------------------	-----------------------

Auxiliary Floor Drains DCGL (adjusted for insignificant contributor dose)

	Auxiliary Basement Dose Factor (mrem/y per mCi)	Auxiliary Floor Drain DCGL (pCi/m ²)
Co-60	1.08E-02	7.33E+09
Cs-134	1.56E-02	5.10E+09
Cs-137	2.96E-02	2.68E+09
Ni-63	2.86E-04	2.78E+11
Sr-90	3.29E-01	2.41E+08

Turbine Basement Embedded Pipe (Floor Drains) (adjusted for insignificant contributor dose)

Inputs to Calculation

Turbine Floor Drain Surface Area	302.43 m ²
----------------------------------	-----------------------

Turbine Embedded Pipe DCGL (adjusted for Insignificant Contributor Dose)

	Turbine Basement Dose Factor (mrem/y per mCi)	Turbine Floor Drain DCGL (pCi/m ²)
Co-60	1.25E-02	6.31E+09
Cs-134	5.49E-02	1.43E+09
Cs-137	4.16E-02	1.89E+09
Ni-63	4.01E-04	1.96E+11
Sr-90	1.13E+00	6.94E+07

Unit 1 and Unit 2 Containment Embedded Pipe (IC-Sump Drain) (adjusted for insignificant contributor dose)

Inputs to Calculation

Containment IC-Sump Pipe Surface Area	1.05 m ²
Nominal Area for DCGL Calculation	100 m ²

Containment Unit 1 and Unit 2 IC-Sump Embedded Pipe DCGL¹ (adjusted for insignificant contributor dose)

	Containment Basement Dose Factor (mrem/y per mCi)	IC-Sump Embedded Pipe DCGL (pCi/m ²)
Co-60	4.11E-02	5.47E+09
Cs-134	2.15E-01	1.05E+09
Cs-137	1.64E-01	1.37E+09
Eu-152	1.76E-02	1.28E+10
Eu-154	2.03E-02	1.11E+10
H-3	2.72E-02	8.28E+09
Ni-63	1.61E-03	1.40E+11
Sr-90	4.51E+00	4.98E+07

Note 1: IC-Sump DCGLs listed applies to both Unit 1 and Unit 2 IC-Sump pipes
Unit 1 and Unit 2 IC-sump pipes are separate survey units

Unit 1 and Unit 2 Steam Tunnel Embedded Pipe (Floor Drains) (adjusted for insignificant contributor dose)

Inputs to Calculation

Steam Tunnel Floor Drain Area ¹	46.88 m ²
--	----------------------

Note 1: Larger of Unit 1 and Unit 2 Steam Tunnel drains used to minimize DCGL. Lower drain area is 46.39 m² (Unit 2).

Unit 1 and Unit 2 Steam Tunnel Embedded Pipe DCGL (adjusted for insignificant contributor dose)

	Turbine Basement Dose Factor (mrem/y per mCi)	Turbine Embedded Pipe DCGL (pCi/m ²)
Co-60	1.25E-02	4.07E+10
Cs-134	5.49E-02	9.22E+09
Cs-137	4.16E-02	1.22E+10
Ni-63	4.01E-04	1.26E+12
Sr-90	1.13E+00	4.48E+08

Unit 1 and Unit 2 Tendon Tunnel Embedded Pipe (Floor Drains) (adjusted for insignificant contributor dose)

Inputs to Calculation

Tendon Tunnel Floor Drain Area	51.41 m ²
--------------------------------	----------------------

Tendon Tunnel Embedded Pipe DCGL (adjusted for insignificant contributor dose)

	Containment Basement Dose Factor (mrem/y per mCi)	Turbine Basement Dose Factor (mrem/y per mCi)	Tendon Tunnel Embedded Pipe DCGL Containment (pCi/m ²)	Tendon Tunnel Embedded Pipe DCGL Turbine (pCi/m ²)
Co-60	4.11E-02	1.25E-02	1.06E+10	3.52E+10
Cs-134	2.15E-01	5.49E-02	2.04E+09	7.97E+09
Cs-137	1.64E-01	4.16E-02	2.67E+09	1.05E+10
Eu-152	1.76E-02	5.41E-03	2.48E+10	8.08E+10
Eu-154	2.03E-02	6.14E-03	2.16E+10	7.13E+10
H-3	2.72E-02	6.80E-03	1.61E+10	6.44E+10
Ni-63	1.61E-03	4.01E-04	2.72E+11	1.09E+12
Sr-90	4.51E+00	1.13E+00	9.70E+07	3.87E+08

Drilling Spoils Area Factor Calculation for Class 1 Survey Units

Inputs to Calculation

Adjusted BFM Drilling Spoils DCGL (Adjusted for Insignificant Contributor Dose)

	Auxiliary pCi/m ²	Spent Fuel Pool/Transfer Canal pCi/m ²	Containment pCi/m ²
Co-60	3.07E+08	2.08E+08	2.18E+08
Cs-134	5.23E+08	3.49E+08	3.77E+08
Cs-137	1.02E+09	6.80E+08	8.89E+08
Eu-152	6.54E+08	4.41E+08	4.69E+08
Eu-154	5.91E+08	3.98E+08	4.41E+08
H-3	2.26E+15	2.26E+16	4.45E+15
Ni-63	1.02E+14	8.69E+13	1.15E+14
Sr-90	5.25E+10	4.32E+10	4.63E+10

Adjusted Basement DCGL (Adjusted for Insignificant Contributor Dose)

	Auxiliary pCi/m ²	Spent Fuel Pool/Transfer Canal pCi/m ²	Containment pCi/m ²
Co-60	3.04E+08	1.57E+08	1.57E+08
Cs-134	2.11E+08	3.01E+07	3.01E+07
Cs-137	1.11E+08	3.94E+07	3.94E+07
Eu-152	6.47E+08	3.66E+08	3.66E+08
Eu-154	5.83E+08	3.19E+08	3.19E+08
H-3	5.30E+08	2.38E+08	2.38E+08
Ni-63	1.15E+10	4.02E+09	4.02E+09
Sr-90	9.98E+06	1.43E+06	1.43E+06

Conversion Factor	0.0929 m ² /ft ²
--------------------------	--

Floor Surface Area and Total Surface Area used for DCGL Calculation

	Floor Area (ft ²)	Floor Area ¹ (m ²)	Total Area Used for DCGL Calculation (m ²)
Auxiliary Basement	27149	2522	7226
SFP/Transfer Canal	2448	227	723
Containment	16489	1532	3482

Note 1: Reference TSD 14-021 , Revision 1, Table 2

**Concentration Corresponding to 25 mrem/yr for Drilling Spoils Only
Assuming all Activity in Floor (Adjusted for Insignificant Contributor)**

	Auxiliary	Spent Fuel Pool/Transfer Canal	Containment
	pCi/m²	pCi/m²	pCi/m²
Co-60	8.78E+08	6.60E+08	4.95E+08
Cs-134	1.50E+09	1.11E+09	8.56E+08
Cs-137	2.93E+09	2.16E+09	2.02E+09
Eu-152	1.88E+09	1.40E+09	1.07E+09
Eu-154	1.69E+09	1.27E+09	1.00E+09
H-3	6.48E+15	7.18E+16	1.01E+16
Ni-63	2.91E+14	2.76E+14	2.62E+14
Sr-90	1.50E+11	1.37E+11	1.05E+11

Drilling Spoils Area Factors

	Auxiliary	Spent Fuel Pool/Transfer Canal	Containment
Co-60	2.89E+00	4.20E+00	3.15E+00
Cs-134	7.09E+00	3.69E+01	2.84E+01
Cs-137	2.63E+01	5.49E+01	5.13E+01
Eu-152	2.90E+00	3.82E+00	2.91E+00
Eu-154	2.90E+00	3.97E+00	3.15E+00
H-3	1.22E+07	3.02E+08	4.25E+07
Ni-63	2.53E+04	6.87E+04	6.51E+04
Sr-90	1.51E+04	9.60E+04	7.36E+04

BFM Dose Factors for Initial Suite Radionuclides (not adjusted for insignificant contributor dose fraction)

BFM Dose Factors for Initial Suite (Reference:TSD 14-019, Table 12).

Radionuclide	Aux mrem/year per mCi	Containment mrem/year per mCi	Spent Fuel mrem/year per mCi	Turbine mrem/year per mCi	Crib House mrem/year per mCi	WWTF mrem/year per mCi
Ag-108m	1.78E-02	4.61E-02	1.85E-01	1.30E-02	1.77E-02	1.32E+00
Am-241	2.58E-01	1.15E+00	3.06E-03	2.86E-01	2.45E-01	5.22E+01
Am-243	2.64E-01	1.15E+00	2.51E-02	2.86E-01	2.46E-01	5.22E+01
C-14	6.49E-02	2.84E-01	3.72E-06	7.09E-02	6.08E-02	1.29E+01
Cm-243	2.69E-02	1.57E-01	1.56E-02	3.94E-02	3.43E-02	7.09E+00
Cm-244	1.74E-02	1.24E-01	7.09E-04	3.11E-02	2.67E-02	5.66E+00
Co-60	1.08E-02	4.11E-02	1.58E-01	1.25E-02	2.03E-02	7.48E-01
Cs-134	1.56E-02	2.15E-01	9.41E-02	5.49E-02	5.25E-02	9.16E+00
Cs-137	2.96E-02	1.64E-01	4.83E-02	4.16E-02	3.79E-02	7.22E+00
Eu-152	5.08E-03	1.76E-02	7.46E-02	5.41E-03	9.07E-03	2.81E-01
Eu-154	5.63E-03	2.03E-02	8.25E-02	6.13E-03	9.97E-03	3.68E-01
Eu-155	2.91E-04	1.37E-03	4.55E-03	3.77E-04	4.64E-04	4.36E-02
Fe-55	8.09E-07	1.51E-05	3.71E-08	3.78E-06	3.23E-06	6.85E-04
H-3	6.21E-03	2.72E-02	1.45E-09	6.80E-03	5.80E-03	1.23E+00
Nb-94	1.41E-02	2.86E-02	1.79E-01	8.61E-03	1.37E-02	5.55E-01
Ni-59	1.35E-04	5.87E-04	1.77E-07	1.47E-04	1.26E-04	2.67E-02
Ni-63	2.86E-04	1.61E-03	3.78E-07	4.01E-04	3.44E-04	7.31E-02
Np-237	4.92E+01	2.13E+02	3.53E-02	5.34E+01	4.57E+01	9.73E+03
Pm-147	3.01E-05	5.67E-04	1.56E-06	1.42E-04	1.22E-04	2.59E-02
Pu-238	2.11E-01	1.03E+00	1.11E-03	2.56E-01	2.19E-01	4.66E+01
Pu-239	2.61E-01	1.14E+00	1.23E-03	2.84E-01	2.43E-01	5.18E+01
Pu-240	2.61E-01	1.14E+00	1.22E-03	2.84E-01	2.43E-01	5.18E+01
Pu-241	4.58E-03	3.65E-02	5.85E-05	9.11E-03	7.80E-03	1.66E+00
Sb-125	1.32E-02	1.98E-01	4.11E-02	4.99E-02	4.40E-02	8.82E+00
Sr-90	3.29E-01	4.51E+00	7.60E-04	1.13E+00	9.67E-01	2.06E+02
Tc-99 ¹	1.48E-01	6.44E-01	1.45E-09	1.61E-01	1.38E-01	2.93E+01

Note 1: BFM DF for Tc-99 was reported as zero in TSD 14-019, Table 11. A non-zero value is required for the DCGL calculation. The lowest non-zero DF reported for all nuclides in SFP was conservatively applied to Tc-99. The nuclide with the lowest SFP DF was H-3 with a value of 1.45E-09 mrem/yr per mCi and was assigned to Tc-99

Survey Unit	Wall and Floor Surface Area ¹ m ²
Auxiliary Building 542 Floor and All Walls	7226
Containment Basement SFP/Transfer Canal	3482
Turbine Building Basement	723
Crib House/Forebay	27135
WWTF	18254
	1124

Reference:

Dose Limit	25 mrem/yr
Conversion Factor	1.00E+09 pCi/mCi

Combined DCGLs for Initial Suite not adjusted for Insignificant Contributor Dose Fraction

Radionuclide	Auxiliary (pCi/m ²)	Containment pCi/m ²	Spent Fuel pCi/m ²	Turbine pCi/m ²	Crib House pCi/m ²	WWTF pCi/m ²
Ag-108m	1.94E+08	1.56E+08	1.87E+08	7.09E+07	7.73E+07	1.69E+07
Am-241	1.34E+07	6.26E+06	1.13E+10	3.22E+06	5.58E+06	4.26E+05
Am-243	1.31E+07	6.26E+06	1.38E+09	3.22E+06	5.56E+06	4.26E+05
C-14	5.33E+07	2.53E+07	9.29E+12	1.30E+07	2.25E+07	1.72E+06
Cm-243	1.28E+08	4.57E+07	2.22E+09	2.34E+07	3.99E+07	3.14E+06
Cm-244	1.99E+08	5.78E+07	4.88E+10	2.96E+07	5.13E+07	3.93E+06
Co-60	3.20E+08	1.75E+08	2.19E+08	7.40E+07	6.76E+07	2.97E+07
Cs-134	2.22E+08	3.34E+07	3.67E+08	1.68E+07	2.61E+07	2.43E+06
Cs-137	1.17E+08	4.38E+07	7.16E+08	2.22E+07	3.62E+07	3.08E+06
Eu-152	6.81E+08	4.07E+08	4.64E+08	1.70E+08	1.51E+08	7.90E+07
Eu-154	6.14E+08	3.54E+08	4.19E+08	1.50E+08	1.37E+08	6.05E+07
Eu-155	1.19E+10	5.25E+09	7.60E+09	2.45E+09	2.95E+09	5.10E+08
Fe-55	4.28E+12	4.77E+11	9.33E+14	2.44E+11	4.25E+11	3.25E+10
H-3	5.58E+08	2.64E+08	2.38E+16	1.36E+08	2.36E+08	1.80E+07
Nb-94	2.46E+08	2.51E+08	1.93E+08	1.07E+08	9.96E+07	4.00E+07
Ni-59	2.57E+10	1.22E+10	1.95E+14	6.29E+09	1.09E+10	8.33E+08
Ni-63	1.21E+10	4.47E+09	9.15E+13	2.30E+09	3.98E+09	3.04E+08
Np-237	7.04E+04	3.37E+04	9.80E+08	1.73E+04	3.00E+04	2.29E+03
Pm-147	1.15E+11	1.27E+10	2.21E+13	6.49E+09	1.13E+10	8.60E+08
Pu-238	1.64E+07	7.00E+06	3.11E+10	3.60E+06	6.25E+06	4.77E+05
Pu-239	1.32E+07	6.30E+06	2.82E+10	3.24E+06	5.63E+06	4.29E+05
Pu-240	1.33E+07	6.30E+06	2.83E+10	3.24E+06	5.63E+06	4.29E+05
Pu-241	7.56E+08	1.97E+08	5.92E+11	1.01E+08	1.76E+08	1.34E+07
Sb-125	2.63E+08	3.62E+07	8.41E+08	1.85E+07	3.11E+07	2.52E+06
Sr-90	1.05E+07	1.59E+06	4.55E+10	8.14E+05	1.42E+06	1.08E+05
Tc-99	2.34E+07	1.11E+07	2.38E+16	5.72E+06	9.95E+06	7.60E+05

Drill Spoils Dose Factors for Initial Suite (Reference: TSD 14-021)

Nuclide	Aux Building Drill Spoils		SFB Drill Spoils		Turbine Drill Spoils	Crib House Drill Spoils	WWTF Drill Spoils
	mrem/yr per mCi	CTMT Drill Spoils mrem per mCi	mrem/yr per mCi	mrem/yr per mCi	mrem/yr per mCi	mrem/yr per mCi	mrem/yr per mCi
Ag-108m	1.23E-02	2.05E-02	1.85E-01	6.61E-03	1.23E-02	1.57E-01	
Am-241	1.51E-04	3.14E-04	3.06E-03	9.76E-05	1.49E-04	2.91E-03	
Am-243	1.58E-03	2.73E-03	2.51E-02	8.75E-04	1.55E-03	2.16E-02	
C-14	3.08E-07	4.27E-07	3.72E-06	1.42E-07	3.08E-07	3.11E-06	
Cm-243	9.93E-04	1.70E-03	1.56E-02	5.47E-04	9.87E-04	1.34E-02	
Cm-244	2.55E-05	6.63E-05	7.09E-04	1.97E-05	2.50E-05	7.21E-04	
Co-60	1.07E-02	2.97E-02	1.58E-01	9.58E-03	1.78E-02	2.26E-01	
Cs-134	6.29E-03	1.72E-02	9.41E-02	5.54E-03	1.02E-02	1.31E-01	
Cs-137	3.22E-03	7.27E-03	4.83E-02	2.35E-03	4.34E-03	5.57E-02	
Eu-152	5.02E-03	1.38E-02	7.46E-02	4.45E-03	8.24E-03	1.05E-01	
Eu-154	5.57E-03	1.46E-02	8.25E-02	4.73E-03	8.77E-03	1.12E-01	
Eu-155	2.83E-04	4.95E-04	4.55E-03	1.58E-04	2.77E-04	3.84E-03	
Fe-55	2.97E-09	4.20E-09	3.71E-08	1.39E-09	2.97E-09	3.29E-08	
H-3	1.45E-09	1.45E-09	1.45E-09	1.45E-09	1.45E-09	1.45E-09	
Nb-94	1.20E-02	1.98E-02	1.79E-01	6.40E-03	1.19E-02	1.52E-01	
Ni-59	1.51E-08	2.04E-08	1.77E-07	6.77E-09	1.50E-08	1.52E-07	
Ni-63	3.23E-08	5.61E-08	3.78E-07	1.86E-08	4.14E-08	4.16E-07	
Np-237	2.91E-03	4.04E-03	3.53E-02	1.34E-03	2.89E-03	3.01E-02	
Pm-147	9.32E-08	1.68E-07	1.56E-06	5.35E-08	9.15E-08	1.35E-06	
Pu-238	3.97E-05	1.04E-04	1.11E-03	3.08E-05	3.89E-05	1.13E-03	
Pu-239	4.41E-05	1.15E-04	1.23E-03	3.40E-05	4.30E-05	1.25E-03	
Pu-240	4.38E-05	1.14E-04	1.22E-03	3.38E-05	4.28E-05	1.24E-03	
Pu-241	2.97E-06	6.03E-06	5.85E-05	1.88E-06	2.92E-06	5.56E-05	
Sb-125	2.75E-03	4.52E-03	4.11E-02	1.46E-03	2.69E-03	3.45E-02	
Sr-90	6.26E-05	1.39E-04	7.60E-04	4.61E-05	9.96E-05	1.04E-03	
Tc-99	1.45E-09	1.45E-09	1.45E-09	1.45E-09	1.45E-09	1.45E-09	

Note 1: BFM DF for Tc-99 and H-3 were reported as zero in TSD 14-019, Table 11 (except for H-3 in SFP). A non-zero value is required for the DCGL calculation.

The nuclide with the lowest DF was H-3 with a value of 1.45E-09 mrem/yr per mCi which was assigned to Tc-99 and H-3

Drilling Spoils DCGLs for Initial Suite not adjusted for Insignificant Contributor Dose Fraction

Radionuclide	Auxiliary (pCi/m2)	Containment pCi/m2	Spent Fuel pCi/m2	Turbine pCi/m2	Crib House pCi/m2	WWTF pCi/m2
Ag-108m	2.80E+08	3.50E+08	1.87E+08	1.39E+08	1.12E+08	1.42E+08
Am-241	2.29E+10	2.28E+10	1.13E+10	9.44E+09	9.19E+09	7.64E+09
Am-243	2.19E+09	2.63E+09	1.38E+09	1.05E+09	8.82E+08	1.03E+09
C-14	1.12E+13	1.68E+13	9.29E+12	6.51E+12	4.45E+12	7.14E+12
Cm-243	3.49E+09	4.22E+09	2.22E+09	1.69E+09	1.39E+09	1.66E+09
Cm-244	1.36E+11	1.08E+11	4.88E+10	4.69E+10	5.47E+10	3.08E+10
Co-60	3.23E+08	2.42E+08	2.19E+08	9.61E+07	7.69E+07	9.83E+07
Cs-134	5.50E+08	4.18E+08	3.67E+08	1.66E+08	1.34E+08	1.69E+08
Cs-137	1.07E+09	9.88E+08	7.16E+08	3.93E+08	3.16E+08	4.00E+08
Eu-152	6.89E+08	5.21E+08	4.64E+08	2.07E+08	1.66E+08	2.12E+08
Eu-154	6.22E+08	4.90E+08	4.19E+08	1.95E+08	1.56E+08	1.99E+08
Eu-155	1.22E+10	1.45E+10	7.60E+09	5.82E+09	4.94E+09	5.79E+09
Fe-55	1.16E+15	1.71E+15	9.33E+14	6.65E+14	4.62E+14	6.77E+14
H-3	2.38E+15	4.94E+15	2.38E+16	6.34E+14	9.42E+14	1.53E+16
Nb-94	2.87E+08	3.62E+08	1.93E+08	1.44E+08	1.16E+08	1.47E+08
Ni-59	2.28E+14	3.51E+14	1.95E+14	1.36E+14	9.10E+13	1.46E+14
Ni-63	1.07E+14	1.28E+14	9.15E+13	4.96E+13	3.31E+13	5.34E+13
Np-237	1.19E+09	1.78E+09	9.80E+08	6.89E+08	4.74E+08	7.38E+08
Pm-147	3.71E+13	4.26E+13	2.21E+13	1.72E+13	1.50E+13	1.65E+13
Pu-238	8.72E+10	6.91E+10	3.11E+10	2.99E+10	3.52E+10	1.96E+10
Pu-239	7.85E+10	6.27E+10	2.82E+10	2.71E+10	3.18E+10	1.78E+10
Pu-240	7.89E+10	6.29E+10	2.83E+10	2.72E+10	3.20E+10	1.79E+10
Pu-241	1.16E+12	1.19E+12	5.92E+11	4.90E+11	4.69E+11	4.00E+11
Sb-125	1.26E+09	1.59E+09	8.41E+08	6.32E+08	5.09E+08	6.45E+08
Sr-90	5.53E+10	5.15E+10	4.55E+10	2.00E+10	1.37E+10	2.14E+10
Tc-99	2.38E+15	4.94E+15	2.38E+16	6.34E+14	9.42E+14	1.53E+16

Calculation of Penetration DCGs (pCi/m²)

Inputs to Calculation

Conversion Factor	1.00E+09 pCi/mCi
Dose Limit	25 mrem/yr
Conversion Factor	0.0929 m ² /ft ²
Conversion Factor	0.0283 m ³ /ft ³

BFM Groundwater Dose Factors (Not adjusted for insignificant contributor dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/Forebay	WWTF
	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)
Co-60	1.00E-04	1.14E-02	0.00E+00	2.87E-03	2.85E-03	5.21E-01
Cs-134	9.27E-03	1.98E-01	0.00E+00	4.94E-02	4.91E-02	9.03E+00
Cs-137	2.64E-02	1.57E-01	0.00E+00	3.92E-02	3.90E-02	7.17E+00
Eu-152	5.96E-05	3.87E-03	0.00E+00	9.69E-04	9.64E-04	1.75E-01
Eu-154	6.77E-05	5.62E-03	0.00E+00	1.41E-03	1.40E-03	2.56E-01
H-3	6.21E-03	2.72E-02	0.00E+00	6.80E-03	6.75E-03	1.23E+00
Ni-63	2.86E-04	1.61E-03	0.00E+00	4.01E-04	4.00E-04	7.31E-02
Sr-90	3.29E-01	4.51E+00	0.00E+00	1.13E+00	1.12E+00	2.06E+02

BFM Drilling Spoils Dose Factors (Reference: TSD 14-021, Table 5) (Not adjusted for insignificant contributor dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/Forebay	WWTF
	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)	(mrem/y per mCi)
Co-60	1.07E-02	2.97E-02	1.58E-01	9.58E-03	2.07E-02	2.26E-01
Cs-134	6.29E-03	1.72E-02	9.41E-02	5.54E-03	1.19E-02	1.31E-01
Cs-137	3.22E-03	7.27E-03	4.83E-02	2.35E-03	5.05E-03	5.57E-02
Eu-152	5.02E-03	1.38E-02	7.46E-02	4.45E-03	9.58E-03	1.05E-01
Eu-154	5.57E-03	1.46E-02	8.25E-02	4.73E-03	1.02E-02	1.12E-01
H-3	0.00E+00	0.00E+00	1.45E-09	0.00E+00	0.00E+00	0.00E+00
Ni-63	3.23E-08	5.61E-08	3.78E-07	1.86E-08	4.81E-08	4.16E-07
Sr-90	6.26E-05	1.39E-04	7.60E-04	4.61E-05	1.16E-04	1.04E-03

Penetration Surface Area (Reference TSD 14-016)

Basement	Surface Area m ²
Containment	242.36
Auxiliary	948.75
Turbine	1081.14
Crib House/Forebay	1.14
SFP/Transfer Canal	337.45
WWTF	0.89

Ratio of Instant Release Groundwater Concentration versus Diffusion Release for Auxiliary Basement DUST Model

(Reference: BNL Report "Evaluation of Maximum Radionuclide Groundwater Concentrations for Basement Fill Model, Zion Restoraion Project", Revision 3, Attachment G)

	Diffusion Release pCi/L	Instant Release pCi/L	Concentration Ratio
Co-60	2.89E-08	7.58E-07	26.23
Cs-134	7.63E-07	3.75E-06	4.91
Cs-137	2.74E-06	3.75E-06	1.37
Eu-152	1.19E-07	1.78E-06	14.96
Eu-154	9.32E-08	1.78E-06	19.1
H-3	1.01E-03	1.02E-03	1.01
Ni-63	2.11E-06	2.73E-06	1.29
Sr-90	2.18E-05	6.87E-05	3.15

Insignificant Contributor Dose Adjustment Factor

	Assigned IC Dose Percentage	IC Dose Adjustment Factor
Auxiliary	5.00%	0.95
Containment	10.00%	0.90
Basements other than Auxiliary and Containment	5.00%	0.95

Penetration DCGL (Adjusted for Insignificant Contributor Dose)

	Auxiliary	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/Forebay ¹	WWTF ²
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	8.82E+07	2.26E+09	4.45E+08	1.76E+09	NA	NA
Cs-134	3.28E+08	4.32E+08	7.48E+08	4.00E+08	NA	NA
Cs-137	6.17E+08	5.66E+08	1.46E+09	5.29E+08	NA	NA
Eu-152	3.29E+08	5.26E+09	9.44E+08	4.06E+09	NA	NA
Eu-154	2.33E+08	4.58E+09	8.53E+08	3.58E+09	NA	NA
H-3	3.99E+09	3.42E+09	4.84E+16	3.23E+09	NA	NA
Ni-63	6.79E+10	5.78E+10	1.86E+14	5.48E+10	NA	NA
Sr-90	2.41E+07	2.06E+07	9.26E+10	1.94E+07	NA	NA

Note 1: Crib House/Forebay penetration surface area of 1.14 m² will be included with Crib House/Forebay surfaces survey unit - surface DCGL will apply

Note 2: WWTF penetration surface area of 0.89 m² will be included in WWTF surface survey unit - surface DCGL will apply

Lower Action Level for Remediation and Grouting Action of Auxiliary Penetration Survey Unit

	Auxiliary pCi/m ²
Co-60	1.16E+07
Cs-134	4.30E+07
Cs-137	8.11E+07
Eu-152	4.32E+07
Eu-154	3.05E+07
H-3	5.24E+08
Ni-63	8.91E+09
Sr-90	3.17E+06

Basement Wall/Floor Surface DCGLs

	Containment	Spent Fuel Pool/Transfer Canal	Turbine	Crib House/Forebay	WWTF
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Co-60	1.57E+08	1.57E+08	7.03E+07	5.52E+07	2.83E+07
Cs-134	3.01E+07	3.01E+07	1.59E+07	2.13E+07	2.31E+06
Cs-137	3.94E+07	3.94E+07	2.11E+07	2.96E+07	2.93E+06
Eu-152	3.66E+08	3.66E+08	1.62E+08	1.23E+08	7.55E+07
Eu-154	3.19E+08	3.19E+08	1.43E+08	1.12E+08	5.74E+07
H-3	2.38E+08	2.38E+08	1.29E+08	1.93E+08	1.71E+07
Ni-63	4.02E+09	4.02E+09	2.18E+09	3.25E+09	2.89E+08
Sr-90	1.43E+06	1.43E+06	7.74E+05	1.16E+06	1.03E+05

Penetration Remediation and Grouting Action Levels

	Aux/CTMT	Aux/SFP	Aux/Turbine	CTMT/SFP	SFP/Turbine	Minimum Aux, CTMT, SFP, Turbine
Co-60	1.16E+07	1.16E+07	1.16E+07	1.57E+08	7.03E+07	1.16E+07
Cs-134	3.01E+07	3.01E+07	1.59E+07	3.01E+07	1.59E+07	1.59E+07
Cs-137	3.94E+07	3.94E+07	2.11E+07	3.94E+07	2.11E+07	2.11E+07
Eu-152	4.32E+07	4.32E+07	4.32E+07	3.66E+08	1.62E+08	4.32E+07
Eu-154	3.05E+07	3.05E+07	3.05E+07	3.19E+08	1.43E+08	3.05E+07
H-3	2.38E+08	2.38E+08	1.29E+08	2.38E+08	1.29E+08	1.29E+08
Ni-63	4.02E+09	4.02E+09	2.18E+09	4.02E+09	2.18E+09	2.18E+09
Sr-90	1.43E+06	1.43E+06	7.74E+05	1.43E+06	7.74E+05	7.74E+05