

USNRC REGION II
ATLANTA, GEORGIA



JO FEB 11 AM 1:13

February 7, 1980
L-80-47

Central File
50-389

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
St. Lucie Unit 2
Docket No. 50-389

Florida Power & Light Company has reviewed I. E. Bulletin 79-28 regarding the possible defect in certain NAMCO EA 180 Model limit switches. Although NAMCO EA 180 Model limit switches are utilized in some of our safety-related equipment, we are in the process of contacting the applicable vendors to determine which of these switches were fabricated between February and August 1979. Those switches falling between these dates will have their top gasket replaced in accordance with the manufacturer's recommendations.

We expect to submit a complete response to this bulletin by April 1, 1980.

Very truly yours,

J. E. De Mastroy

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/JRP/ah

cc: Harold F. Reis, Esquire

AD/I
2

