

8005020354

P.O. BOX 529100, MIAMI, FL 33152

A012

NAMCO REGION II
ATLANTA, GEORGIA



APR 7 AIO: 35

April 4, 1980
L-80-114

Central File
50-389

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-389
I.E. Bulletin 79-28

Florida Power & Light Company is submitting the following information in response to items 1 through 4 of the subject bulletin.

NAMCO EA-180 model limit switches have been identified as being installed in certain valves and in back draft dampers for the containment fan coolers. Of the above equipment utilizing the NAMCO EA-180 model limit switches, only the back draft dampers for containment fan coolers were found to be incorporating models dated between 02-79 through 09-79. However, the top cover gaskets of these limit switches have already been replaced by the manufacturer.

This closes any action items required by IE Bulletin 79-28.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/JRP/ah

cc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C. 20555

Harold F. Reis, Esquire

OFFICIAL COPY

PEOPLE...SERVING PEOPLE

