

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250

UNIT Turkey Point  
Unit No. 3

DATE May 14, 1978

COMPLETED BY V. T. Chilson

TELEPHONE 305/552-3824

REPORT MONTH April, 1978

Turkey Point Unit No. 3 operated at approximately 100% R.P. during the month, except for the outage of April 19-20, 1978 and the load reductions on April 26 and 28, 1978. Refer to the Unit Shutdowns and Power Reductions Section of the Operating Status report for details.

Major safety-related maintenance performed during the month included inspection of the Rod Control System.

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251  
UNIT Turkey Point  
Unit No. 4  
DATE May 14, 1978  
COMPLETED BY V. T. Chilson  
TELEPHONE 305/552-3824

REPORT MONTH April, 1978

Turkey Point Unit No. 4 operated at approximately 100% R.P. during the month except for the load reduction on April 24-25, 1978 to perform the periodic test of turbine main steam stop, reheat stop, and reheat intercept valves.

No Major safety-related maintenance was performed during the month.

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-335

UNIT St. Lucie  
Unit No. 1

DATE May 14, 1978

COMPLETED BY V. T. Chilson

TELEPHONE 305/552-3824

REPORT MONTH April, 1978

St. Lucie Unit No. 1 remained out of service during the month for scheduled refueling, maintenance, and inspection.

Major safety-related maintenance included:

Performance of Steam Generator Tube Inspection Program.

Refueling operation continued during the month.

