

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8005200595 DOC. DATE: 79/11/03 NOTARIZED: NO
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light Co
 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.

DOCKET #
 05000250
 05000251
05000335

AUTH. NAME: SCHMIDT, A.D.
 RECIP. NAME: AUTHORITY AFFILIATION: Florida Power & Light Co.
 RECIPIENT AFFILIATION: Office of Management and Program Analysis

SUBJECT: Forwards monthly operating repts for Oct 1979.

DISTRIBUTION CODE: A008S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+15
 TITLE: Annual, Semi-Annual & Monthly Operating Reports (OL Stag

NOTES:

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR	ENCL
	05 BC <u>ORB # 1,</u> <u>ORB # 4,</u>	6	6			
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	11 I & E	2	2	14 MPA	2	2
	16 DIR OOR	1	1	18 ENGR BR	1	1
	19 REAC SAFT BR	1	1	20 PLANT SYS BR	1	1
	21 EES	1	1	22 CORE PERF BR	1	1
	23 EFFL TR SYS	1	1	AEOD	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	24 NATL LAB	1	1	25 BROOKHAVEN	1	1
	26 ACRS	15	15			

MAY 22 1980


TOTAL NUMBER OF COPIES REQUIRED: LTTR

40 ENCL 40

MR

50

8005200.595



FLORIDA POWER & LIGHT COMPANY

November 3, 1979

Office of Management Information,
and Program Controls
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Gentlemen:

Attached are the October, 1979, Operating Status Reports for
Turkey Point Unit Nos. 3 and 4 and St. Lucie Unit No. 1.

Very truly yours,

A. D. Schmidt
Vice President
Power Resources

VTC/DDC

cc: Mr. James P. O'Reilly
Robert Lowenstein, Esquire

*Acc 8
S/11*

AVERAGE DAILY UNIT POWER LEVEL

~~8-005200~~

DOCKET NO. 50 - 250
 UNIT Turkey Point
Unit No. 3

DATE Nov. 3, 1979

COMPLETED BY V.T. Chilson

TELEPHONE (305) 552-3824

MONTH OCTOBER, 1979

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	652	17	667
2	604	18	664
3	308	19	664
4	532	20	665
5	646	21	663
6	592	22	664
7	---	23	664
8	---	24	659
9	---	25	657
10	---	26	657
11	---	27	662
12	---	28	667
13	410	29	668
14	664	30	665
15	566	31	665
16	468		

NOTE: Average daily power level greater than 666 MWe due to cooler condenser cooling water.

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.