

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8006230476 DOC. DATE: 80/06/15 NOTARIZED: NO DOCKET # 05000335  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.  
 AUTH. NAME: SCHOPPMAN, M.A. AUTHOR AFFILIATION: Florida Power & Light Co.  
 RECIP. NAME: RECIPIENT AFFILIATION: Region 2, Atlanta, Office of the Director

SUBJECT: LER 80-0242/03L-0: on 800516, while shutdown for refueling, periodic test of engineered safety features showed 10 diesel generators load sequence timers were out of tolerance. Caused by setpoint drift. Maladjusted relays caused other problems.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2  
 TITLE: Incident Reports

NOTES: -----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR	ENCL
	BCCLARK, R. 05	4	4			
INTERNAL:	A/D CORE & CS	1	1	A/D RAD PROT	1	1
	A/D REACT SYS	1	1	A/D TECHNOLOGY	1	1
	AEOD	10	10	AUX SYS BR	1	1
	CHEM ENG BR	1	1	CONT SYS BR	1	1
	CORE PERF BR	1	1	EISENHUT, D.	1	1
	EMERG PREP	1	1	EQUIP QUAL BR	1	1
	HANAUER, S.	1	1	I&C SYS BR	1	1
	I&E 09	2	2	JORDAN, E./IE	1	1
	MOORE, V.	1	1	MPA 11	3	3
	NRC PDR 02	1	1	OP EX EVAL BR	3	3
	OR ASSESS BR	1	1	PPAS	1	1
	QA BR	1	1	<u>REG FILE</u> 01	1	1
	SIT ANAL BR	1	1	SYS INTERAC BR	1	1
	TERA: DOUG MAY	1	1			
EXTERNAL:	ACRS	16	16	LPDR	03	1
	NSIC 04	1	1			

JUN 24 1980

NOTE  
4

511

