



JUN 13 1980  
June 11, 1980  
L-80-177

Mr. James P. O'Reilly, Director, Region II  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII: BRC  
50-335/80-10

Florida Power & Light Company has reviewed the subject inspection report and a response is attached.

There is no proprietary information in the report.

Very truly yours,

A handwritten signature in cursive script, appearing to read "R. Uhrig", is written over the typed name.

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/MAS/pa

Attachment

cc: Harold F. Reis, Esquire

OFFICIAL COPY

8007070/00

RESPONSE TO USNRC I & E INSPECTION REPORT 80-10

Finding:

As required by Criterion V of Appendix B to 10 CFR 50 and as implemented by Section 5.0 of the FPL Topical Quality Assurance Report, "Activities affecting quality shall be prescribed by documented instructions, procedures, drawings... and shall be accomplished in accordance with these instructions, procedures and drawings". Paragraph 5.4.3.1 of FP&L procedure QI 9 PR/PSL-2, the implementing Quality Instruction for the control of NDE, and paragraph 8 of ASNT SNT-TC-1A require a yearly eye examination for NDE personnel.

Contrary to the above, on April 11, 1980 NDE records revealed that for the site Level III examiner, an eye examination had not been administered within the required yearly time frame.

Response:

1. The Level III examiner has satisfactorily passed his eye examination.
2. All affected personnel have been reminded of the need for yearly vision tests and given a recertification schedule for the current year.
3. Full compliance is considered achieved as of this date.

