NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0 1] F L S L S 1 (2) 0 0 - 0 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) [ ] (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
[0 1] REPORT SOURCE L (6) 0 5 0 0 0 3 3 5 (7) 0 5 3 0 8 0 (8) 0 6 2 9 8 0 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0 2] During normal power operation, it was noted that the 31-day fire station
[0 3] inspection interval required by T.S. 4.7.11.2(a) had been exceeded. The
[0 4] stations were not inspected between 2/5/80 and 3/23/80. A routine QC
[0 5] review on 5/30/80 identified the oversight. The inspection on 3/23/80 was
[0 6] satisfactory. There was no adverse effect on public health and safety.
[0 7] For related LERs see 335-78-30 and 335-78-32.
[0 8]

[0 9] SYSTEM CODE A B (11) CAUSE CODE A (12) CAUSE SUBCODE C (13) COMPONENT CODE Z Z Z Z Z Z (14) COMP. SUBCODE Z (15) VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 0 — SEQUENTIAL REPORT NO. 0 2 6 — OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN H (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS (22) 0 0 0 0 ATTACHMENT SUBMITTED N (23) NPRD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER Z (25) COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1 0] Maintenance personnel inadvertently overlooked the inspection while
[1 1] preparing for a scheduled refueling outage. The appropriate personnel
[1 2] have been advised of the importance of performing required inspections.
[1 3]
[1 4]

FACILITY STATUS E (28) % POWER 1 0 0 (29) OTHER STATUS (30) NA — METHOD OF DISCOVERY B (31) — DISCOVERY DESCRIPTION (32) QC Review

ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) — AMOUNT OF ACTIVITY (35) NA — LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE (38) DESCRIPTION (39) NA

PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION (43) NA

PUBLICITY ISSUED N (44) DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER M. A. Schoppman PHONE: 305-552-3802

8 007140 389