

USNRC REC  
ATLANTA, GA



23 AUG 11 4 9: 49

August 4, 1980

L-80-253

Mr. James P. O'Reilly, Director, Region II  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO  
50-335  
IE Bulletin 80-04 Supplemental Report

The St. Lucie Plant NRC Resident Inspector has requested that we supplement our May 8, 1980 response to Bulletin 80-04 (FPL letter L-80-145). In that report we explained that the St. Lucie Plants' Feedwater and Condensate systems were properly isolated on MSIS as provided in the original system designs and that AFW was manually initiated only after operator determination of the appropriate response to avoid overfeeding a faulty steam generator. This subject is discussed in the PSL FSAR (section 6.2.1.3.2, pages 6.2 - 41 through 6.2-49). We also stated that an analysis assuming automatic AFW initiation was in progress to support final installation and activation of the automatic system. This analysis has been completed and was submitted to the Office of Nuclear Reactor Regulation's Division of Licensing on June 20, 1980, (FPL letter L-80-175) with a copy to the Region II Office of Inspection and Enforcement. This letter completes our response to Bulletin 80-04.

Very truly yours,

*fl*

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/PLP/pa

Attachment

cc: Harold F. Reis, Esquire

*ROE*  
*2*  
OFFICIAL

*60*

