

USNRC REGION II
ATLANTA, GEORGIA



30 SEP 16 A 8:37

September 12, 1980
L-80-300

Central File

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO
50-335
IE Bulletin 80-20

Florida Power & Light has reviewed the St. Lucie Plant electrical system and has determined that Westinghouse Type W-2 spring return switches are used in our safety related 4160 V switch gear. In all cases, however, the switches are only used when the breaker is in the test position during maintenance and the switches do not use the neutral function. The neutral position contacts, which caused the problem referenced in the Bulletin, are not utilized.

Very truly yours,

A handwritten signature in cursive script that reads "Robert E. Uhrig".

R.E. Uhrig
Vice President
Advanced Systems & Technology

REU/PLP/md

cc: Mr. Harold F. Reis, Esquire

AO
2

60

OFFICIAL COPY

8009300152

Q

PEOPLE...SERVING PEOPLE