

APPENDIX A

NOTICE OF VIOLATION

Florida Power and Light Company
St. Lucie

License No. DPR-67

Based on the NRC inspection July 8-11, 1980, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

As required by Section 6.8.1 and 6.8.2 of the Technical Specifications, written procedures are required to be established, implemented and maintained covering the following: applicable procedures recommended in Appendix A of Regulatory Guide 1.33; surveillance and test activities of safety related equipment; and, fire protection program implementation. These written procedures are required to be reviewed by the Facility Review Group and approved by the Plant Manager.

Contrary to the above, the surveillance inspections of the fire protection hose stations within safety related areas required by the Technical Specifications are accomplished under a maintenance inspection and work instruction which has not been reviewed by the Facility Review Group and approved by the Plant Manager. Also, the existing maintenance instruction is inadequate in that sufficient detail inspection and acceptance criteria is not provided to assure high quality inspections are accomplished.

This is an infraction.