

ACCESSION NBR: 801215023 DOC. DATE: 80/12/09 NOT RIZED: NO  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.  
 AUTH. NAME AUTHOR AFFILIATION  
 UHRIG, R. E. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 CLARK, R. A. Operating Reactors Branch 3

DOCKET #  
 05000335

SUBJECT: Provides results of containment valve torque & stress analysis completed by Henry Pratt, Co, valve manufacturer.  
 Containment purge valves operable under DBA-LOCA conditions.  
 Forwards completion of containment purging justification.

DISTRIBUTION CODE: A034S COPIES RECEIVED: LTR 3 ENCL 3 SIZE: 3  
 TITLE: Containment Purging

## NOTES:

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTTR	ENCL			LTTR	ENCL
	CLARK, R.	04	7	7				
INTERNAL:	A/D CORE & CS		1	0	CONT SYS BR	12	1	1
	EFF TR SYS BRO8		1	1	EQUIP QUAL BRO9		1	1
	I&E	06	2	2	NRC PDR	02	1	1
	OR ASSESS BR	10	1	1	RAD ASSESS BR11		1	1
	REEVES, E.	14	1	1	<u>REG FILE</u>	01	1	1
	SHUM, D.	15	1	1				
EXTERNAL:	ACRS	13	16	16	LPDR	03	1	1
	NSIC	05	1	1				

DEC 16 1980

TOTAL NUMBER OF COPIES REQUIRED: LTTR 37 ENCL 36

MA 4

100

100-443887-1

1. The first step in the process is to identify the problem or issue that needs to be addressed. This involves gathering information and understanding the context of the problem.

2. Once the problem is identified, the next step is to define the objectives and goals of the project. This helps to clarify what needs to be achieved and provides a clear direction for the team.

3. The third step is to develop a plan or strategy to address the problem. This involves breaking down the problem into smaller, manageable tasks and determining the resources needed to complete them.

4. The fourth step is to implement the plan. This involves putting the strategy into action and monitoring progress to ensure that the project is on track.


5. The final step is to evaluate the results of the project. This involves assessing the outcomes against the objectives and goals and identifying any areas for improvement.

... ..

1. The first step in the process is to identify the problem or issue that needs to be addressed. This involves gathering information and understanding the context of the problem.

1990

[illegible]



December 9, 1980  
L-80-399

Office of Nuclear Reactor Regulation  
Attention: Mr. Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Clark:

Re: St. Lucie Unit #1  
Docket No. 50-335  
Containment Purge

A containment purge valve torque and stress analysis has been completed by Henry Pratt Company, the valve manufacturer. Based on the conservative analysis, the containment purge valves are adequate and operable under DBA-LOCA conditions when the valve disc opening angle is limited to 50 degrees. A modification to limit the valve disc opening angle to 50 degrees has been completed on all six purge valves at St. Lucie Unit 1.

The information in Attachment 1 is also being submitted to close out an NRC information request of November 5, 1979.

With this submittal Florida Power & Light Company has provided all the information and evaluations requested to justify containment purging during normal operation. The effect of purging on ECCS performance, the evaluation of instrumentation and control circuit design, and the valves' integrity against the dynamic forces of a DBA-LOCA have been presented.

Very truly yours,

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/MAS/ras

cc: J. P. O'Reilly, Region II  
Harold F. Reis, Esquire

A034  
5/3

8012150233

A

ATTACHMENT 1

RESPONSE TO ADDITIONAL NRC QUESTIONS  
RELATING TO CONTAINMENT PURGE VALVES

- 1a. Failure of the containment purge system to isolate the containment due to entrained debris in the exhausting fluid (air and steam) is highly unlikely. The two potential types of material which can be postulated to prevent the closure of the purge system isolation valves are low and high density material.

In order for low density material of sufficient size to prevent the isolation of the system, the material would have to travel in a straight path from opposite the valve inlet. In the case of the air supply valve, the valve inlet faces the secondary shield wall and a valve gallery wall. For the air exhaust valve, flow to the valve inlet is through the containment cooling system ring duct header. Debris traveling in these paths is not considered credible.

High density materials (missiles) could be generated by a postulated accident, such as, DBA-LOCA. For these missiles, the primary and secondary shield walls are designed to provide missile shields to contain any missiles generated within the primary coolant system and prevent these impinging upon the steel containment vessel. Both supply and exhaust valves are located against the steel containment vessel.

In conclusion, there are adequate provisions to preclude the failure of the containment purge isolation valves to close due to entrained debris in the fluid stream.

- 1b. The isolation function of the containment purge valves is tested in accordance with Technical Specification 4.6.3.1.2. They are demonstrated operable during the cold shutdown or refueling mode at least once per 18 months by (a) verifying that on a containment isolation test signal, each valve actuates to close and (b) cycling the valves through one complete cycle of full travel and measuring its isolation time.

The leakage rate of the containment purge valves is tested in accordance with Technical Specification 4.6.1.2. In conformance with the criteria of Appendix J, 10 CFR 50 using the methods and provisions of ANSI N45.4-1972, the valves are given local leak detection tests at not less than 39.6 psig at intervals no greater than 24 months. The stated acceptance criteria is that the sum of all local leak rate tests shall not exceed 60 percent of the total containment allowable leak rate.

- 1c. The total release through the containment purge system assuming initially fully open valves, single valve failure, and Tech Spec closure time was reported via our letter to you of December 13, 1979(L-79-347). The air mass loss from containment was calculated to be 5104 pounds.
- 1d. No safety related equipment is located in the flow stream beyond the out-board valves at the supply or exhaust penetrations.
- 1e. The containment purge valves were initially tested by the manufacturer for leakage at the valve's design pressure. The installed valves are tested as indicated in 1b above to insure isolation integrity as required by our Technical Specifications.