

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103130429 DOC. DATE: 81/03/10 NOTARIZED: NO DOCKET #
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Division of Licensing

SUBJECT: Provides info re results of 800826-30 test conducted to demonstrate reactor coolant pump seal design adequacy during postulated station blackout conditions. Major seal failure abnormal leakage did not occur. Results will be included in

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR ENCL SIZE: 3
 TITLE: PSAR/FSAR AMDTS and Related Correspondence


NOTES:


ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	A/D LICENSNG	1	0	YOUNGBLOOD, B	1	0
	RUSHBROOK, M.	1	0	NERSES, V. 04	1	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 07	1	1
	CHEM ENG BR 08	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMERG PREP 22	1	0	EQUIP QUAL BR13	3	3
	GEOSCIENCES 14	1	1	HUM FACT ENG BR	1	1
	HYD/GEO BR 15	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	LIC GUID BR	1	1
	LIC QUAL BR	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDR 02	1	1	OELD	1	0
	OP LIC BR	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
	REG FILE 01	1	1	SIT ANAL BR 24	1	1
	STRUCT ENG BR25	1	1	SYS INTERAC BR	1	1
EXTERNAL:	ACRS 27	16	16	LPDR 03	1	1
	NSIC 05	1	1			

MAR 16 1981


MA 4

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 51





March 10, 1981
L-81-107



Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Unit 2
Docket No. 50-389
Adequacy of Reactor Coolant, Pump Seal Design
During Postulated Station Blackout Conditions

This letter is to report the results of Florida Power and Light Company's test of the reactor coolant pump seals used at St. Lucie Unit 2 under simulated conditions to establish their ability to withstand a station blackout event. The performance of this test has demonstrated that the design of the reactor coolant pump seals is such that no abnormal leakage should be expected to occur from these seals during a postulated loss of all AC power situation when there is no cooling water to the seal coolers.

The test was conducted at the Byron Jackson Pump Division in Los Angeles on August 26-30, 1980, utilizing an actual pump seal cartridge supplied by Florida Power and Light Company from St. Lucie Unit 2.

A test fixture was used which simulated a reactor coolant pump under hot standby conditions. All of the seal related parts were of the same material and geometrical configuration as in the actual pump. The seal cartridge related portions of this fixture, including the shaft, were made dimensionally the same as that of the reactor coolant pump. As specified, hot pressurized water was circulated in the fixture duplicating the internal flow system of the pump. The shaft was sealed at the top of the fixture using the test seal cartridge. The block-off plate or collection chamber was bolted on top of the seal cartridge in order to direct the seal leakage to a measuring system.

Boo!
s
//

8108130429

A



Temperature detectors were placed in various locations as follows: (1) in the lower fixture chamber (location of the reactor coolant pump impeller), (2) in the upper fixture chamber (location of the seal cartridge), and (3) in the upper seal cavity (between the third and vapor seal locations). The seal cartridge pressure connections were used to read the pressure in each seal cavity, and the leakage was piped through heat exchangers to cool this flow so that it would remain a liquid to be measured with a beaker and stop watch. Since this flow exits the pump from the vapor seal, a pressure and temperature gage was placed in this line to record the vapor seal condition.

The seal cartridge was tested with water at 550°F and 2250 psig to duplicate initial conditions expected in the event of a loss of all AC power. These test conditions were maintained for more than 50 hours.

Significant seal failure did not occur during this test and, with the exception of abnormally high vapor seal temperatures and pressures, the controlled leakage was recorded within normal limits during most of the test, although this leakage was two phase flow as determined from the high temperature readings of the water in the upper seal cavity. The maximum seal leakage recorded was 16.1 gph.


The seal cartridge was disassembled and inspected after the test. All pressure containing housings and the seal sleeves were still within the drawing tolerances. Seal damage included a broken vapor seal rotating fact ring, permanent compression of all O-rings, permanent hardening of all U-cups, a slight out-of-round condition in the U-cup followers and the spring holders, and slight distortion of all lapped surfaces.

In conclusion, this severe test demonstrated the capability of a reactor coolant pump seal used at St. Lucie Unit 2 to withstand conditions far in excess of the environment encountered in any hypothetical station blackout event.

As requested in Mr. Robert L. Baer's letter of September 17, 1979, the results of this test will be included in the Final Safety Analysis Report for St. Lucie Unit 2.

If there are any questions concerning this test, please contact us.

Very truly yours,



Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/TCG/mc

cc: J. P. O'Reilly, Director, Region II
Harold F. Reis, Esquire



100-100000-100000

100-100000-100000

Additional copies to:

Chairman Joseph M. Hendrie
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Commissioner Victor Gilinsky
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Commissioner Peter A. Bradford
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Commissioner John F. Ahearne
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Secretary
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555
Attn: Chief, Docketing and
Service Section

Michael Glaser, Esq., Administrative
Judge
Alternate Chairman, Atomic Safety &
Licensing Board
1150 - 17th Street, N.W.
Washington, D.C. 20036

Dr. Marvin M. Mann
Technical Advisor
Atomic Safety & Licensing Board
Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. David L. Hetrick, Administrative
Judge
Professor of Nuclear Engineering
University of Arizona
Tucson, Arizona 85721

Dr. Frank P. Hooper, Administrative
Judge
Resource Ecology Program
School of Natural Resources
University of Michigan
Ann Arbor, Michigan 48104

Martin Harold Hodder, Esq.
1130 N.E. 86th Street
Miami, Florida 33138

Dr. W. Reed Johnson, Administrative
Judge
Atomic Safety & Licensing Appeal Board
Nuclear Regulatory Commission
Washington, D.C.

Richard S. Salzman, Esq., Administrative
Judge
Chairman, Atomic Safety & Licensing
Appeal Board
Nuclear Regulatory Commission
Washington, D.C. 20555

Alan S. Rosenthal, Esq., Administrative
Judge
Chairman
Atomic Safety & Licensing Appeal
Panel
Nuclear Regulatory Commission
Washington, D.C. 20555

Edward Luton, Esq., Administrative
Judge
Chairman, Atomic Safety & Licensing
Board
Nuclear Regulatory Commission
Washington, D.C. 20555

Terence J. Anderson, Esq.
University of Miami
School of Law
Coral Gables, Florida 33134

William D. Paton, Esq.
Counsel for NRC Regulatory Staff
Nuclear Regulatory Commission
Washington, D.C. 20555

William J. Olmstead, Esq.
Nuclear Regulatory Commission
Washington, D.C. 20555

Local Public Document Room
Indian River Junior College Library
3209 Virginia Avenue
Ft. Pierce, Florida 33450

Norman A. Coll, Esq.
Steel, Hector and Davis
1400 Southeast First National
Bank Building
Miami, Florida 33131

