

USNRC REGION II  
ATLANTA, GEORGIA

31 APR 6 8 5: 01



April 3, 1981  
L-81-151

Mr. J. P. O'Reilly, Director, Region II  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:WPK  
St. Lucie Unit 2  
Docket No. 50-389/81-02

In accordance with the request of Mr. W. P. Kleinsorge, this supplementary response is provided to address corrective action taken with respect to storage of valves in response to open infraction 50-389/80-13-01.

The main steam stop valve is designed to function exposed to the atmosphere. The equipment storage/maintenance record card for this valve is being revised to show that the valve can be stored uncovered. This revision will be processed by April 13, 1981.

To assure compliance with quality requirements, separate enclosures are currently being fabricated in the south long term storage area and behind both the stainless steel and carbon steel fabrication shops for ASME Class I, II and III Valve Storage. In addition, heat will be provided to each enclosure. This activity will be completed by April 30, 1981.

Very truly yours,

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/TG/nlc

cc: Harold F. Reis, Esquire

!810.41.40715!