

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-335FLORIDA POWER & LIGHT COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 40 to Facility Operating License No. DPR-67, issued to Florida Power & Light Company (the licensee), which revised the Technical Specifications for operation of the St. Lucie Plant, Unit No. 1 (the facility), located in St. Lucie County, Florida. The amendment is effective as of its date of issuance.

The amendment changes the Technical Specifications to clarify the term "OPERABLE" as it applies to single failure criterion for safety systems and modifies the decay time of spent fuel required for movement of the spent fuel cask, based on correction of a previous analysis error.


The applications for the amendment comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the applications for amendment dated June 20 and October 16, 1980, (2) Amendment No. 40 to License No. DPR-67, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. and at the Indian River Junior College Library, 3209 Virginia Avenue, Ft. Pierce, Florida. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland this 28th day of May 1981.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

