

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8106220283 DOC. DATE: 81/06/11 NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 CLARK, R.A. Operating Reactors Branch 3

SUBJECT: Forwards response to NRC 810511 request for addl info re stretch power application.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 3 ENCL 3 SIZE: 3 711
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

ACTION:	RECIPIENT	COPIES	RECIPIENT		COPIES
	ID CODE/NAME		LTR	ENCL	
	CLARK, R.	04	13	13	
INTERNAL:	D/DIR, HUM FAC 08	1	1		DIR, DIV OF LIC 1 1
	I&E 06	2	2		NRC PDR 02 1 1
	OELD 11	1	0		OR ASSESS BR 10 1 0
	RAD ASMT BR	1	1		REG FILE 01 1 1
EXTERNAL:	ACRS 09	16	16		LPDR 03 1 1
	NSIC 05	1	1		

JUN 23 1981

HA
4

TOTAL NUMBER OF COPIES REQUIRED: LTR 40 ENCL 38

RG

THE UNITED STATES OF AMERICA
 DEPARTMENT OF THE ARMY
 OFFICE OF THE CHIEF OF STAFF
 WASHINGTON, D. C.

MEMORANDUM FOR THE CHIEF OF STAFF
 SUBJECT: [Illegible]


1. [Illegible]

2. [Illegible]

3. [Illegible]

4. [Illegible]

5. [Illegible]



June 11, 1981
L-81-246


Office of Nuclear Reactor Regulation
Attention: Mr. Robert A. Clark, Chief
Operating Reactors Branch #3
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Clark:

Re: St. Lucie Unit 1
Docket No. 50-335
Stretch Power Application

Enclosed is our response to the information request of your letter dated May 11, 1981.

Very truly yours,


Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/DME/ah

Attachment

cc: Mr. J. P. O'Reilly, Region II
Mr. Harold F. Reis, Esquire

A001
s
3/3

8106220 283
p

1944
JAN 10 1944
U.S. DEPT. OF AGRICULTURE
WASHINGTON, D.C.

Question 1

What is the magnitude of the bias applied to increase the maximum calculated radial peaking factors in fuel pins adjacent to CEA water holes?

Response

For the St. Lucie 1 Cycle 4 Stretch Power Analysis, a bias value of 4.9% was applied to increase the maximum radial peaking factors around the water holes. The effects of water hole peaking are included in both the nominal and safety peaking data presented in the Stretch Power Application.

Question 2

For the CEA withdrawal event, it is stated that either the Variable High Power Level or Thermal Margin/Low Pressure trip are used in conjunction with the initial steady state LCOs to prevent DNBR limits from being exceeded. It was our understanding that the CEAW event was reclassified as per CEN-126(F) so that only the High Power Trip or the Variable High Power Trip were required to prevent violation of SAFDLs in lieu of including a pressure bias component in the TM/LP trip algorithm. Explain the continued reliance on the TM/LP trip for the CEAW event depending on the initial conditions and the reactivity insertion rate.

Response

The CEAW event for St. Lucie 1 Cycle 4 stretch power was analyzed without crediting the TM/LP trip. This event was analyzed with the methods reported in CEN-126(F)-P. Although no reliance is placed on the TM/LP trip, it is our best estimate that the TM/LP trip will still act as an additional preventative measure to prevent DNB limits from being exceeded.

Question 3

The key parameters assumed in the full length CEA drop analysis are shown in Table 7.2.4-1. The dropped CEA worth for the unrodded condition has decreased from 0.10% to 0.04% $\Delta\rho$. Please explain this decrease in CEA worth.

Response

The minimum dropped CEA worth presented in Table 7.2.4-1 of 0.04% $\Delta\rho$ is an "enveloping" value which is significantly below the actual reactivity change calculated for Cycle 4. This explanation may also be found in Table 5-5 (Footnote 3) of Section 5 where the



1950

Response Continued

input physics data for the CEA drop analysis is presented. The lowest calculated dropped CEA worth for a configuration which also produces the maximum increase in the radial peaking factor is .10% $\Delta\rho$ and is the same as the value presented for the Cycle 3 reference analysis. The minimum reactivity change is conservative with respect to the CEA drop analysis because it produces the smallest decrease in core power during the event.



11-11-11