

KHNPDCDRAIsPEm Resource

From: Ward, William
Sent: Friday, July 28, 2017 7:07 PM
To: apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource; daegeun.ahn@gmail.com; Andy Jiyong Oh; Jungho Kim (jhokim082@gmail.com); Rob Sweeney (AECOM)
Cc: McCoppin, Michael; Ward, William; Hayes, Michelle; Wagage, Hanry; Steckel, James
Subject: APR1400 Design Certification Application RAI 551-8962 [19.2 - Review of Risk Information Used to Support Permanent Plant-Specific Changes to the Licensing Basis: General Guidance]
Attachments: APR1400 DC RAI 551 SPRA 8962.pdf

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

William R. Ward, P.E.
APR1400 DCA Lead Project Manager
U.S. Nuclear Regulatory Commission
m/s O8-G9
Washington, DC, 20555-0001
NRO/DNRL/Licensing Branch 2
ofc O8-H15
ofc (301) 415-7038

U.S. NRC PROTECTING PEOPLE AND THE ENVIRONMENT
Please consider the environment before printing this email.

Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 610

Mail Envelope Properties (88fa14ea9a5d47498bf29845de569a59)

Subject: APR1400 Design Certification Application RAI 551-8962 [19.2 - Review of Risk Information Used to Support Permanent Plant-Specific Changes to the Licensing Basis: General Guidance]

Sent Date: 7/28/2017 7:06:38 PM

Received Date: 7/28/2017 7:06:39 PM

From: Ward, William

Created By: William.Ward@nrc.gov

Recipients:

"McCoppin, Michael" <Michael.McCoppin@nrc.gov>

Tracking Status: None

"Ward, William" <William.Ward@nrc.gov>

Tracking Status: None

"Hayes, Michelle" <Michelle.Hayes@nrc.gov>

Tracking Status: None

"Wagage, Hanry" <Hanry.Wagage@nrc.gov>

Tracking Status: None

"Steckel, James" <James.Steckel@nrc.gov>

Tracking Status: None

"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>

Tracking Status: None

"KHNPDCDRAIsPEM Resource" <KHNPDCDRAIsPEM.Resource@nrc.gov>

Tracking Status: None

"daegeun.ahn@gmail.com" <daegeun.ahn@gmail.com>

Tracking Status: None

"Andy Jiyong Oh" <jiyong.oh5@gmail.com>

Tracking Status: None

"Jungcho Kim (jhokim082@gmail.com)" <jhokim082@gmail.com>

Tracking Status: None

"Rob Sweeney (AECOM)" <Robert.sweeney@consultant.aecom.com>

Tracking Status: None

Post Office: HQPWMSMRS01.nrc.gov

Files	Size	Date & Time
MESSAGE	679	7/28/2017 7:06:39 PM
APR1400 DC RAI 551 SPRA 8962.pdf		87883

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 551-8962

Issue Date: 07/28/2017

Application Title: APR1400 Design Certification Review – 52-046

Operating Company: Korea Hydro & Nuclear Power Co. Ltd.

Docket No. 52-046

Review Section: 19.02 - Review of Risk Information Used to Support Permanent Plant-Specific Changes to the Licensing Basis: General Guidance

Application Section:

QUESTIONS

19.02-1

10 CFR 52.47 (a)(23) requires applications for light-water reactor designs to include “a description and analysis of design features for the prevention and mitigation of severe accidents, e.g., challenges to containment integrity caused by core-concrete interaction, steam explosion, high-pressure core melt ejection, hydrogen combustion, and containment bypass.” Specifically, SRP Section 19.0 states that the staff review should address the issues identified in SECY-90-016 [[ML003707849](#)] and SECY-93-087 [[ML003708021](#)], which the Commission approved in related SRMs, dated June 26, 1990 [[ML003707885](#)], and July 21, 1993 [[ML003760768](#)], respectively, for prevention and mitigation (e.g., equipment survivability).

APR1400-E-P-NR-14003-P, Rev. 0, “Severe Accident Analysis Report,” Section 3.2 states that “The [Emergency Containment Spray Backup System] ECSBS is actuated 24 hours after the onset of core damage at a flow rate of [proprietary information].” It begins to cool and depressurize the containment atmosphere as shown in Figure 3-7. The result shows that the ECSBS is capable of controlling the containment pressure for a period of 48 hours after 24 hours following the onset of core damage.

When ECSBS adds water into the containment flooding may occur, affecting the equipment relied upon during severe accidents. Therefore, the staff raised this concern during the APR1400 Chapter 19 audit. In response, the applicant presented to the staff the results of flooding evaluation when using ECSBS during severe accidents.

In order for the staff to reach an assurance finding on the conformance to SRP Section 19.0 regarding equipment survivability evaluation, please revise the DCD summarizing the above flooding evaluation.