

Enclosure 3

P. O. BOX 013100, MIAMI, FL 33101



June 16, 1978
L-78-207

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

Re: St. Lucie Unit No. 1
Docket No. 50-335
Diesel Generator Information

The attached information is submitted in response to
a letter from Karl R. Goller dated December 15, 1977.

Very truly yours,

Robert E. Uhrig
Vice President


REU/MAS/bb

Attachment

cc: Mr. James P. O'Reilly, Region II
Harold F. Reis, Esquire

781700051

8107210127 810709
PDR ADOCK 05000335
F PDR



A014
S
11

- S. Are any foreign gases such as propane, freon, halon, carbon dioxide, etc. stored in the: Diesel Engine room?
Yes _____ No x or adjacent buildings? Yes _____ No x

If yes, (other than hand portable fire extinguishers), then identify gases and give approximate tank size.

Gases _____ Volume (ft ³) _____

- T. Does control system automatically bypass, in emergency starting, any engine temporarily out of service for maintenance? Yes _____ No x

If yes, then how many failures to bypass have occurred?

- U. Does the control system automatically override the test mode under emergency conditions? Yes x No _____

- V. Have repetitive mechanical failures occurred in any component part or subsystem of the engine, generator, or switch gear, etc.?
Yes x No _____

If yes, then which part or subsystem? Turbo-charger; loss of lubrication to bearings and gears.

How many failures? 5 (1 pre-op testing; 4 since license) Note: There are 4 turbo-chargers per unit

Give nature of failure. On D/G start, electric oil pump stopped (by design) at 200 rpm, but main oil pump had not developed pressure. Design change implemented 3/78 to preclude recurrence. Re-reportable Occurrence 335-77-42, followup report #1, of 5/15/78

- W. Would periodic (yearly or other) evaluation and/or testing by "outside experts" contribute significantly to the diesel-generator reliability? Yes _____ No x

Give brief reasons for the answer. We have sufficient knowledge available on site or within company. Vendor examination of turbo-chargers has confirmed in-house evaluation alluded to in V. above.

- X. 1. Give the accumulated time-load operating record for each diesel-generator unit from installation to the present (Running Hours):

Preoperational test Date 8-75

: Engine	: Surv. Testing &	: Emergency	: Total
: Serial No.	: Maintenance Hrs.	: and Other	: Hours
:	: No Load : Loaded	: Service Hrs.	:
: 1A.	: ~10	: ~161	: ~ 15
:	:	:	:
: 1B	: ~10	: ~124	: ~ 15
:	:	:	:
:	:	:	:
:	:	:	:
:	:	:	:

NOTE: Total Hours were read off "hour meter". Remaining numbers are rough estimates.

2. Surveillance test load (percent of continuous rating) 30% before 1-78
95-100% after 1-78
3. Give the projected or planned time-load operation for each diesel-generator unit during the next 12 months.

: Surveillance &	: Emergency	: Total
: Maintenance Hrs.	: and other	: Hours
:	: Service Hrs.	:
: ~36	: 0	: ~36
:	:	:
:	:	:

4. Provide the following summary of the periodic surveillance testing experience:

- a. Starting date of surveillance testing (OL date) 3-1-76
b. Periodic test interval monthly; plus every 8 hrs. if other diesel out-of ser
c. Total number of surveillance tests performed ~80*
d. Total number of test failures 6; most recent was 8 mos. ago.

started & ran & then turbo-charger failed failure to start 4 (2 cp. error) failure to accept load 1- would not reach full failure to carry load 1 failures due to operator error 2 load due to failure due to equipment not being operative during emergency turbo-charg conditions 0 problem

- e. Supply a copy of the surveillance test procedures with this completed questionnaire.

* Since OL, ~200 starts

